

إقرار

أنا الموقع أدناه مقدم الرسالة التي تحمل العنوان:

Diesel-Driven Emergency Generation Units For Saudi village in Rafah City-Gaza Strip

أقر بأن ما اشتملت عليه هذه الرسالة إنما هو نتاج جهدي الخاص، باستثناء ما تمت الإشارة إليه
حيثما ورد، وإن هذه الرسالة ككل أو أي جزء منها لم يقدم من قبل لنيل درجة أو لقب علمي أو
بحثي لدى أي مؤسسة تعليمية أو بحثية أخرى.

DECLARATION

The work provided in this thesis, unless otherwise referenced, is the
researcher's own work, and has not been submitted elsewhere for any
other degree or qualification

Student's name:

اسم الطالب/ة: بلال دياب ضميده

Signature:

التوقيع: 

Date:

التاريخ: 2016 / 4 / 16

The Islamic University Of Gaza
Research and Graduate Affairs
Department of Electrical Engineering



Master Thesis

**Diesel-Driven Emergency Generation Units For Saudi village
in Rafah City-Gaza Strip**

Belal D. M. Demada

Advisor

Dr. Assad Abu-Jasser

A Thesis Submitted in Partial Fulfillment of the Requirements for the
Degree of Master of Science in Electrical Engineering.

2016-1437



مكتب نائب الرئيس للبحث العلمي والدراسات العليا هاتف داخلي 1150

الرقم.....ج.س.غ/35/.....Ref

التاريخ.....2016/02/29.....Date

نتيجة الحكم على أطروحة ماجستير

بناءً على موافقة شئون البحث العلمي والدراسات العليا بالجامعة الإسلامية بغزة على تشكيل لجنة الحكم على أطروحة الباحث/ بلال دياب مصطفى ضميده لنيل درجة الماجستير في كلية الهندسة قسم الهندسة الكهربائية - أنظمة التحكم وموضوعها:

تشغيل مولدات الديزل في حالة الطوارئ للحي السعودي في رفح - قطاع غزة Diesel-Engine-Driven Emergency Generation Units For Saudi Village in Rafah city- Gaza Strip

وبعد المناقشة العلنية التي تمت اليوم الاثنين 20 جماد الأولى 1437هـ، الموافق 2016/02/29 الساعة الحادية عشرة صباحاً بمبنى القدس، اجتمعت لجنة الحكم على الأطروحة والمكونة من:

د. أسعد نمر أبو جاسر مشرفاً ورئيساً
د. حاتم علي العايدي مناقشاً داخلياً
د. محمد حاتم مشتهى مناقشاً خارجياً

وبعد المداولة أوصت اللجنة بمنح الباحث درجة الماجستير في كلية الهندسة / قسم الهندسة الكهربائية -

أنظمة التحكم

واللجنة إذ تمنحه هذه الدرجة فإنها توصيه بتقوى الله ولزوم طاعته وأن يسخر علمه في خدمة دينه ووطنه.

والله ولي التوفيق،،،

نائب الرئيس لشئون البحث العلمي والدراسات العليا

أ.د. عبدالرؤف علي المناعمة

صفحة الحكم

DEDICATION

To my parents, my brothers, my sisters, and my wife, who have been a constant source of motivation, inspiration, and support.

ACKNOWLEDGEMENT

I thank Allah, the Lord of the worlds, for His mercy and limitless help and guidance. May peace and blessings be upon Mohammed the last of the messengers.

I would like to express my deep appreciation to my advisor Dr. Assad Abu-Jasser for providing advice, support and excellent guidance. The warm discussions and regular meetings I had with him during this research, contributed greatly to the successful completion of this research.

There are no words that can describe how grateful I am to my family specially my wife for her support and encouragement through the years. My deepest thanks go to my brothers and my sisters for their patience and understanding during my busy schedule.

Table Of Contents

Chapter 1	1
INTRODUCTION.....	1
1.1 Background	1
1.2 Problem Statement	2
1.3 Motivation	2
1.4 Methodology	2
1.5 Literature Review	2
1.6 Thesis Structure	3
Chapter 2	4
ELECTRIC ENERGY IN THE GAZA STRIP	4
2.1 Background	4
2.2 Electricity in Gaza strip.....	5
2.3 Generation Plant in Gaza strip.....	6
2.4 Electrical Energy Price in Gaza Strip.....	7
2.5 The Power Crisis in the Gaza Strip.....	7
Chapter 3	9
STUDY MODEL.....	9
3.1 Background	9
3.2 ETAP Software.....	10
3.3 Simulation in ETAP.....	11
3.3.1 First Transform T1.....	12
3.3.2 Second Transform T2	16
3.3.3 Third Transform T3	21
3.3.4 Fourth Transform T4.....	24
3.3.5 Fifth Transform T5.....	29
3.3.6 Sixth Transform T6.....	33
3.3.7 Seventh Transform T7.....	38
3.3.8 Eighth Transform T8.....	42
Chapter 4	47
SUGGESTED SCHEME.....	47
4.1 Background	47
4.2 Generators Specifications.....	49
4.3 Simulation in ETAP	49
4.4 Case One: Generators Full Capacity Operation	50
4.4.1 Energy Consumption	50
4.4.2 Generator at Standby Rate	51
4.4.3 Generator at Prime Rate	51
4.5 Case Two: Generators Operation at Full Load.....	52
4.5.1 Generator at Standby Rate.....	57
4.5.2 Generator at Prime Rate.....	57
4.6 Case Three: Generators Operating at Full Load without Street Lighting.....	58
4.6.1 Energy Consumption.....	58
4.6.2 Generator at Standby Rate.....	63
4.6.3 Generator at Prime Rate.....	63
4.7 Case Four: Generators Operating at Full Load without Schools.....	64
4.7.1 Energy Consumption.....	64
4.7.2 Generator at Standby Rate.....	69
4.7.3 Generator at Prime Rate.....	69

4.8	Case Five: Generators Operating at Full Load without Streets Lighting and Schools.....	70
4.8.1	Energy Consumption.....	70
4.8.2	Generator at Standby Rate.....	75
4.8.3	Generator at Prime Rate.....	75
4.9	Case Six: Generators Operating at Loads Distributor on 366 Day.....	75
4.9.1	Generator at Standby Rate.....	75
4.9.2	Generator at Prime Rate.....	76
4.10	Comparison between Prime and Standby Rates.....	77
	Chapter 5	78
	FEASIBILITY STUDY.....	78
5.1	Background.....	78
5.2	Annual Income of The Project.....	78
5.3	Payback Period.....	81
5.3.1	Case 1 at NIS 1.5 per KWH.....	81
5.3.2	Case 1 at NIS 2 per KWH.....	81
5.3.3	Case 2 at NIS 1.5 per KWH	82
5.3.4	Case 2 at NIS 2 per KWH	82
5.3.5	Case 3 at NIS 1.5 per KWH	83
5.3.6	Case 3 at NIS 2 per KWH.....	83
5.3.7	Case 4 at NIS 1.5 per KWH	84
5.3.8	Case 4 at NIS 2 per KWH.....	84
5.3.9	Case 5 at NIS 1.5 per KWH.....	85
5.3.10	Case 5 at NIS 2 per KWH	85
5.3.11	Case 6 at NIS 1.5 per KWH	86
5.3.12	Case 6 at NIS 2 per KWH	86
5.3.13	The average cases	87
5.4	Implementation of The Project.....	89
	Chapter 6	90
	CONCLUSIONS AND FUTURE WORK	90
6.1	Conclusions	90
6.2	Future Work	90
	REFERENCES	91

LIST OF FIGURES

Figure 2.1:	The Gaza Strip map	5
Figure 2.2:	Electrical power supply for Gaza Strip.....	6
Figure 2.3:	Electrical deficit for Gaza Strip.....	8
Figure 3.1:	The Saudi village in Auto CAD program.....	11
Figure 3.2:	Branches of Transform T1.....	12
Figure 3.3:	Branches T1A in Transform T1.....	13
Figure 3.4:	Branches T1B in Transform T1.....	14
Figure 3.5:	Branches T1C in Transform T1.....	15
Figure 3.6:	Branches T1D in Transform T1.....	15
Figure 3.7:	Branches in Transform T2.....	16
Figure 3.8:	Branch T2A in Transform T2.....	18
Figure 3.9:	Branch T2B in Transform T2.....	18
Figure 3.10:	Branch T2C in Transform T2.....	19
Figure 3.11:	Branch T2D in Transform T2.....	20
Figure 3.12:	Branch T2E in Transform T2.....	20
Figure 3.13:	Branches in Transform T3.....	21
Figure 3.14:	Branch T3A in Transform T3.....	22
Figure 3.15:	Branch T3B in Transform T3.....	23
Figure 3.16:	Branch T3C in Transform T3.....	23
Figure 3.17:	Branches in Transform T4.....	24
Figure 3.18:	Branch T4A in Transform T4.....	26
Figure 3.19:	Branch T4B in Transform T4.....	26
Figure 3.20:	Branch T4C in Transform T4.....	27
Figure 3.21:	Branch T4D in Transform T4.....	27
Figure 3.22:	Branch T4E in Transform T4.....	28
Figure 3.23:	Branches in Transform T5.....	29
Figure 3.24:	Branch T5A in Transform T5.....	30
Figure 3.25:	Branch T5B in Transform T5.....	31
Figure 3.26:	Branch T5C in Transform T5.....	31
Figure 3.27:	Branch T5D in Transform T5.....	32
Figure 3.28:	Branches in Transform T6.....	33
Figure 3.29:	Branch S.D.B1 Transform T6.....	35
Figure 3.30:	Branch S.D.B2 Transform T6.....	35
Figure 3.31:	Branch S.D.B3 Transform T6.....	36
Figure 3.32:	Branch S.D.B4 Transform T6.....	37
Figure 3.33:	Branch S.D.B5 Transform T6.....	37
Figure 3.34:	Branches in Transform T7.....	38
Figure 3.35:	Branch S.D.B6 Transform T7.....	40
Figure 3.36:	Branch S.D.B7 Transform T7.....	40
Figure 3.37:	Branch S.D.B8 Transform T7.....	41
Figure 3.38:	Branch S.D.B9 Transform T7.....	41
Figure 3.39:	Branches in Transform T8.....	42
Figure 3.40:	Branch S.D.B10 Transform T8.....	44
Figure 3.41:	Branch S.D.B11 Transform T8.....	44
Figure 3.42:	Branch S.D.B12 Transform T8.....	45
Figure 3.43:	Branch S.D.B13 Transform T8.....	45
Figure 3.44:	Branch S.D.B14 Transform T8.....	46
Figure 3.45:	Branch S.D.B15 Transform T8.....	46

Figure 4.1:	Generators Operation during 366 days.....	48
Figure 4.2:	Generator 1 When Operation at Full Load.....	53
Figure 4.3:	Generator 2 When Operation at Full Load.....	53
Figure 4.4:	Generator 3 When Operation at Full Load.....	54
Figure 4.5:	Generator 4 When Operation at Full Load.....	54
Figure 4.6:	Generator 5 When Operation at Full Load.....	55
Figure 4.7:	Generator 6 When Operation at Full Load.....	55
Figure 4.8:	Generator 7 When Operation at Full Load.....	56
Figure 4.9:	Generator 8 During Operation at Full Load.....	56
Figure 4.10:	Generator 1 When Operation at Full Load without Street Lighting.....	59
Figure 4.11:	Generator 2 When Operation at Full Load without Street Lighting.....	59
Figure 4.12:	Generator 3 When Operation at Full Load without Street Lighting.....	60
Figure 4.13:	Generator 4 When Operation at Full Load without Street Lighting.....	60
Figure 4.14:	Generator 5 When Operation at Full Load without Street Lighting.....	61
Figure 4.15:	Generator 6 When Operation at Full Load without Street Lighting.....	61
Figure 4.16:	Generator 7 When Operation at Full Load without Street Lighting.....	62
Figure 4.17:	Generator 8 When Operation at Full Load without Street Lighting.....	62
Figure 4.18:	Generator 1 When Operating at Full Load without Street Schools.....	65
Figure 4.19:	Generator 2 When Operating at Full Load without Street Schools.....	65
Figure 4.20:	Generator 3 When Operating at Full Load without Street Schools.....	66
Figure 4.21:	Generator 4 When Operating at Full Load without Street Schools.....	66
Figure 4.22:	Generator 5 When Operating at Full Load without Street Schools.....	67
Figure 4.23:	Generator 6 When Operating at Full Load without Street Schools.....	67
Figure 4.24:	Generator 7 When Operating at Full Load without Street Schools.....	68
Figure 4.25:	Generator 8 When Operating at Full Load without Street Schools.....	68
Figure 4.26:	Generator 1 When Operating at Full Load without Streets Lighting and Schools.....	71
Figure 4.27:	Generator 2 When Operating at Full Load without Streets Lighting and Schools.....	71
Figure 4.28:	Generator 3 When Operating at Full Load without Streets Lighting and Schools.....	72
Figure 4.29:	Generator 4 When Operating at Full Load without Streets Lighting and Schools.....	72
Figure 4.30:	Generator 5 When Operating at Full Load without Streets Lighting and Schools.....	73
Figure 4.31:	Generator 6 When Operating at Full Load without Streets Lighting and Schools.....	73
Figure 4.32:	Generator 7 When Operating at Full Load without Streets Lighting and Schools.....	74
Figure 4.33:	Generator 8 When Operating at Full Load without Streets Lighting and Schools.....	74

LIST OF TABLE

Table 3.1:	Consumption in Saudi Village in Hour.....	10
Table 3.2:	Load on Transform T1.....	13
Table 3.3:	Load on Transform T2.....	17
Table 3.4:	Load in Transform T3.....	22
Table 3.5:	Load in Transform T4.....	25
Table 3.6:	Load in Transform T5.....	30
Table 3.7:	Load in Transform T6.....	34
Table 3.8:	Load in Transform T7.....	39
Table 3.9:	Load in Transform T8.....	43
Table 4.1:	Generator Capacity at Prime and standby rates (KVA).....	47
Table 4.2:	Generator Cost at Prime and Standby Rate.....	49
Table 4.3:	Various Loading Conditions (KVA).....	50
Table 4.4:	Generator Fuel Consumption and Cost at Full Capacity Operation.....	50
Table 4.5:	Fuel Consumption and Cost from Generator in Prime Rate per Hour...52	
Table 4.6:	Generator Fuel Consumption and Cost at Full Load Operation.....	52
Table 4.7:	Generator Fuel Consumption and Cost at Full Load Operation without Street Lighting per Hour.....	58
Table 4.8:	Generator Fuel Consumption and Cost at Full Load Operation without Schools per Hour.....	64
Table 4.9:	Generators Fuel Consumption and Cost at Full Load Operation without Streets Lighting and Schools per Hour.....	70
Table 4.10:	Comparison Between Prime and Standby Rates \$.....	77
Table 5.1:	Profit in Case one.....	82
Table 5.2:	Profit in Case 2.....	83
Table 5.3:	Profit in Case 3.....	84
Table 5.4:	Profit in Case 4.....	85
Table 5.5:	Profit in Case 5.....	86
Table 5.6:	Profit in Case 6.....	87
Table 5.7:	Profit in Average Cases.....	88
Table 5.1:	Comparison between Profit in Prime and Standby Rates at 1KWh equal 1.5 NIS.....	88
Table5.2:	Comparison between Profit in Prime and Standby Rates at 1KWh equal 2 NIS.....	88
Table5.3:	The Wheeling Cost to All Cases in Prime and Standby Rates.....	89

ABSTRACT

Citizens in the Gaza Strip use small power generation units (3-5KVA) through Gaza Strip streets and markets. You can see many of these units are running on the street with much noise and pollution. This problem increases the suffering of the people in Gaza Strip. In addition to that these units consume large amounts of fuel and more cost on consumers, which cause shortage for cars and transportation from gasoline and diesel, also becoming liability on the people and government to provide fuel to run these units.

This thesis proposes a solution to this problem by using a distributed larger generation units so that these units are connected in a power network. The operation and shutdown of these are based on the local demand for electricity.

This scheme is applied to the Saudi village in the Rafah city. The number of required operating units are computed based on the average demand on power. So that these units operate when the power shortage is on the same electrical grid. A control scheme is proposed for these units for setting up a mechanism to provide these units with fuel.

ETAP software is used for implementation of the project, it is providing the value of load flow analysis, also it is used to calculate the voltage drop and branch losses in cables. We can also obtain a detailed report about the electric grid in the Saudi Neighborhood. The international electrotechnical commission (IEC) standard is used as a reference.

Finally, feasibility studies for the various loading conditions are provided. The study has shown that the payback period varies between 4-5 years at a price of NIS 1.5/kWh and about 1 year at a price of NIS 2/kWh.

CHAPTER 1

INTRODUCTION

1.1 Background

The electric power is an essential foundation for social and economic development in any society. It is the main source of the driving forces in industrial, agricultural residential and business facilities in villages and cities. Providing stable and continuous service to wide range in order to use electricity in industry, commerce, agriculture, residents and public utilities. It is essential to ensure that the electricity is provided to these places with high quality at the lowest possible losses in balancing the load throwing three phases.

Gaza Strip is one of highest overpopulated regions in the world; there are 1.8 million people in 360 km². In addition, it is considered one of the poorest regions in the world of stable electricity [1]. Power networks in Gaza Strip have complex systems that cannot be efficiently and securely operated without any management of energy system [2]. As a result of several years in Israeli siege of the Palestinian Territories, the Palestinian economy suffers from major distortions and underdevelopment. During the Israeli siege, infrastructures of the Gaza Strip are largely destroyed.

Electricity sector in the Palestinian land shows a high vulnerability to political instability. The influence of the conflict on the electricity sector goes beyond direct destruction [3].

It results in a modification of electricity consumption, a deceleration in the growth rate, and the retardation of a “healthy” recovery. Also, the lack of investment, public expenditure, high prices, and high transmission losses and constituting fundamental problems for the electricity sector. The quality of the electrical services is inadequate and below standard [4].

The electrical network in Gaza is considered as radial [2]. A radial network leaves the station and passes through the network area with no normal connection to any other supply. This is typical of long rural lines with isolated load areas. An interconnecting network is generally found in more urban areas, it will have multiple connections to other points of supply. These points of connection are normally open, but they allow various configurations by the operating utility with closing and opening switches. Operation of these switches may be by remote control from a control center or by a lineman. The benefit of the interconnected model is in the event of a fault or required maintenance as a small area of network which can be isolated and the remainder keep on supply [5].

The main sources of electricity in Gaza are: Gaza Power Station, the Israeli Electricity Company, and the limited power line that comes from Egypt, which feeds the southern part of Gaza Strip [6, 7].

1.2 Problem Statement

The Saudi village suffers from the power crisis just like any other area in the Gaza Strip. The power cut-offs take place in the Saudi village on a daily basis. Sometimes at night and sometimes during the day. This causes a suffering of the residents who reside in the village. For this reason, the people have resorted the use of alternative methods as a solution to this problem, such as using small-sized generators and candles.

A proposed system in how to operate diesel generation units to cover the loads to Saudi village during electricity cut-offs. These units are supposed to be connected to the same electrical grid. Preparing a feasibility study of this project is to be presented.

1.3 Motivation

The work of this thesis is to overcome or mitigate the crisis of power outages. It experiences on a daily basis. It works to reduce air pollution and noise which results from the proliferation of small-sized diesel generators and capacitance scattered in the streets and buildings. This causes a lot of fires in homes, which results injuries and deaths, as this project will provide job opportunities.

This project applies to the Saudi village in Rafah city as a model that can be applied to the rest of the region.

1.4 Methodology

1. Field Visits: Visits include the Power and Natural Resources Authority, the Electricity Distribution Company, and the Gaza power Generation Plant. The purpose of these visits are to collect the necessary data from expert engineers such as the electric power problems, the current methods of connecting and disconnecting power, energy quality that reaches to the consumer, etc.
2. Analyze and classify these problems by putting clear description for the most important ones, who use the collected data.
3. Identify similar systems in other countries; also identify their problems and how they are solved.
4. Choose the best way to an electricity generation network in Saudi village.
5. Develop model simulates with distribution of network to test and evaluate the System.
6. Test the developed model and collect the results and feedbacks.

1.5 Literature Review

chirl Park, (1999), proposed models of small turbine generators (i.e. a combustion turbine, a diesel engine, etc), that were used for dynamic distributed generation. Also, he proposed the detailed synchronous machine and the excitation system model were obtained for the standard simulation. The simulation was performed with an infinite bus system model. The synchronous machine was connected with a local load in order to develop the terminal voltage and avoiding the differentiation.

Hermann, (2006), proposed designing a micro-hydro powered battery charging system for rural village electrification. The other investigated and explored the possibilities of battery charging by using small hydropower resources in rural areas with respect to its economical and technical feasibility.

Nayar, Tang and Suponthana (2008), proposed an innovative wind/PV/diesel hybrid system implemented in three remote islands in the Republic of Maldives. The newly developed and installed system can provide very good opportunities to showcase high penetration of renewable energies, also using state of the art wind turbines, photovoltaic modules, advanced power electronics, control technology and the future possibilities of distributed generation in remote locations.

Bustami, (2008), proposed an optimum design and performance analysis of a proposed Palestinian electrical network, where he outlined an integrated electrical network with standard voltages, low power losses, high quality electrical energy, high reliability, source diversity, good voltage level, and low transmission cost. Its integrated model allowed for future connection to the seven Arab country grids, and eventually supplied end users with low cost electrical energy, however, his proposal did not present any approach to monitoring or controlling the network.

Abu Meteir, (2012), proposed designing a Supervisory Control and Data Acquisition (SCADA System) for the management of the electricity network in the Gaza Strip. He expected from this system work to transfer all the data necessary for the system operator, and provide specialists with the necessary information about the network and transformer substations in the sub-regions such as voltage, current and productive capacity in order to reduce losses on the network to help develop plans to manage power distribution in a fair.

1.6 Thesis Structure

The thesis is organized into 6 chapters. Firstly, **chapter 1** begins with an introduction describing the topic to readers. **Chapter 2** covers the Electricity network in the Gaza Strip and the electricity crisis which are found in the Strip. **Chapter 3** covers the electric grid in the Saudi village. **Chapter 4** Presents proposal for resolving the crisis in Saudi village using diesel generators and the costs of these solutions. **Chapter 5** proposes a feasibility study of the proposed solutions. Finally, **Chapter 6** concludes this study and proposes future work and recommendations.

Chapter 2

ELECTRIC ENERGY

IN GAZA STRIP

2.1 Background

The Gaza strip is located at the south-west area of Palestine as shown in Fig. (2.1). It expands along the Mediterranean Sea with 40 km long and between 6 and 12 km wide. The total area of the Gaza strip is estimated at 360 km². Its height above sea level reach 50 m in some locations. It is located on Longitude 34° 26' east and Latitude 31° 10' north [8, 9].

Gaza Strip has come to be known as the fast growing area of the Middle East in terms of population in recent years. It began with a manageable population of 1.2 million in 2002, which reached 1.7 million in 2012. Gaza Strip's population is expected to grow at a rate of 4.2% annually and will reach a total of 2.13 million in 2020 [10].

Energy is vital for all living-beings on earth. Modern life-style has further increases its importance, since a faster life means faster transportation, faster communication and faster manufacturing processes. All these lead to an increase in energy demand that is required for all those modern systems [9].

The Gaza strip population of 1.7 million Palestinians residents must cope with scheduled electricity cuts 8 hours on daily basis due to the increment in annual demand growth. Statistic for energy consumption revealed that the electrical energy consumption per person is the lowest indicator in the region and is estimated at 583kWh as the electrical consumption rose by 28% in Gaza Strip and West bank during the period 2003-2009 [11, 12, 13].

The Palestinian electricity sector suffers from many electrical problems such as high electrical deficit rate, transmission losses, and absent energy management strategies. Energy efficiency improvement is an important way to reduce electrical deficit with various opportunities available in a cost-effective manner [14].

Other problems in the Gaza Strip electric power sector include high system losses, delays in completion of new plants, low plant efficiencies, erratic power supply, electricity theft, blackouts, and shortages of funds for power plant maintenance [15].



Figure 2.1: The Gaza Strip map [16]

2.2 Electricity in Gaza strip

There are multiple sources of electric energy that provide Gaza with electricity. The need of the Gaza Strip's electricity is currently between 350 and 450 MW which is expected to raise up to 600 MW in case of lifting the Israeli siege.

There are three primary sources as shown in Fig. (2.2):

1- The Israeli electricity company, which supplies 120 MW via ten electric lines [17]. Divided as follows:

- Gaza City: Dome line, Baghdad line, Sha'af line, and the sea line (Shared between Gaza City and the north area).
- North area: Jabalya line and Beit Lahiya line.
- Central area: Line K7 and line 11 (shared between the Central area and Khan Younis).
- Khan Younis: Line 8.
- Rafah: Line 9 (joint between Khan Younis and Rafah) [18, 21].

2- The power station in Gaza and its theoretical capacity is to produce 140 MW though its actual average of production is only 80 MW due to the generators transformers have been destroyed in 2006 as a result of the Zionist shelling, also its dependency on the amount of fuel is available for the production of electricity.

3- The Egyptian electricity grid that supplies Gaza with around 27 MW through two main electric lines.



Figure 2.2: Electrical power supply for Gaza Strip in 2010[9]

This means that the total electricity quantity available from the three sources is about 227 MW with a seasonal variation of the electricity needs of Gaza that reach its peak to 440 MW in summer and winter. Accordingly, this shows large deficit up to more than 150 MW, representing 35 % to 40% of the total needs of electricity, which is largely influenced by the change in the supply and demand causing a power failure. [17].

The demand for electricity is growing at a rate of 7% per year without any well designed plan to meet the demand. The main problem of energy in the Gaza Strip is that it has almost no conventional energy sources. This problem becomes worse by the high density pollution of the Gaza strip and the difficult political status which are caused by (Israel) occupation [9].

2.3 Generation Plant in Gaza Strip

In 2003, with generation plant with a nominal power of 120 MW and a capacity that can reach 140 MW, Gaza Strip was set for the next five years. The Western power substation was destroyed by Israel on 28/6/2006 which led to the destruction of transformers up number 4 with voltage rate 220 / 11KV and transformers down with voltage rate 220 / 22KV number 2 where the power plant completely stopped working and the Gaza Strip suffers from a large deficit in the electric power. The value of the damage caused totaled about \$ 6 million. The power station needs to the amount of 650 thousand liters of industrial diesel daily to operate at full capacity (120 MW).

It was planned that the station was expand at several stages to reach production capacity of 570 megawatts, but the Israeli aggression and the siege has prevented the implementation of this expansion so far.[18]

Due to the siege on Gaza Strip imposed by Israel, Gaza Power Generation Company is unable to expand its facilities and generate more power. Reducing losses on the transmission and distribution networks requires major investments, while efficiency and management programs requires much less investment with individual paybacks [14].

2.4 Electrical energy price in Gaza Strip

Electrical prices typically are very high compared to international prices; this is considered one of the main problems for the Palestinian energy sector. Currently, a new electricity tariff structure was approved and implemented in Aug 2011 by GEDCO (Gaza Energy Distribution Company) and became with average rate 0.5 NIS for household prices and 0.592 NIS for other sectors [19]. The fact that electricity production is monopolized by the IEC with the power to impose high prices. The price of energy differs between regions due to the full control of Israeli Authority on energy sources for the Palestinian Territory [20]. Most utilities offer industrial customers a lower price per kWh as consumption increases but in Gaza, a higher price per kWh as consumption. This situation is abnormal and differs from international regulations. This is in particular to encourage less consumption during the peak period of the power system.

2.5 The power crisis in the Gaza Strip

For many years to now, Gaza Strip has been suffering from a chronic crisis in the electricity sector. This crisis is connected with a variety of crises which its intensity varies according to the changing circumstances and contexts that affect them. The continuation of the electricity crisis has actual impacted on large sectors of the Gaza Strip. About 75% of the total available electricity is used for domestic purposes, while the remaining percentage is for the rest of the activities, including industrial productivity and other economic aspects. Most factories and industrial companies have stopped working either completely or partially due to the continued power outages. In addition, the services in the field of health and education sectors have been badly affected through the negative impact on the work of the equipment and facilities that operate on electricity and the inability of students which pursue their studies, don't forget to mention risks arising from the use of alternative means such as candles, which have caused many disasters, fires and injuries [17].

Due to the electricity crisis and insufficient electricity to the needs of Gaza Strip is the sense of "electricity shortfall" terrible. This deficit, which is exacerbated and growing every year with the increasing of natural annual loads and the stability of the sources unchanged. But the decline in the truth now is less than the past. Whereas the needs of the sector in 2005 do not exceed 214 MW.

While the combined sources of electricity in the Gaza Strip (from Egypt and the occupation and the station) isn't more than 227 MW the best conditions. This means that we are suffering from a constant deficit of electricity up to 45% even with the station work at full capacity [18].

As for other details of the crisis of non-payment of bills or lack of fuel for the power station or the imposition of tax. etc., all of them sub-details increase the severity of the crisis and are not the crisis itself, and any procedures or administrative improvements or financial in the file management or provide fuel or bring grants to operate the plant For it only move us in the area of reducing the deficit even no more than 45% (which is part expressed as "variable deficit" in the illustration and value of 22% is the ratio of the station) work.. This preface is necessary and important to understand this complex file and interlaced, and lest fancy one that the solution to the electricity crisis is generating its own station, or in paying bills alone, or in free fuel saving alone, but it must be with all of that to provide additional electricity sources, such as any country in the world to keep up with increasing terrible consumption year after year, strategy which is not based on this rule (additional sources of electricity) is throwing dust in the eyes and isn't put the wheel on the road as a radical solution to the crisis is compounded each year and does not end.[18]




Figure 2.3: Electrical deficit for Gaza Strip [18]

Chapter 3

STUDY MODEL

3.1 Background

Saudi village is located in the Rafah in the Gaza Strip within the land is vacated by the Israeli occupation of the Gaza Strip in 2005[22]. This project aimed to provide homes for the families which the Israeli occupation destroyed their homes in Rafah in 2003 and 2004 to alleviate the suffering of the Palestinian refugees. This project was established in accordance with the latest international schemes were set up roads and streets on modern style. The project provided facilities, educational institutions, market and Yards green [23].

Saudi Village consists of 8 electrical transformers that convert the voltage of 22 KV to 0.4 KV. The capacity of these electrical transformers is either 1250 KVA or 1600 KVA. Each transform connects to a set of the Sub Distribution Board (S.D.B) via underground cable $3 \times 240 \text{ mm}^2 + 1 \times 120 \text{ mm}^2$ Aluminum. Each underground cable is connected to a set of L.V Metering Panel (M.P) via underground cable $4 \times 150 \text{ mm}^2$ Aluminum, the houses subscription from electricity network from L.V Metering Panel (M.P) via L.V. Cable $2 \times 10 \text{ mm}^2$ Cupper.

The village contains 1790 housing units. Each unit consumes about 7 A (1.2 KWh) per hour. The Saudi village contains about 6 schools, the consumption rate for each school (7.04 KWh) per hour, a Masjid contains the water well with consumption rate of electricity (21.12 KWh) per hour, a cultural center and kindergarten with consumption rate of electricity is (21.12 KWh) per hour, a health center with consumption rate of electricity is (111.2 KWh) per hour, and commercial center with consumption rate of electricity is (31.68 KWh), as shown in Table (3.1).

Next to each electrical transformer the Board controls the street lighting, used two types of electrical cables in street lighting, underground $5 \times 16 \text{ mm}^2$ and underground $3 \times 35 \text{ mm}^2 + 16 \text{ mm}^2$ and different capacity lamp, which lights between 250 W and 400 W and it is installed on the lighting poles in length vary from 4 m, 8m, 10m and 12 m depending on the nature Location, the consumption rate of electricity is (60 KWh) per hour as shown in Fig. (3.1).

Table 3.1: Consumption in Saudi Village in Hour

Sector	Units	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
		A	KVA		
housing unit	1790	7	1.5	1.2	2148
School	6	40	8.8	7.04	42.24
Masjid	1	120	26.4	21.12	21.12
cultural center and kindergarten	1	120	26.4	21.12	21.12
health center	1	630	139	111.2	111.2
commercial center	1	180	39.6	31.68	31.68
Street Lighting	-	341	75	60	60
Total	1800	1438	316.7	253.36	2435.36

3.2 ETAP Software

ETAP is software designed to help electrical engineers in the processes of designing, simulating, operating and optimizing power systems. The software allows you to perform load flow analysis, short-circuit analysis, motor acceleration analysis, harmonic analysis and transient stability analysis. The software is made up of several modules that users can choose from at purchase.

ETAP offers a large array of tools for power system design. The designed project can be studied by performing load flow analysis, short-circuit analysis, motor acceleration analysis, harmonic analysis, transient stability analysis and others. Control system diagrams can be created. Cable pulling force can be predicted and graphical underground raceway systems are provided, among others. Users can create and edit one-line diagrams, 3D cable systems, plots, 3D ground grid systems and the list can go on. The program is meant to combine electrical, mechanical, logical and physical attributes that describe system elements. Mastering the utility does not require special computer skills.

ETAP is a complex utility that can support engineers in monitoring power, managing energy, optimizing a system or automating certain processes [24]. This software is utilized for simulation in this thesis.




Figure 3.1: The Saudi village in Auto CAD program

3.3 Simulation in ETAP

In this section, we used ETAP software to simulate the electric grid in Saudi village. We have data entry as eight electrical transformers, electrical cables, buildings and other facilities, such as Continuous Maximum Rating (C.M.R), Cooling method (ONAN), Normal Voltage Between Phases (22/.4 KVA), Connection and Vector Group (delta to star), Cross Section for cables, Material, Insulation to cables, Maximum DC Resistance of Conductor, average electric demand to load in Ampere units, power factors 0.8 PF, frequency 50 HZ, voltage 220 V and other data.

We obtained these values from the catalogs which are taken from the electricity company in Gaza Strip.

The ETAP software provides the value of load flow analysis such as KW, Kvar, KVA, Amp and %PF of sources, loads, each Sub distribution board S.D.B. and each metering panel M.P. Also it calculates the voltage drop and branch losses in cables. We can also obtain a detailed report about the electric grid in the Saudi Neighborhood. The international electrotechnical commission (IEC) standard is used as the reference.

The capacity of the electrical transformers used are either 1250 KVA or 1600 KVA, where each transform is connected to a set of Sub Distribution Board (S.D.B), The S.D.B is connected to a set of L.V Metering Panel (M.P).

3.3.1 First Transform (T1)

The first transform (T1) has a capacity of 1250 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T1 includes 4 Sub Distribution Board (S.D.B) named (T1A, T1B, T1C, T1D) and two lighting cables as shown in Fig. (3.2).




Figure 3.2: Branches of Transform T1

Table 3.2: Load on Transform T1

Sub Distribution Board (S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			A	KVA		
T1A	5B	14	32.2	22	17.6	81.84
	6B	14	33.2	23	18.8	
	7B	15	34.5	24	19.2	
	8B	15	34.5	24	19.2	
	School1	1	40	8.8	7.04	
T1B	1A	26	36.8	25	20	75.2
	2A	20	46	31	24.8	
	3B	14	32.2	22	17.6	
	4A	10	23	16	12.8	
T1C	13A	18	41.4	28	22.4	76.3
	14B	14	32.2	22	17.6	
	12C	10	23	16	12.8	
	15C	8	18.4	13	10.4	
	11C	10	23	16	12.8	
T1D	9B	12	27.6	19	15.2	39.84
	10B	14	32.2	22	17.6	
	School2	1	40	8.8	7.04	
lightT1A			6.7	1.5	1.2	1.2
lightT1B			6.1	1.4	1.12	1.12
Total		216	563	343.5	275.5	275.5

T1A branches into 4 L.V Metering Panel (M.P) (5B, 6B, 7B, 8B) which feed the housing units and school. The average energy consumption per hour of all loads are as follows: School consumes an average of 7.04 KWh, 5B consumes an average of 17.6 KWh, 6B consumes an average of 18.8 KWh, 7B consumes an average 19.2 KWh, and 8B consumes an average 19.2 KWh. While 5B, 6B, 7B, 8B feed housing units only with an average energy consumption of 1.2 KWh per unit as shown in Fig. (3.3).




Figure 3.3: Branches T1A in Transform T1

For more details about 5B, 6B, 7B, and 8B, please refer to Appendix A.1.

T1B branches into 4 L.V Metering Panel (M.P) named (1A, 2A, 3B, 4A) which feed the housing units. The average energy consumption per hour of all loads are as follows: 1A consumes an average 20 KWh, 2A consumes an average 24.8 KWh, 3B consumes an average 17.6 KWh, and 4A consumes an average 12.8 KWh. While 1A, 2A, 3B, 4A feed housing units only as shown in Fig. (3.4).




Figure 3.4: Branches T1B in Transform T1

For more details about 1A, 2A, 3B, and 4A, please refer to Appendix A.2.

T1C branches into 5 L.V Metering Panel (M.P) named (11C, 15C, 12C, 14B, 13A) which feed the housing units. The average energy consumption per hour of all loads are as follows: 11C consumes an average of 12.8 KWh, 15C consumes an average of 10.4 KWh, 12C consumes an average of 12.8 KWh, 14B consumes an average of 17.6 KWh, and 13A consumes an average of 22.4 KWh, While 11C, 15C, 12C, 14B, 13A feed housing units only as shown in Fig. (3.5).




Figure 3.5: Branches T1C in Transform T1

For more details about 11C, 15C, 12C, 14B, and 13A, please refer to Appendix A.3.

T1D branches into 2 L.V Metering Panel (M.P) named (9B, 10B) which feed the Housing units and school. The average energy consumption per hour of all loads is as follows: School consumes an average of 7.04 KWh, 9B consumes an average of 15.2 KWh, and 10B consumes an average of 17.6 KWh as shown in Fig. (3.6).




Figure 3.6: Branches T1D in Transform T1

For more details about 9B, and 10B, please refer to Appendix A.4.

3.3.2 Second Transform (T2)

The Second transform (T2) has a capacity of 1250 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T2 includes 5 Sub Distribution Board (S.D.B) named (T2A, T2B, T2C, T2D, T2E) and lighting cable as shown in Fig. (3.7).




Figure 3.7: Branches in Transform T2

Table 3.3: Load on Transform T2

Sub Distribution Board(S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
T2A	32C	7	11	16.1	8.8	33.44
	33B	14	22	32.2	17.6	
	School3	1	8.8	40	7.04	
T2B	18C	9	14	20.7	11.2	81.6
	23B	14	22	32.2	17.6	
	17C	11	17	25.3	13.6	
	22C	11	17	25.3	13.6	
	16C	10	16	23	12.8	
	21C	10	16	23	12.8	
T2C	30C	12	19	27.6	15.2	55.04
	31C	10	16	23	12.8	
	29C	9	14	20.7	11.2	
	28C	7	11	16.1	8.8	
	School4	1	8.8	40	7.04	
T2D	26C	8	13	18.4	10.4	36.8
	27C	7	11	16.1	8.8	
	25C	6	9	13.8	7.2	
	24C	8	13	18.4	10.4	
T2E	19B	12	19	27.5	15.2	30.4
	20B	12	19	27.5	15.2	
lightT2A			13.1	59.67	10.48	10.48
Total		179	309.7	546.57	247.76	247.76

T2A Branches into 2 L.V Metering Panel (M.P) named (32C, 33B) which feed the Housing units and school. The average energy consumption per hour of all loads is as follows: School consumes an average of 7.04 KWh, 32C consumes an average of 8.8 KWh, and 33B consumes an average of 17.6 KWh, While 32C, 33B feed housing units only with an average energy consumption of 1.2 KWh per unit as shown in Fig. (3.8).




Figure 3.8: Branch T2A in Transform T2

For more details about 32C, and 33B, please refer to Appendix B.1.

T2B branches into 6 L.V Metering Panel (M.P) named (18C, 23B, 17C, 22C, 16C, 21C) which feed the housing units. The average energy consumption per hour of all loads are as follows: 18C consumes an average of 1.2 KWh, 23B consumes an average of 17.6 KWh, 17C consumes an average of 13.6KWh, 22C consumes an average of 13.6 KWh, 16C consumes an average of 12.8 KWh, and 21C consumes an average of 12.8 KWh. While 18C, 23B, 17C, 22C, 16C, 21C feed housing units only as shown in Fig. (3.9).




Figure 3.9: Branch T2B in Transform T2

For more details about 18C, 23B, 17C, 22C, 16C, and 21C, please refer to Appendix B.2.

T2C branches into 4 L.V Metering Panel (M.P) named (28C, 29C, 31C, 30C) which feed the housing units and school. The average energy consumption per hour of all loads are as follows: School consumes an average of 7.04 KWh, 28C consumes an average of 8.8 KWh, 29C consumes an average of 11.2 KWh, 31C consumes an average of 12.8 KWh, and 30C consumes an average of 15.2 KWh, while 28C, 29C, 31C, 30C feed housing units only with an average energy consumption of 1.2 KWh per unit as shown in Fig. (3.10).




Figure 3.10: Branch T2C in Transform T2

For more details about 28C, 29C, 31C, and 30C, please refer to Appendix B.3.

T2D branches into 4 L.V Metering Panel (M.P) named (24C, 25C, 27C, 26C) which feed the housing units. The average energy consumption per hour of all loads is as follows: 24C consumes an average of 10.4 KWh, 25C consumes an average of 7.2 KWh, 27C consumes an average of 8.8 KWh, and 26C consumes an average of 10.4 KWh, while 24C, 25C, 27C, 26C feed housing units only as shown in Fig. (3.11).




Figure 3.11: Branch T2D in Transform T2

For more details about 24C, 25C, 27C, and 26C, please refer to Appendix B.4.

T2E branches into 2 L.V Metering Panel (M.P) named (20B, 19B) which feed the housing units. The average energy consumption per hour of all loads is as follows: 20B consumes an average of 15.2 KWh, and 19B consumes an average of 15.2 KWh, while 20B, 19B feed housing units only as shown in Fig. (3.12).




Figure 3.12: Branch T2E in Transform T2

For more details about 20B, and 19B, please refer to Appendix B.5.

3.3.3 Third Transform (T3)

The third transform (T3) has a capacity of 1250 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T3 includes 3 Sub Distribution Board (S.D.B) named (T3A, T3B, T3C) and two lighting cables as shown in Fig. (3.13).




Figure 3.13: Branches in Transform T3

Table 3.4: Load on Transform T3

Sub Distribution Board (S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
T3A	44B	14	22	32.2	17.6	72
	46C	9	14	20.7	11.2	
	48C	11	17	25.3	13.6	
	47C	11	17	25.3	13.6	
	45B	13	20	29.9	16	
T3B	40C	7	11	16.1	8.8	66.4
	81C	6	9	13.8	7.2	
	41A	18	28	41.3	22.4	
	43C	10	16	23	12.8	
	42B	12	19	27.6	15.2	
T3C	34C	6	9	13.8	7.2	74.4
	39C	10	16	23	12.8	
	35B	12	19	27.6	15.2	
	37C	10	16	23	12.8	
	38C	11	17	25.3	13.6	
	36C	10	16	23	12.8	
lightT3A			0.94	4.26	0.752	0.752
lightT3B			10.3	46.59	8.24	8.24
Total		170	277.24	441.55	221.792	221.792

T3A branches into 5 L.V Metering Panel (M.P) named (44B, 46C, 48C, 47C, 45B) which feed the Housing units. The average energy consumption per hour of all loads are as follows: 44B consumes an average of 17.6 KWh, 46C consumes an average of 11.2 KWh, 48C consumes an average of 13.6 KWh, 47C consumes an average of 13.6 KWh, and 45B consumes an average of 16 KWh, while 44B, 46C, 48C, 47C, 45B feed housing units only as shown in Fig. (3.14).




Figure 3.14: Branch T3A in Transform T3

For more details about 44B, 46C, 48C, 47C, and 45B, please refer to Appendix C.1.

T3B branches into 5 L.V Metering Panel (M.P) named (40C, 81C, 41A, 43C, 42B) which feed the housing units. The average energy consumption per hour of all loads are as follows: 40C consumes an average of 8.8 KWh, 81C consumes an average of 7.2 KWh, 41A consumes an average of 22.4 KWh, 43C consumes an average of 12.8 KWh, and 42B consumes an average of 15.2 KWh as shown in Fig. (3.15).




Figure 3.15: Branch T3B in Transform T3

For more details about 40C, 81C, 41A, 43C, and 42B, please refer to Appendix C.2.

T3C branches into 6 L.V Metering Panel (M.P) named (34C, 39C, 35B, 37C, 38C, 36C) which feed the housing units. The average energy consumption per hour of all loads are as follows: 34C consumes an average of 7.2 KWh, 39C consumes an average of 12.8 KWh, 35B consumes an average of 15.2 KWh, 37C consumes an average of 12.8 KWh, 38C consumes an average of 13.6 KWh, and 36C consumes an average of 12.8 KWh, while 34C, 39C, 35B, 37C, 38C, 36C feed housing units only as shown in Fig. (3.16).




Figure 3.16: Branch T3C in Transform T3

For more details about 34C, 39C, 35B, 37C, 38C and 36C please refer to Appendix C.3.

3.3.4 Fourth Transform (T4)

The fourth transform (T4) has a capacity of 1250 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T4 includes 5 Sub Distribution Board (S.D.B) named (T4A, T4B, T4C, T4D,T4E) and lighting cables as shown in Fig. (3.17).




Figure 3.17: Branches in Transform T4

Table 3.5: Load on Transform T4

Sub Distribution Board(S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
T4A	50C	7	11	16.1	8.8	72.8
	49C	9	14	20.7	11.2	
	51B	14	22	32.2	17.6	
	52B	13	20	29.9	16	
	53B	15	24	34.5	19.2	
T4B	54B	15	24	34.5	19.2	47.2
	55C	10	16	23	12.8	
	56B	12	19	27.6	15.2	
T4C	58B	12	19	27.6	15.2	76
	59C	10	16	23	12.8	
	68B	16	25	36.8	20	
	60B	12	19	27.6	15.2	
	57C	10	16	23	12.8	
T4D	62B	13	20	29.9	16	50.4
	82C	8	13	18.4	10.4	
	83C	8	13	18.4	10.4	
	61C	11	17	25.3	13.6	
T4E	63B	14	22	32.2	17.6	77.6
	65B	13	20	29.9	16	
	66B	14	22	32.2	17.6	
	64C	10	16	23	12.8	
	67C	11	17	25.3	13.6	
lightT4A			2.1	9.66	1.68	1.68
Total		257	407.1	600.76	325.68	325.68

T4A branches into 5 L.V Metering Panel (M.P) named (50C, 49C, 51B, 52B, 53B) which feed the housing units. The average energy consumption per hour of all loads are as follows: 50C consumes an average of 8.8 KWh, 49C consumes an average of 11.2 KWh, 51B consumes an average of 17.6 KWh, 52B consumes an average of 16 KWh, and 53B consumes an average of 19.2 KWh, while 50C, 49C, 51B, 52B, 53B feed housing units only with an average energy consumption of 1.2 KWh per unit as shown in Fig. (3.18).




Figure 3.18: Branch T4A in Transform T4

For more details about 50C, 49C, 51B, 52B, and 53B, please refer to Appendix D.1.

T4B branches into 3 L.V Metering Panel (M.P) named (54B, 55C, 56B) which feed the housing units. The average energy consumption per hour of all loads is as follows: 54B consumes an average of 19.2 KWh, 55C consumes an average of 12.8 KWh, and 56B consumes an average of 15.2 KWh, while 54B, 55C, 56B feed housing units only as shown in Fig. (3.19).




Figure 3.19: Branch T4B in Transform T4

For more details about 54B, 55C, and 56B, please refer to Appendix D.2.

T4C branches into 5 L.V Metering Panel (M.P) named (57C, 60B, 68B, 59C, 58B) which feed the housing units. The average energy consumption per hour of all loads are as follows: 57C consumes an average of 12.8 KWh, 60B consumes an average of 15.2 KWh, 68B consumes an average of 20 KWh, 59C consumes an average of 12.8 KWh, and 58B consumes an average of 15.2 KWh, while 57C, 60B, 68B, 59C, 58B feed housing units only as shown in Fig. (3.20).




Figure 3.20: Branch T4C in Transform T4

For more details about 57C, 60B, 68B, 59C, and 58B, please refer to Appendix D.3.

T4D branches into 4 L.V Metering Panel (M.P) named (61C, 83C, 82C, 62B) which feed the housing units. The average energy consumption per hour of all loads is as follows: 61C consumes an average of 13.6 KWh, 83C consumes an average of 10.4 KWh, 82C consumes an average of 10.4 KWh, and 62B consumes an average of 16 KWh, while 61C, 83C, 82C, 62B feed housing units only as shown in Fig. (3.21).




Figure 3.21: Branch T4D in Transform T4

For more details about 61C, 83C, 82C, and 62B, please refer to Appendix D.4.

T4E branches into 5 L.V Metering Panel (M.P) named (67C, 64C, 66B, 65B, 63B) which feed the housing units. The average energy consumption per hour of all loads are as follows: 67C consumes an average of 13.6 KWh, 64C consumes an average of 12.8 KWh, 66B consumes an average of 17.6 KWh, 65B consumes an average of 16 KWh, and 63B consumes an average of 17.6 KWh, while 67C, 64C, 66B, 65B, 63B feed housing units only as shown in Fig. (3.22).




Figure 3.22: Branch T4E in Transform T4

For more details about 67C, 64C, 66B, 65B, and 63B, please refer to Appendix D.5.

3.3.5 Fifth Transform (T5)

The fifth transform (T5) has a capacity of 1250 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T5 includes 4 Sub Distribution Board (S.D.B) named (T5A, T5B, T5C, T5D, T5E) and sixth lighting cables as shown in Fig. (3.23).




Figure 3.23: Branches in Transform T5

Table 3.6: Load on Transform T5

Sub Distribution Board(S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
T5A	71C	9	14	20.7	11.2	24
	72C	10	16	23	12.8	
T5B	69C	8	13	18.4	10.4	63.04
	70C	8	13	18.4	10.4	
	Masjid	1	26.4	120	21.12	
	Cultural center	1	26.4	120	21.12	
T5C	Health center	1	139	630	111.2	111.2
T5D	76C	8	13	18.4	10.4	61.28
	77C	7	11	16.1	8.8	
	78C	8	13	18.4	10.4	
	Commercial center	1	39.6	180	31.68	
lightT5A			2.6	11.93	2.08	2.08
lightT5B			1.9	8.52	1.52	1.52
lightT5C			3.6	16.46	2.88	2.88
lightT5D			0.63	2.84	0.504	0.504
lightT5E			0.75	3.41	0.6	0.6
lightT5F			0.87	3.96	0.696	0.696
Total		62	334.75	1230.52	267.8	267.8

T5A branches into 2 L.V Metering Panel (M.P) named (71C, 72C) which feed the housing units. The average energy consumption per hour of all loads is as follows: 71C consumes an average of 11.2 KWh, and 72C consumes an average of 12.8 KWh, while 71C, 72C feed housing units only as shown in Fig. (3.24).




Figure 3.24: Branch T5A in Transform T5

For more details about 71C, and 72C, please refer to Appendix E.1.

T5B branches into 2 L.V Metering Panel (M.P) named (69C, 70C) which feed the housing units, masjid and cultural center. The average energy consumption per hour of all loads is as follows: The cultural center consumes an average of 21.12 KWh, the masjid consumes an average of 21.12 KWh, 69C consumes an average of 10.4 KWh, and 70C consumes an average of 10.4 KWh, while 69C, 70C feed housing units only as shown in Fig. (3.25).




Figure 3.25: Branch T5B in Transform T5

For more details about 69C, and 70C, please refer to Appendix E.2.

The T5C feeding the health center, consumes an average of 111.2 KWh as shown in Fig. (3.26).




Figure 3.26: Branch T5C in Transform T5

T5D branches into 3 L.V Metering Panel (M.P) named (78C, 77C, 76C,) and commercial center, The average energy consumption per hour of all loads are as follows: the commercial center consumes an average of 31.68 KWh, 78C consumes an average of 10.4 KWh, 77C consumes an average of 8.8 KWh, and 76C consumes an average of 10.4 KWh, while 78C, 77C, 76C feed housing units only as shown in Fig. (3.27).




Figure 3.27: Branch T5D in Transform T5

For more details about 78C, 77C, and 76C, please refer to Appendix E.3.

3.3.6 Sixth Transform (T6)

The sixth transform (T6) has a capacity of 1600 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T6 includes 5 Sub Distribution Board (S.D.B) named (S.D.B1, S.D.B2, S.D.B3, S.D.B4, S.D.B5) and lighting cable as shown in Fig. (3.28).




Figure 3.28: Branches in Transform T6

Table 3.7: Load on Transform T6

Sub Distribution Board(S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
S.D.B1	M.P1/1	20	31	46.1	24.8	91.2
	M.P1/2	19	30	43.8	24	
	M.P1/3	20	31	46.1	24.8	
	M.P1/4	14	22	32.2	17.6	
S.D.B2	M.P2/1	19	30	43.7	24	80
	M.P2/2	14	22	32.2	17.6	
	M.P2/3	15	24	34.5	19.2	
	M.P2/4	15	24	34.5	19.2	
S.D.B3	M.P3/1	15	24	34.5	19.2	79.2
	M.P3/2	14	22	32.2	19.2	
	M.P3/3	20	31	46.1	24.8	
	M.P3/4	13	20	29.9	16	
S.D.B4	M.P4/1	10	16	23	12.8	68.5
	M.P4/2	12	19	27.6	15.2	
	M.P4/3	10	16	23	12.8	
	M.P4/4	12	19	27.6	15.2	
	M.P4/5	10	16	23	12.8	
S.D.B5	M.P5/1	11	17	25.3	13.6	82.4
	M.P5/2	9	14	20.7	11.2	
	M.P5/3	16	25	36.8	20	
	M.P5/4	19	30	43.8	24	
	M.P5/5	11	17	25.3	13.6	
lightT6A			12.5	56.82	10	10
Total		318	512.5	788.72	411.3	411.3

S.D.B1 branches into 4 L.V Metering Panel (M.P) named (M.P1/1, M.P1/2, M.P1/3, and M.P1/4). The average energy consumption per hour of all loads is as follows: M.P1/1 consumes an average of 24.8 KWh, M.P1/2 consumes an average of 24 KWh, M.P1/3 consumes an average of 24.8 KWh, and M.P1/4 consumes an average of 17.6 KWh. While M.P1/1, M.P1/2, M.P1/3, and M.P1/4 feed housing units only as shown in Fig. (3.29).




Figure 3.29: Branch S.D.B1 in Transform T6

For more details about M.P1/1, M.P1/2, M.P1/3, and M.P1/4, please refer to Appendix F.1.

S.D.B2 branches into 4 L.V Metering Panel (M.P) named (M.P2/1, M.P2/2, M.P2/3, and M.P2/4). The average energy consumption per hour of all loads is as follows: M.P2/1 consumes an average of 24 KWh, M.P2/2 consumes an average of 17.6 KWh, M.P2/3 consumes an average of 19.2 KWh, and M.P2/4 consumes an average of 19.2 KWh. While M.P2/1, M.P2/2, M.P2/3, and M.P2/4 feed housing units only as shown in Fig. (3.30).




Figure 3.30: Branch S.D.B2 Transform T6

For more details about M.P2/1, M.P2/2, M.P2/3, and M.P2/4, please refer to Appendix F.2.

S.D.B3 branches into 4 L.V Metering Panel (M.P) named (M.P3/1, M.P3/2, M.P3/3, and M.P3/4). The average energy consumption per hour of all loads is as follows: M.P3/1 consumes an average of 19.2 KWh, M.P3/2 consumes an average of 17.6 KWh, M.P3/3 consumes an average of 24.8 KWh, and M.P3/4 consumes an average of 16 KWh. While M.P3/1, M.P3/2, M.P3/3, and M.P3/4 feed housing units only as shown in Fig. (3.31).




Figure 3.31: Branch S.D.B3 Transform T6

For more details about M.P3/1, M.P3/2, M.P3/3, and M.P3/4, please refer to Appendix F.3.

S.D.B4 branches into 5 L.V Metering Panel (M.P) named (M.P4/1, M.P4/2, M.P4/3, and M.P4/4, M.P4/5) to feed the housing units. The average energy consumption per hour of all loads is as follows: M.P4/1 consumes an average of 12.8 KWh, M.P4/2 consumes an average of 15.2 KWh, M.P4/3 consumes an average of 12.8 KWh, M.P4/4 consumes an average of 15.2 KWh, and M.P4/5 consumes an average of 12.8 KWh. While M.P4/1, M.P4/2, M.P4/3, M.P4/4, and M.P4/5 feed housing units only as shown in Fig. (3.32).




Figure 3.32: Branch S.D.B4 Transform T6

For more details about M.P4/1, M.P4/2, M.P4/3, M.P4/4, and M.P4/5, please refer to Appendix F.4.

S.D.B5 branches into 5 L.V Metering Panel (M.P) named (M.P5/1, M.P5/2, M.P5/3, and M.P5/4, M.P5/5) to feed the housing units. The average energy consumption per hour of all loads is as follows: M.P5/1 consumes an average of 13.6 KWh, M.P5/2 consumes an average of 11.2 KWh, M.P5/3 consumes an average of 20 KWh, M.P5/4 consumes an average of 24 KWh, and M.P5/5 consumes an average of 13.6 KWh. While M.P5/1, M.P5/2, M.P5/3, M.P5/4, and M.P5/5 feed housing units only as shown in Fig. (3.33).




Figure 3.33: Branch S.D.B5 Transform T6

For more details about M.P5/1, M.P5/2, M.P5/3, M.P5/4, and M.P5/5, please refer to Appendix F.5.

3.3.7 Seventh Transform (T7)

The seventh transform (T7) has a capacity of 1250 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T7 includes 4 Sub Distribution Board (S.D.B) named (S.D.B6, S.D.B7, S.D.B8, S.D.B9) and lighting cable as shown in Fig. (3.34).




Figure 3.34: Branches in Transform T7

Table 3.8: Load on Transform T7

Sub Distribution Board(S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
S.D.B6	M.P6/1	16	25	36.8	20	75.84
	M.P6/2	18	28	41.4	22.4	
	M.P6/3	11	17	25.3	13.6	
	M.P6/4	10	16	23	12.8	
	School 5	1	8.8	40	7.04	
S.D.B7	M.P7/1	18	28	41.5	22.4	81.6
	M.P7/2	12	19	27.6	15.2	
	M.P7/3	12	19	27.6	15.2	
	M.P7/4	11	17	25.3	13.6	
	M.P7/5	12	19	27.6	15.2	
S.D.B8	M.P8/1	14	22	32.2	17.6	84.8
	M.P8/2	15	24	34.5	19.2	
	M.P8/3	15	24	34.5	19.2	
	M.P8/4	13	20	29.9	16	
	M.P8/5	10	16	23	12.8	
S.D.B9	M.P9/1	13	20	29.9	16	78.4
	M.P9/2	10	16	23	12.8	
	M.P9/3	11	17	25.3	13.6	
	M.P9/4	11	17	25.3	13.6	
	M.P9/5	18	28	41.5	22.4	
lightT7A			10	45.45	8	8
Total		251	410.8	660.65	328.64	328.64

S.D.B 6 branches into 4 L.V Metering Panel (M.P) named (M.P6/1, M.P6/2, M.P6/3, M.P6/4) which feed the housing units and school. The average energy consumption per hour of all loads are as follows: school consumes an average of 7.04 KWh, M.P6/1 consumes an average of 20 KWh, M.P6/2 consumes an average of 22.4 KWh, M.P6/3 consumes an average of 13.6 KWh, and M.P6/4 consumes an average of 12.8 KWh, while M.P6/1, M.P6/2, M.P6/3, M.P6/4 feed housing units only as shown in Fig. (3.35).




Figure 3.35: Branch S.D.B6 Transform T7

For more details about M.P6/1, M.P6/2, M.P6/3, and M.P6/4, please refer to Appendix G.1.

S.D.B7 branches into 5 L.V Metering Panel (M.P) named (M.P7/1, M.P7/2, M.P7/3, and M.P7/4, M.P7/5) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P7/1 consumes an average of 22.4 KWh, M.P7/2 consumes an average of 15.2 KWh, M.P7/3 consumes an average of 15.2 KWh, M.P7/4 consumes an average of 13.6 KWh, and M.P7/5 consumes an average of 15.2 KWh. While M.P7/1, M.P7/2, M.P7/3, M.P7/4, and M.P7/5 feed housing units only as shown in Fig. (3.36).




Figure 3.36: Branch S.D.B7 Transform T7

For more details about M.P7/1, M.P7/2, M.P7/3, M.P7/4, and M.P7/5, please refer to Appendix G.2.

S.D.B8 branches into 5 L.V Metering Panel (M.P) named (M.P8/1, M.P8/2, M.P8/3, and M.P8/4, M.P8/5) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P8/1 consumes an average of 17.6 KWh, M.P8/2 consumes an average of 19.2 KWh, M.P8/3 consumes an average of 19.2 KWh, M.P8/4 consumes an average of 16 KWh, and M.P8/5 consumes an average of 12.8 KWh. While M.P8/1, M.P8/2, M.P8/3, M.P8/4, and M.P8/5 feed housing units only as shown in Fig. (3.37).




Figure 3.37: Branch S.D.B8 Transform T7

For more details about M.P8/1, M.P8/2, M.P8/3, M.P8/4, and M.P8/5, please refer to Appendix G.3.

S.D.B 9 branches into 5 L.V Metering Panel (M.P) named (M.P9/1, M.P9/2, M.P9/3, M.P9/4, M.P9/5) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P9/1 consumes an average of 16 KWh, M.P9/2 consumes an average of 12.8 KWh, M.P9/3 consumes an average of 13.6 KWh, M.P9/4 consumes an average of 13.6 KWh, and M.P9/5 consumes an average of 22.4 KWh as shown in Fig. (3.38).




Figure 3.38: Branch S.D.B9 Transform T7

For more details about M.P9/1, M.P9/2, M.P9/3, M.P9/4, and M.P9/5, please refer to Appendix G.4.

3.3.8 Eighth Transform (T8)

The eighth transform (T8) has a capacity of 1600 KVA and power factor 0.8, which converts the next voltage of the electric grid (22 KV) to low voltage network (0.4KV) which feeds the Saudi Village, T8 includes 6 Sub Distribution Board (S.D.B) named (S.D.B10, S.D.B11, S.D.B12, S.D.B13, S.D.B14, S.D.B15) and lighting cable as shown in Fig. (3.39) as shown in Fig. (3.39).




Figure 3.39: Branches in Transform T8

Table 3.9: Load on Transform T8

Sub Distribution Board (S.D.B)	Metering Panel (M.P)	Number of unit	Average Electricity Demand		Average Consumption (KWh)	Total Consumption (KWh)
			KVA	A		
S.D.B10	M.P10/1	16	25	36.9	20	105.44
	M.P10/2	11	17	25.4	13.6	
	M.P10/3	10	16	23.1	12.8	
	M.P10/4	19	30	43.8	24	
	M.P10/5	22	35	50.8	28	
	School 6	1	8.8	40	7.04	
S.D.B11	M.P11/1	19	30	43.8	24	72.8
	M.P11/2	12	19	27.6	15.2	
	M.P11/3	18	28	41.5	22.4	
	M.P11/4	9	14	20.7	11.2	
S.D.B12	M.P12/1	14	22	32.2	17.6	65.6
	M.P12/2	18	28	41.5	22.4	
	M.P12/3	12	19	27.6	15.2	
	M.P12/4	8	13	18.4	10.4	
S.D.B13	M.P13/1	13	20	29.9	16	73.6
	M.P13/2	15	24	34.6	19.2	
	M.P13/3	15	24	34.6	19.2	
	M.P13/4	15	24	34.6	19.2	
S.D.B14	M.P14/1	22	35	50.1	28	71.2
	M.P14/2	15	24	34.6	19.2	
	M.P14/3	19	30	43.8	24	
S.D.B15	M.P15/1	14	22	32.2	17.6	68
	M.P15/2	10	16	23	12.8	
	M.P15/3	13	20	29.9	16	
	M.P15/4	17	27	39.2	21.6	
lightT8A			9.1	41.2	7.28	7.28
Total		357	579.92	901	463.92	463.92

S.D.B10 branches into 5 L.V Metering Panel (M.P) named (M.P10/1, M.P10/2, M.P10/3, and M.P10/4, M.P10/5) which feed the housing units and school. The average energy consumption per hour of all loads are as follows: School consumes an average of 7.04 KWh, M.P10/1 consumes an average of 20 KWh, M.P10/2 consumes an average of 13.6 KWh, M.P10/3 consumes an average of 12.8 KWh, M.P10/4 consumes an average of 24 KWh, and M.P10/5 consumes an average of 28 KWh. While M.P10/1, M.P10/2, M.P10/3, M.P10/4, and M.P10/5 feed housing units only as shown in Fig. (3.40).




Figure 3.40: Branch S.D.B10 Transform T8

For more details about M.P10/1, M.P10/2, M.P10/3, M.P10/4, and M.P10/5, please refer to Appendix H.1.

S.D.B11 branches into 4 L.V Metering Panel (M.P) named (M.P11/1, M.P11/2, and M.P11/3, M.P11/4) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P11/1 consumes an average of 24 KWh, M.P11/2 consumes an average of 15.2 KWh, M.P11/3 consumes an average of 22.4 KWh, and M.P11/4 consumes an average of 11.2 KWh as shown in Fig. (3.41).




Figure 3.41: Branch S.D.B11 Transform T8

For more details about M.P11/1, M.P11/2, M.P11/3, and M.P11/4, please refer to Appendix H.2.

S.D.B12 branches into 4 L.V Metering Panel (M.P) named (M.P12/1, M.P12/2, and M.P12/3, M.P12/4) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P12/1 consumes an average of 17.6 KWh, M.P12/2 consumes an average of 22.4 KWh, M.P12/3 consumes an average of 15.2 KWh, and M.P12/4 consumes an average of 10.4 KWh as shown in Fig. (3.42).




Figure 3.42: Branch S.D.B12 Transform T8

For more details about M.P12/1, M.P12/2, M.P12/3, and M.P12/4, please refer to Appendix H.3.

S.D.B13 branches into 4 L.V Metering Panel (M.P) named (M.P13/1, M.P13/2, and M.P13/3, M.P13/4) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P13/1 consumes an average of 16 KWh, M.P13/2 consumes an average of 19.2 KWh, M.P13/3 consumes an average of 19.2 KWh, and M.P13/4 consumes an average of 20 KWh as shown in Fig. (3.43).




Figure 3.43: Branch S.D.B13 Transform T8

For more details about M.P13/1, M.P13/2, M.P13/3, and M.P13/4, please refer to Appendix H.4.

S.D.B14 branches into 3 L.V Metering Panel (M.P) named (M.P14/1, M.P14/2, and M.P14/3) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P14/1 consumes an average of 28 KWh, M.P14/2 consumes an average of 19.2 KWh, and M.P14/3 consumes an average of 24 KWh as shown in Fig. (3.44).




Figure 3.44: Branch S.D.B14 Transform T8

For more details about M.P14/1, M.P14/2, and M.P14/3, please refer to Appendix H.5.

S.D.B15 branches into 4 L.V Metering Panel (M.P) named (M.P15/1, M.P15/2, M.P15/3, M.P15/4) which feed the housing units. The average energy consumption per hour of all loads is as follows: M.P15/1 consumes an average of 17.6 KWh, M.P15/2 consumes an average of 12.8 KWh, M.P15/3 consumes an average of 16 KWh, and M.P15/4 consumes an average of 21.6 KWh as shown in Fig. (3.45).




Figure 3.45: Branch S.D.B15 Transform T8

For more details about M.P15/1, M.P15/2, M.P15/3, and M.P15/4, please refer to Appendix H.6.

Chapter 4

Suggested Scheme

4.1 Background

To overcome the problem of power outages in the Saudi village, we use eight diesel generators, where each generator is placed beside each electric transformer from the eight electrical transformers and covers the load on that transformer, and is manufactured by FG Wilson Company. The capacity of these generators is the average consumption rate load of the electrical transformers. Use the generators in two cases.

First case used in prime rate and second case used in standby rate Table (4.1) and the comparison is made between the two cases.

Table 4.1: Generator Capacity at Prime and standby rates (KVA)

generator	Prime Rate	Standby Rate
1	400	400
2	350	330
3	300	300
4	455	450
5	400	400
6	550	550
7	455	450
8	600	605
Total	3510	3485

Prime Rating, These ratings are applicable for supplying continuous electrical power (At variable load) in lieu of commercially purchased power. There is not limitation to the annual hours of operation and same model can be supply 10% overload power for 1 hour in 12 hours [25].

Standby Rating, These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. Overload isn't permitted on these ratings [25].

Power Cut off duration is usually eight hours per day; these hours are sometimes in the day and sometimes at night as what set on a schedule regularly by the Electricity Distribution Company in Gaza Strip. In the case of power cuts at night. The electrical loads for schools neglected, and when the power cut on day, the electrical loads for street lighting neglected, and in public holidays the street lighting and loads schools are neglected during the day.

In this chapter , we working study to provide electricity on Saudi village using these generators on the same electrical grid, and we account the financial cost, consumption of fuel for these generators, And we take the account of the annual maintenance , the price of generators , the proportion of risk , the cost of using the electricity network in the case of the implementation of this project from outside the electricity distribution company (Wheeling cost) and the cost of installing automatic

transfer switch (ATS) system operation on/off generators automatically in the following cases.

1. Generators operating at full capacity.
2. Generators operating at full load.
3. Generators operating at full load without street lighting.
4. Generators operating at full load without schools.
5. Generators operating at full load without the streets Lighting and schools.
6. Generators operating when the loads distributor on 366 day as figure (4.1).

The 366 day divides into two sections. The First Section, where generators operating with schools and the number of his days 240 days divide into two parts, the first part, the generator operates at night, so the electricity load schools are neglected and the number of his days 120 days, the second part, which calculates the electrical load of the schools.

The second section, where generators operating without schools and the number of days 90 days (summer vacation) is added to Fridays in the remaining nine months and is divided into two parts, the first part without lighting and schools and a number of days is 63, and the second part without schools and the number of days is 63.

The days of year in the sixth case as follows.

Without school $120+63 = 183$ day

Without light $120=120$ day

Without light & school $=63$ day




Figure 4.1: Generators Operation during 366 days

in the case 2,3,4,5 are calculated the fuel consumption base on of the electrical load on the generator as the 1 KVA consumes about 0.2 liters of diesel on average, as inferred from catalogs used generators, while in Case 1 is calculated fuel consumption of direct catalog, and in the case 6 days year will be divided by the previous cases.

4.2 Generators Specifications

In this study, we choose generators FG Wilson Company are obtained on the prices of these generators and necessary ATS system from Murtaja Company, which imports and sells these generators in the Gaza Strip as in Table 4.2.

Table 4.2: Generator Cost at Prime and Standby Rate

Generator	Standby \$	ATS Standby NIS	Prime \$	ATS Prime NIS
1	62000	8500	65000	9000
2	52000	7500	62000	8500
3	50000	7000	52000	7500
4	65000	9000	67000	9500
5	62000	8500	65000	9000
6	70000	10000	72000	10500
7	65000	9000	67000	9500
8	72000	10500	75000	11000
Total	498000	70000 \$18372.7	525000	74500 \$19553.8

The generator operates at frequency 50 HZ and 1500 rpm [25, 26]

4.3 Simulation in ETAP

In this section we use power factor 0.8 PF and the number house equal 1790 unit approximately , that require an average of 1.5 KVA (1.2 KW) per unit, and six schools that require an average of 8.8 KVA (7.04 KW) per school, unique Masjid contain the water well requires an average about 26.4 KVA (21.12 KW), a cultural center and kindergarten requires an average about 26.4 KVA (21.12 KW), a health center requires an average of about 139 KVA (111.2 KW), commercial center requires an average about 39.6 KVA (31.68 KW), and light street requires an average 75 KVA (60 KW) , and we use cost Liter Diesel equal NIS5.2=\$1.36, and \$1 equal 3.81NIS , the load capacity as shown in Table 4.3.

We used ETAP software to simulate the same electric grid in Saudi village. We have data entry of eight electrical generators, electrical cables connected to generators, buildings and other facilities. We obtained these values from the catalogs which have taken from Murtaja Company in Gaza Strip. The ETAP software provides the value of load flow analysis of sources, loads, each Sub distribution board S.D.B. and each metering panel M.P. The international electro technical commission (IEC) standard is used as a reference.

Table 4.3: Various Loading Conditions (KVA)

Generator	Full Load	Full Load without Light & school	Full Load without school	Full Load without Light
1	346	325	328	343
2	313	281	295	299
3	282	270	282	270
4	411	409	411	409
5	344	334	344	334
6	520	507	520	507
7	418	398	409	407
8	587	568	578	577
Total	3221	3092	3167	3146

4.4 Case One: Generators Full Capacity Operation

From the catalogue generator the fuel consumption and its cost when the liter diesel equal 5.2 NIS as shown in table 4.4:

Table 4.4: Generator Fuel Consumption and Cost at Full Capacity Operation

Generator	Fuel consumption at 1500 rpm L/hr	Cost fuel in hour \$
1	79	107.44
2	64.8	88.128
3	60.1	81.73
4	89.2	121.31
5	79	107.44
6	108.6	147.69
7	89.2	121.31
8	119.3	162.24
Total	689.2	937.28

4.4.1 Energy Consumption

Housing Units: $1.5 \times 0.8 = 1.2 \text{ KW}$.

$1.2 \text{ KW} \times 1 \text{ h} \times 1790 \text{ unit} = 2148 \text{ KWh}$.

Schools: $8.8 \times 0.8 = 7.04 \text{ KW}$.

$7.04 \text{ KW} \times 1 \text{ h} \times 6 \text{ unit} = 42.24 \text{ KWh}$.

Masjid: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Cultural Center: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Health center: $139 \times 0.8 = 111.2 \text{ KW}$.

$111.2 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 111.2 \text{ KWh}$.

Commercial center: $39.6 \times 0.8 = 31.68 \text{ KW}$

$31.68 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 31.68 \text{ KWh}$.

Street Lighting: $75 \times 0.8 = 60 \text{ KW}$.

$60 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 60 \text{ KWh}$.

Consumption load per hour = $2148 + 42.24 + 21.12 + 21.12 + 111.2 + 31.68 + 60$
= 2435.36 KWh.

Consumption load in day = $2435.36 \times 8 = 19482.88$ KWh.

Consumption load in year = $19482.88 \times 366 = 7130734.08$ KWh.

The wheeling cost equals NIS 0.05 per 1 KWh.

The wheeling cost = $7130734.08 \times 0.05 = \text{NIS } 356536.704 = \93579.187 .

Cost fuel at Full capacity Operation = $689.2 \text{ L/hr} = 937.3 \text{ \$/hr}$.

In day 8 hour at Full capacity Operation.

$\$937.3 \times 8 = \7498.4 in Day.

$\$7498.4 \times 15 = \112476 in 15 Day.

$798.4 \$ \times 30 = \224952 in 30 day.

4.4.2 Generator at Standby Rate

The initial cost from this project equals to adding generator cost and ATS cost as shown in Table 4.2.

Initial cost: ATS cost + Generator cost = $\$18372.7 + \$498000 = \$516372.7$.

The risk cost and inflation rate equals 2% from the initial cost = $\$10327.45$.

The maintenance cost equals 5% from initial cost = $\$25818.6$.

Annual cost.

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = $516372.7 + (7498.4 \times 366) + 93579.187 = 516372.7 + 2744414.4 + 93579.187 = \3354366.287

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = $25818.6 + 10327.45 + 2744414.4 + 93579.187 = \2874139.637 .

In third year equals second year.

4.4.3 Generator at Prime Rate

The initial cost from this project equals summation generator cost and ATS cost as shown in Table 4.2.

Initial cost: ATS cost + Generator cost = $\$19553.8 + \$525000 = \$544553$

The risk cost and inflation rate equals 2% from the initial cost = $\$10891.06$

The maintenance cost equals 5% from initial cost = $\$27227.65$

From the catalogue generator the fuel consumption and its cost when the liter diesel equals NIS 5.2 as shown in table 4.5:

Table 4.5: Fuel Consumption and Cost from Generator in Prime Rate per Hour

Generator	Fuel consumption at 1500 rpm L/hr	fuel Cost \$
1	79.9	108.66
2	69.6	94.65
3	59.5	80.92
4	94	127.84
5	79.9	108.66
6	108	146.88
7	94	127.84
8	120.3	163.6
Total	705.2	959.05

Cost fuel at Full capacity Operation = 705.2 L/hr = 959.05 \$/hr.

In day 8 hour Full capacity Operation.

$\$959.05 \times 8 = \7672.4 in Day.

$\$7672.4 \times 15 = \115086 in 15 Day.

$\$7672.4 \times 30 = \230172 in 30 day.

Annual cost.

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 544553 + (7672.4 × 366) + 93579.187 = 544553 + 2808098.4 + 93579.187 = \$3446230.587.

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 27227.65 + 10891.06 + 2808098.4 + 93579.187 = \$2939796.297.

In third year equal second year.

4.5 Case Two: Generators Operation at Full Load

From the catalogue generator the fuel consumption and its cost when the liter diesel equals NIS 5.2 as shown in Table 4.6:

1KVA consumes 0.2 liter from diesel.

Table 4.6: Generator Fuel Consumption and Cost at Full Load Operation

Generator	Load capacity KVA	Fuel consumption at 1500 rpm L/hr	Cost fuel per hour \$
1	346	69.2	94.112
2	313	62.6	85.136
3	282	56.4	76.704
4	411	82.2	111.792
5	344	68.8	93.568
6	520	104	141.44
7	418	83.6	113.696
8	587	117.4	159.664
Total	3221	644.2	876.11

The wheeling cost = $7130734.08 \times 0.05 = \text{NIS } 356536.704 = \93579.187 .

Cost fuel at full load = $644.2 \text{ L/hr} = 876.11 \text{ \$/hr}$.

In day 8 hour at full load

$\$876.11 \times 8 = \7008.88 in day.

$\$7008.88 \times 15 = \105133.2 in 15 day.

$\$7008.88 \times 30 = \210266.4 in 30 day.




Figure 4.2: Generator 1 When Operation at Full Load




Figure 4.3: Generator 2 When Operation at Full Load




Figure 4.4: Generator 3 When Operation at Full Load




Figure 4.5: Generator 4 When Operation at Full Load




Figure 4.6: Generator 5 When Operation at Full Load




Figure 4.7: Generator 6 When Operation at Full Load




Figure 4.8: Generator 7 When Operation at Full Load




Figure 4.9: Generator 8 During Operation at Full Load

4.5.1 Generator at Standby Rate

Initial cost: ATS cost + Generator cost = \$18372.7 + \$498000 = \$516372.7.

The risk cost and inflation rate equals 2% from the initial cost = \$10327.45.

The maintenance cost equals 5% from initial cost = \$25818.6.

Annual cost.

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 516372.7 + (7008.88×366) + 93579.187 = 516372.7 + 2565250.05 + 93579.187 = \$3175201.967.

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 25818.6 + 10327.45 + 2565250.05 + 93579.187 = \$2694975.317.

In third year equals second year.

4.5.2 Generator at Prime Rate

Initial cost: ATS cost + Generator cost = \$19553.8 + \$525000 = \$ 544553.

The risk cost and inflation rate equals 2% from the initial cost = \$10891.06.

The maintenance cost equals 5% from initial cost = \$27227.65.

Annual cost.

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 544553 + (7008.88×366) + 93579.187 = 544553 + 2565250.05 + 93579.187 = \$3203382.237.

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 27227.65 + 10891.06 + 2565250.05 + 93579.187 = \$2696947.947.

In third year equals second year.

4.6 Case Three: Generators Operating at Full Load without Street Lighting

From the catalogue generator the fuel consumption and its cost when the liter diesel equals 5.2 NIS as shown in Table 4.7:
1KVA consumes 0.2 liter from diesel.

Table 4.7: Generator Fuel Consumption and Cost at Full Load Operation without Street Lighting per Hour

Generator	Load capacity KVA	Fuel consumption at 1500 rpm L/hr	Cost Fuel \$
1	343	68.6	93.29
2	299	59.8	81.32
3	270	54	73.44
4	409	81.8	111.28
5	334	66.8	90.848
6	507	101.4	137.9
7	407	81.4	110.7
8	577	115.4	156.94
Total	3146	629.2	855.71

4.6.1 Energy Consumption

Housing Units: $1.5 \times 0.8 = 1.2 \text{ KW}$.

$1.2 \text{ KW} \times 1 \text{ h} \times 1790 \text{ unit} = 2148 \text{ KWh}$.

Schools: $8.8 \times 0.8 = 7.04 \text{ KW}$.

$7.04 \text{ KW} \times 1 \text{ h} \times 6 \text{ unit} = 42.24 \text{ KWh}$.

Masjid: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Cultural Center: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Health center: $139 \times 0.8 = 111.2 \text{ KW}$.

$111.2 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 111.2 \text{ KWh}$.

Commercial center: $39.6 \times 0.8 = 31.68 \text{ KW}$.

$31.68 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 31.68 \text{ KWh}$.

Consumption load per hour = $2148 + 42.24 + 21.12 + 21.12 + 111.2 + 31.68 = 2375.36 \text{ KWh}$.

Consumption load in day = $2375.36 \times 8 = 19002.88 \text{ KWh}$.

Consumption load in year = $19482.88 \times 366 = 6955054.08 \text{ KWh}$.

The wheeling cost equals NIS 0.05 per 1 KWh.

The wheeling cost = $7130734.08 \times 0.05 = \text{NIS } 347752.704 = \91273.67 .

Cost fuel at full load without street lighting = $629.2 \text{ L/hr} = 855.71 \text{ \$/hr}$.

In day 8 hour at full load without street lighting.

$\$855.71 \times 8 = \6845.68 in day.

$\$6845.68 \times 15 = \102685.2 in 15 day.

$\$6845.68 \times 30 = \205370.4 in 30 day.




Figure 4.10: Generator 1 When Operation at Full Load without Street Lighting




Figure 4.11: Generator 2 When Operation at Full Load without Street Lighting




Figure 4.12: Generator 3 When Operation at Full Load without Street Lighting




Figure 4.13: Generator 4 When Operation at Full Load without Street Lighting




Figure 4.14: Generator 5 When Operation at Full Load without Street Lighting




Figure 4.15: Generator 6 When Operation at Full Load without Street Lighting




Figure 4.16: Generator 7 When Operation at Full Load without Street Lighting




Figure 4.17: Generator 8 When Operation at Full Load without Street Lighting

4.6.2 Generator at Standby Rate

Initial cost: ATS cost + Generator cost = $\$18372.7 + \$498000 = \$516372.7$.

The risk cost and inflation rate equals 2% from the initial cost = $\$10327.45$.

The maintenance cost equals 5% from initial cost = $\$25818.6$.

Annual cost

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = $516372.7 + (6845.68 \times 366) + 91273.67 = 516372.7 + 2505518.88 + 91273.67 = \3113165.25 .

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = $25818.6 + 10327.45 + 2505518.88 + 91273.67 = \2632938.6 .

In third year equals second year.

4.6.3 Generator at Prime Rate

Initial cost: ATS cost + Generator cost = $\$19553.8 + \$525000 = \$544553$.

The risk cost and inflation rate equals 2% from the initial cost = $\$10891.06$.

The maintenance cost equals 5% from initial cost = $\$27227.65$.

Annual cost

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = $544553 + (6845.68 \times 366) + 91273.67 = 544553 + 2505518.88 + 91273.67 = \3141345.55 .

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = $27227.65 + 10891.06 + 2505518.88 + 91273.67 = \2634911.26 .

In third year equals second year.

4.7 Case Four: Generators Operating at Full Load without Schools

From the catalogue generator the fuel consumption and its cost when the liter diesel equals 5.2 NIS as shown in Table 4.8:
1KVA consumes 0.2 liter from diesel.

Table 4.8: Generator Fuel Consumption and Cost is Full Load Operation without Schools per Hour

Generator	Load capacity KVA	Fuel consumption at 1500 rpm L/hr	Cost fuel \$
1	328	65.6	89.21
2	295	59	80.24
3	282	56.4	76.7
4	411	82.2	111.79
5	344	68.8	93.568
6	520	104	141.44
7	409	81.8	111.248
8	578	115.6	157.21
Total	3167	633.4	861.42

4.7.1 Energy Consumption

Housing Units: $1.5 \times 0.8 = 1.2 \text{ KW}$.

$1.2 \text{ KW} \times 1 \text{ h} \times 1790 \text{ unit} = 2148 \text{ KWh}$.

Masjids: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Cultural Center: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Health center: $139 \times 0.8 = 111.2 \text{ KW}$.

$111.2 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 111.2 \text{ KWh}$.

Commercial center: $39.6 \times 0.8 = 31.68 \text{ KW}$.

$31.68 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 31.68 \text{ KWh}$.

Light: $75 \times 0.8 = 60 \text{ KW}$.

$60 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 60 \text{ KWh}$.

Consumption load per hour = $214 + 21.12 + 21.12 + 111.2 + 31.68 + 60 = 2393.12 \text{ KWh}$.

Consumption load in day = $2393.12 \times 8 = 19144.96 \text{ KWh}$.

Consumption load in year = $19144.96 \times 366 = 7007055.36 \text{ KWh}$.

The wheeling cost equals NIS 0.05 per 1 KWh.

The wheeling cost = $7007055.36 \times 0.05 = \text{NIS } 350352.768 = \91956.1 .

Cost fuel at full load without schools = $633.4 \text{ L/hr} = 861.42 \text{ \$/hr}$.

In day 8 hour full load without schools.

$\$861.42 \times 8 = \6891.36 in day.

$\$6891.36 \times 15 = \103370.4 in 15 day.

$\$6891.36 \times 30 = \206740.8 in 30 day.




Figure 4.18: Generator 1 When Operating at Full Load without Street Schools




Figure 4.19: Generator 2 When Operating at Full Load without Street Schools




Figure 4.20: Generator 3 When Operating at Full Load without Street Schools




Figure 4.21: Generator 4 When Operating at Full Load without Street Schools




Figure 4.22: Generator 5 When Operating at Full Load without Street Schools




Figure 4.23: Generator 6 When Operating at Full Load without Street Schools




Figure 4.24: Generator 7 When Operating at Full Load without Street Schools




Figure 4.25: Generator 8 When Operating at Full Load without Street Schools

4.7.2 Generator at Standby Rate

Initial cost: ATS cost + Generator cost = \$18372.7 + \$498000 = \$516372.7

The risk cost and inflation rate equals 2% from the initial cost = \$10327.45

The maintenance cost equals 5% from initial cost = \$25818.6

Annual cost

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 516372.7 + (6891.36 × 366) + 91956.1 = 516372.7 + 2522237.76 + 91956.1 = \$3130566.56

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 25818.6 + 10327.45 + 2522237.76 + 91956.1 = \$2650339.91

In third year equals second year.

4.7.3 Generator at Prime Rate

Initial cost: ATS cost + Generator cost = \$19553.8 + \$525000 = \$544553

the risk cost and inflation rate equals 2% from the initial cost = \$10891.06

The maintenance cost equals 5% from initial cost = \$27227.65

Annual cost

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 544553 + (6891.36 × 366) + 91956.1 = 544553 + 2522237.76 + 91956.1 = \$3158746.86

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 27227.65 + 10891.06 + 2522237.76 + 91956.1 = \$2652311.98

In third year equals second year

4.8 Case Five: Generators Operating at Full Load without Streets Lighting and Schools

From the catalogue generator the fuel consumption and its cost when the liter diesel equal 5.2 NIS as shown in Table 4.9:

1KVA consumes 0.2 liter from diesel.

Table 4.9: Generators Fuel Consumption and Cost at Full Load Operation without Streets Lighting and Schools per Hour

Generator	Load capacity KVA	Fuel consumption at 1500 rpm L/hr	Cost fuel \$
1	325	65	88.4
2	281	56.2	76.43
3	270	54	73.44
4	409	81.8	111.248
5	334	66.8	90.848
6	507	101.4	137.9
7	398	79.6	108.25
8	568	113.6	154.49
Total	3092	618.4	841.02

4.8.1 Energy Consumption

Housing Units: $1.5 \times 0.8 = 1.2 \text{ KW}$.

$1.2 \text{ KW} \times 1 \text{ h} \times 1790 \text{ unit} = 2148 \text{ KWh}$.

Masjid: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Cultural Center: $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 21.12 \text{ KWh}$.

Health center: $139 \times 0.8 = 111.2 \text{ KW}$.

$111.2 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 111.2 \text{ KWh}$.

Commercial center: $39.6 \times 0.8 = 31.68 \text{ KW}$.

$31.68 \text{ KW} \times 1 \text{ h} \times 1 \text{ unit} = 31.68 \text{ KWh}$.

Consumption load per hour = $2148 + 21.12 + 21.12 + 111.2 + 31.68 = 2333.12 \text{ KWh}$.

Consumption load in day = $2333.12 \times 8 = 18664.96 \text{ KWh}$.

Consumption load in year = $18664.96 \times 366 = 6831375.36 \text{ KWh}$.

The wheeling cost equals NIS 0.05 per 1 KWh.

The wheeling cost = $6831375.36 \times 0.05 = \text{NIS } 341568.768 = \89650.59 .

Cost fuel at full load less the streets Lighting and schools = $618.4 \text{ L/hr} = 841.02 \text{ \$/hr}$.

In day 8 hour full load less the streets lighting and schools.

$\$841.02 \times 8 = \6728.16 in day.

$\$6891.36 \times 15 = \100922.4 in 15 day.

$\$6891.36 \times 30 = \201844.8 in 30 day.




Figure 4.26: Generator 1 When Operating at Full Load without Streets Lighting and Schools




Figure 4.27: Generator 2 When Operating at Full Load without Streets Lighting and Schools




Figure 4.28: Generator 3 When Operating at Full Load without Streets Lighting and Schools




Figure 4.29: Generator 4 When Operating at Full Load without Streets Lighting and Schools




Figure 4.30: Generator 5 When Operating at Full Load without Streets Lighting and Schools




Figure 4.31: Generator 6 When Operating at Full Load without Streets Lighting and Schools




Figure 4.32: Generator 7 When Operating at Full Load without Streets Lighting and Schools




Figure 4.33: Generator 8 When Operating at Full Load without Streets Lighting and Schools

4.8.2 Generator at Standby Rate

Initial cost: ATS cost + Generator cost = \$18372.7 + \$498000 = \$516372.7

The risk cost and inflation rate equals 2% from the initial cost = \$10327.45

The maintenance cost equals 5% from initial cost = \$25818.6

Annual cost

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 516372.7 + (6728.16 × 366) + 89650.59 = 516372.7 + 2462506.56 + 89650.59 = \$3068529.85

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 25818.6 + 10327.45 + 2462506.56 + 89650.59 = \$2588303.2

In third year equals second year.

4.8.3 Generator at Prime Rate

Initial cost: ATS cost + Generator cost = \$19553.8 + \$525000 = \$544553

The risk cost and inflation rate equals 2% from the initial cost = \$10891.06

The maintenance cost equals 5% from initial cost = \$27227.65

Annual cost.

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = 544553 + (6728.16 × 366) + 89650.59 = 544553 + 2462506.56 + 89650.59 = \$3096710.15

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = 27227.65 + 10891.06 + 2462506.56 + 89650.59 = \$2590275.86

In third year equals second year.

4.9 Case Six: Generators Operating at Loads Distributor on 366 Day

The loads distributor 183 day without school, 120 day are without light and 63 day without light and school.

The average wheeling cost = (93579.187 + 91273.67 + 91956.1 + 89650.59)/4 = \$91614.88

4.9.1 Generator at Standby Rate

Initial cost: ATS cost + Generator cost = \$18372.7 + \$498000 = \$516372.7

The risk cost and inflation rate equals 2% from the initial cost = \$10327.45

The maintenance cost equals 5% from initial cost = \$25818.6

Annual cost

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = $516372.7 + (6845.68 \times 120) + (6891.36 \times 183) + (6728.16 \times 63) + 91614.88 = 516372.7 + (821481.6 + 1261118.88 + 423874.08) + 91614.88 = 516372.7 + 2506474.56 + 91614.88 = \3114462.14

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = $25818.6 + 10327.45 + 2506474.56 + 91614.88 = \2634235.49

In third year equals second year.

4.9.2 Generator at Prime Rate

Initial cost: ATS cost + Generator cost = $\$19553.8 + \$525000 = \$544553$

The risk cost and inflation rate equals 2% from the initial cost = $\$10891.06$

The maintenance cost equals 5% from initial cost = $\$27227.65$

Annual cost.

In first year.

Total cost = initial cost + fuel cost in year + wheeling cost = $544553 + (6845.68 \times 120) + (6891.36 \times 183) + (6728.16 \times 63) + 91614.88 = 544553 + (821481.6 + 1261118.88 + 423874.08) + 91614.88 = 544553 + 2506474.56 + 91614.88 = \3142642.44

In second year.

Total cost = maintenance + risk cost + fuel cost in year + wheeling cost = $27227.65 + 10891.06 + 2506474.56 + 91614.88 = \2636208.15

In third year equal second year.

4.10 Comparison between Prime and Standby Rates

Table 4.10: Comparison Between Prime and Standby Rates \$

Annual cost		Standby Rate	Prime Rate
Initial cost		516372.7	544553
Risk cost		10327.45	10891.06
Maintenance cost		25818.6	27227.65
Wheeling cost		Equal for Standby / Prime Rates	
The case one cost	First year	3354366.287	3446230.587
	Second year	2874139.637	2939796.297
The case two cost	First year	3175201.967	3203382.237
	Second year	2694975.317	2696947.947
The case three cost	First year	3113165.25	3141345.55
	Second year	2632938.6	2634911.26
The case four cost	First year	3130566.56	3158746.86
	Second year	2650339.91	2652311.98
The case five cost	First year	3068529.85	3096710.15
	Second year	2588303.2	2590275.86
The case six cost	First year	3114462.14	3142642.44
	Second year	2634235.49	2636208.15

Chapter 5

Feasibility Study

5.1 Background

In this chapter we will study the different scenarios for the implementation of this project to get the best quality at the lowest cost. We will study the price of 1KWh equals 1.5 NIS and 2 NIS, The application of this study is to all previous cases in chapter 4 and comparing to them, which will apply on the project? Is the electricity distribution company, government or contractors and businessmen? Is the project funded by the third party or not? What and How this fund? when this project will achieve its goals and reap profits? when will the owner of project recover the Equity capital? All of these questions will take in this chapter with more details.

5.2 Annual Income of The Project

1. at NIS 1.5 per KWH

House $1.5 \times 0.8 = 1.2 \text{KW}$.

$1.2 \text{KW} \times 8 \text{ h} = 9.6 \text{ KWh}$.

$9.6 \text{ KWh} \times 1.5 \text{NIS} \times 1790 \text{ unit} = \text{NIS } 25776 = \6765.35 in day .

School $8.8 \times 0.8 = 7.04 \text{ KW}$.

$7.04 \text{ KW} \times 8 \text{ h} = 56.32 \text{ KWh}$.

$56.32 \text{ KWh} \times 1.5 \text{NIS} \times 6 \text{ unit} = \text{NIS } 506.88 = \133.03 in day .

Masjid $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 8 \text{ h} = 168.96 \text{ kwh}$.

$168.96 \text{ kwh} \times 1.5 \text{NIS} \times 1 \text{unit} = \text{NIS } 253.44 = \66.51 in day .

Cultural Center $26.4 \times 0.8 = 21.12 \text{ KW}$.

$21.12 \text{ KW} \times 8 \text{ h} = 168.96 \text{ KWh}$.

$168.96 \text{ KWh} \times 1.5 \text{NIS} \times 1 \text{unit} = \text{NIS } 253.44 = \66.51 in day .

Health center $139 \times 0.8 = 111.2 \text{ KW}$.

$111.2 \text{ KW} \times 8 \text{ h} = 889.6 \text{ KWh}$.

$889.6\text{KWh} \times 1.5 \text{ NIS} \times 1\text{unit} = \text{NIS } 1334.4 = \350.23 in day.

Commercial center $39.6 \times 0.8 = 31.68 \text{ KW.}$

$31.68 \text{ KW} \times 8\text{h} = 253.44 \text{ KWh.}$

$253.44 \text{ KWh} \times 1.5 \times 1\text{unit} = \text{NIS } 380.16 = \99.77 in day.

Light $75 \times 0.8 = 60 \text{ KW.}$

$60 \text{ KW} \times 8\text{h} = 480 \text{ KWh.}$

$480 \text{ KWh} \times 1.5 \times 1\text{unit} = \text{NIS } 720 = \188.97 in day.

Consumption in Day

$6765.35 + 133.03 + 66.51 + 66.51 + 350.23 + 99.77 + 188.97 = \7670.37

In 15 day $7670.37 \times 15 = \$115055.55$

In 30 day $7670.37 \times 30 = \$230111.1$

Year $7670.37 \times 366 = \$2807355.42$

Annual income = $7670.37 \times 366 = \$2807355.42$

2. When 1 KWh = 2 NIS.

House $1.5 \times 0.8 = 1.2\text{KW.}$

$1.2\text{KW} \times 8\text{h} = 9.6 \text{ KWh.}$

$9.6 \text{ KWh} \times 2 \times 1790 \text{ unit} = \text{NIS } 34368 = \9020.47 in day.

School $8.8 \times 0.8 = 7.04 \text{ KW.}$

$7.04 \text{ KW} \times 8\text{h} = 56.32 \text{ KWh.}$

$56.32 \text{ KWh} \times 2 \times 6 \text{ unit} = \text{NIS } 675.84 = \177.38 in day.

Masjid $26.4 \times 0.8 = 21.12 \text{ KW.}$

$21.12 \text{ KW} \times 8\text{h} = 168.96 \text{ KWh.}$

$168.96 \text{ KWh} \times 2 \times 1\text{unit} = \text{NIS } 337.92 = \88.69 in day.

Cultural Center $26.4 \times 0.8 = 21.12 \text{ KW.}$

$21.12 \text{ KW} \times 8\text{h} = 168.96 \text{ KWh.}$

$168.96 \text{ KWh} \times 2 \times 1\text{unit} = \text{NIS } 337.92 = \88.69 in day.

Health center $139 \times 0.8 = 111.2$ KW.

111.2 KW $\times 8$ h = 889.6 KWh.

889.6 KWh $\times 2 \times 1$ unit = 1779.2 NIS = \$ 466.98 in day.

Commercial center $39.6 \times 0.8 = 31.68$ KW.

31.68 KW $\times 8$ h = 253.44 KWh.

253.44 KWh $\times 2 \times 1$ unit = NIS 506.88 = \$ 133.03 in day.

Light $75 \times 0.8 = 60$ KW.

60 KW $\times 8$ h = 480 KWh.

480 KWh $\times 2 \times 1$ unit = NIS 960 = \$ 251.96 in day.

Consumption in Day

$9020.47 + 177.38 + 88.69 + 88.69 + 466.98 + 133.03 + 251.96 = \10227.2

In 15 day $10227.2 \times 15 = \$153408$

In 30 day $10227.2 \times 30 = \$306816$

In year $10227.2 \times 366 = \$3743155.2$

Income cost in year $10227.2 \times 366 = \$3743155.2$

5.3 Payback Period

5.3.1 Case 1 at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3354366.287. This means that there is deficit of \$547010.867. In the second year, the expenses equal \$2874139.637 with the fixing income remains; This means that there is a deficit of \$66784.217, and every year this deficit increases by \$66784.217.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42; while the capital and the running cost equal \$3446230.587 This means that there is deficit of \$638875.167. In the second year, the expenses equal \$2939796.297 with the fixing income remains; This means that there is deficit of \$132440.877, and every year this deficit increases by \$132440.877.

5.3.2 Case 1 at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3354366.287. This means that there is profit of \$388788.917, and recovers the owner of this Equity capital project in about 327 day ($\$3743155.2/366=10227.2$ income cost in day. In 327 recovers the Equity capital and other day is a profit). In the second year, the expenses equal \$2874139.637 with the fixing income remains; This means that there is profit of \$869015.563, and every year the profit increases by \$869015.563.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3446230.587. This means that there is profit of \$296924.613, and recovers the owner of this Equity capital project in about 337 day. In the second year, the expenses equal \$2939796 With the fixing income remains; This means that there is profit of \$803358.903, and every year the profit increases by \$803358.903.

Table 5.1: Profit in Case one

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-547010.867	-66784.217	-638875.167	-132440.877
at NIS 2 Per KWH	388788.917	869015.563	296924.613	803358.903

5.3.3 Case 2 at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42; while the capital and the running cost equal \$3175201.967. This means that there is deficit of \$367846.547. In the second year, the expenses equal \$2694975.317, with the fixing income remains, This means that there is profit of \$112380.103, and every year the profit increases by \$112380.103 and recovers the owner of this Equity capital project in about 4 year and 3 month.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3203382.237; this means that there is deficit of \$396026.817. In the second year, the expenses equal \$2696947.947, with the fixing income remains, This means that there is profit of \$110407.473, and every year the profit increases by \$110407.473, and recovers the owner of this Equity capital project in about 4 year and 5 month.

5.3.4 Case 2 at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3175201.967 this means that there is profit of \$567953.233, and recovers the owner of this Equity capital project in about 310 day. In the second year, the expenses equal \$2694975.317 with the fixing income remains; This means that there is profit of \$1048179.883, and every year the profit increases by \$1048179.883.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3203382.237, This means that there is profit of \$539772.963, and recovers the owner of this Equity capital project in about 313 day. In the second year, the expenses equal \$2696947.947, with the fixing income remains; This means that there is profit of \$1046207.253, and every year the profit increases by \$1046207.253.

Table 5.2: Profit in Case 2

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-367846.547	112380.103	-396026.817	110407.473
at NIS 2 Per KWH	567953.233	1048179.883	539772.963	1046207.253

5.3.5 Case 3 at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3113165.25; this means that there is deficit of \$305809.83. In the second year, the expenses equal \$2632938.6, with the fixing income remains. This means that there is profit of \$174416.82, and every year the profit increases by \$174416.82, and recovers the owner of this Equity capital project in about 3 year and 3 month.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3141345.55; this means that there is deficit of \$333990.13. In the second year, the expenses equal \$2634911.26, with the fixing income remains. This means that there is profit of \$172444.16, and every year the profit increases by \$172444.16, and recovers the owner of this Equity capital project in about 3 year and 1 month.

5.3.6 Case 3 at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3113165.25, this means that there is profit of \$629989.95, and recovers the owner of this Equity capital project in about 304 day. In the second year, the expenses equal \$2632938.6 with the fixing income remains. This means that there is profit of \$1110216.6, and every year the profit increases by \$1110216.6.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3141345.55, this means that there is profit of \$601809.65, and recovers the owner of this Equity capital project in about 307 day. In the second year, the expenses equal \$2634911.26 with the fixing income remains. This means that there is profit of \$1108243.94, and every year the profit increases by \$1108243.94.

Table 5.3: Profit in Case 3

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-305809.83	174416.82	-333990.13	172444.16
at NIS 2 Per KWH	629989.95	1110216.6	601809.65	1108243.94

5.3.7 Case 4 at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3130566.56; this means that there is deficit of \$323211.14. In the second year, the expenses equal \$2650339.91 with the fixing income remains, This means that there is profit of \$157015.51, and every year the profit increases by \$157015.51, and recovers the owner of this Equity capital project in about 3 year.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3158746.86; this means that there is deficit of \$351391.44. In the second year, the expenses equal \$2652311.98 with the fixing income remains, This means that there is profit of \$155043.44, and every year the profit increases by \$155043.44, and recovers the owner of this Equity capital project in about 3 year and 2 month.

5.3.8 Case 4 at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$ 3130566.56; this means that there is profit of \$612588.64, and recovers the owner of this Equity capital project in about 306 day. In the second year, the expenses equal \$2650339.91, with the fixing income remains; This means that there is profit of \$1092815.29, and every year the profit increases by \$1092815.29.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3158746.86, this means that there is profit of \$584408.34, and recovers the owner of this Equity capital project in about 308 day, In the second year, the expenses equal \$2652311.98, with the fixing income remains, This means that there is profit of \$1090843.22, and every year the profit increases by \$1090843.22,

Table 5.4: Profit in Case 4

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-323211.14	157015.51	-351391.44	155043.44
at NIS 2 Per KWH	612588.64	1092815.29	584408.34	1090843.22

5.3.9 Case 5 at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3068529.85; this means that there is deficit of \$261174.43. In the second year, the expenses equal \$2588303.2, with the fixing income remains, This means that there is profit of \$219052.22, and every year the profit increases by \$219052.22, and recovers the owner of this Equity capital project in about 2 year and 3 month.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3096710.15; this means that there is deficit of \$289354.73. In the second year, the expenses equal \$2590275.86, with the fixing income remains, This means that there is profit of \$217079.56, and every year the profit increases by \$217079.56, and recovers the owner of this Equity capital project in about 2 year and 3 month.

5.3.10 Case 5 at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3068529.85, this means that there is profit of \$674625.35, and recovers the owner of this Equity capital project in about 300 day In the second year, the expenses equal \$2588303.2, with the fixing income remains, This means that there is profit of \$1154852, and every year the profit increases by \$1154852.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3096710.15, this means that there is profit of \$646445.05, and recovers the owner of this Equity capital project in about 302 day In the second year, the expenses equal \$2590275.86, with the fixing income remains, This means that there is profit of \$1152879.34, and every year the profit increases by \$1152879.34.

Table 5.5: Profit in Case 5

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-261174.43	219052.22	-289354.73	217079.56
at NIS 2 Per KWH	674625.35	1154852	646445.05	1152879.34

5.3.11 Case 6 at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3114462.14; this means that there is deficit of \$307106.72. In the second year, the expenses equal \$2634235.49, with the fixing income remains. This means that there is profit of \$173119.93, and every year the profit increases by \$173119.93, and recovers the owner of this Equity capital project in about 2 year and 9 month.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3142642.44; this means that there is deficit of \$335287.02. In the second year, the expenses equal \$2636208.15, with the fixing income remains. This means that there is profit of \$171147.27, and every year the profit increases by \$171147.27, and recovers the owner of this Equity capital project in about 2 year and 11 month.

5.3.12 Case 6 at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3114462.14; this means that there is profit of \$628693.06, and recovers the owner of this Equity capital project in about 304 day. In the second year, the expenses equal \$2634235.49, with the fixing income remains. This means that there is profit of \$1108919.71, and every year the profit increases by \$1108919.71.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3142642.44; this means that there is profit of \$600512.76, and recovers the owner of this Equity capital project in about 307 day. In the second year, the expenses equal \$2636208.15, with the fixing income remains. This means that there is profit of \$1106947.05, and every year the profit increases by \$1106947.05.

Table 5.6: Profit in Case 6

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-307106.72	173119.93	-335287.02	171147.27
at NIS 2 Per KWH	628693.06	1108919.71	600512.76	1106947.05

5.3.13 The average cases

1. at NIS 1.5 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3159382.009; this means that there is deficit of \$352026.589. In the second year, the expenses equal \$2679155.359, with the fixing income remains. This means that there is profit of \$128200.061, and every year the profit increases by \$128200.061, and recovers the owner of this Equity capital project in about 4 year and 10 month.

- **Prime Rate**

For the first year, the income in this case equals \$2807355.42, while the capital and the running cost equal \$3198176.304; this means that there is deficit of \$390820.884. In the second year, the expenses equal \$2691741.916, with the fixing income remains. This means that there is profit of \$115613.504, and every year the profit increases by \$115613.504, and recovers the owner of this Equity capital project in about 5 year and 5 month.

2. at NIS 2 per KWH

- **Standby Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$3159382.009; this means that there is profit of \$583773.191, and recovers the owner of this Equity capital project in about 308 day. In the second year, the expenses equal \$2679155.359, with the fixing income remains. This means that there is profit of \$1063999.841, and every year the profit increases by \$1063999.841.

- **Prime Rate**

For the first year, the income in this case equals \$3743155.2, while the capital and the running cost equal \$ 3198176.304; this means that there is profit of \$544978.896, and recovers the owner of this Equity capital project in about 312 day. In the second year, the expenses equal \$2691741.916, with the fixing income remains. This means that there is profit of \$1051413.284, and very year the profit increases by \$1051413.284.

Table 5.7: Profit in Average Cases

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
at NIS 1.5 Per KWH	-352026.589	128200.061	-390820.884	115613.504
at NIS 2 Per KWH	583773.191	1063999.841	544978.896	1051413.284

Table 5.1: Comparison between Profit in Prime and Standby Rates at 1KWh equal 1.5 NIS

Annual cost	profit in Standby Rate \$		profit in Prime Rate \$	
	First year	Second year	First year	Second year
The first case cost	-547010.867	-66784.217	-638875.167	-132440.877
The second case cost	-367846.547	112380.103	-396026.817	110407.473
The third case cost	-305809.83	174416.82	-333990.13	172444.16
The fourth case cost	-323211.14	157015.51	-351391.44	155043.44
The fifth case cost	-261174.43	219052.22	-289354.73	217079.56
The sixth case cost	-307106.72	173119.93	-335287.02	171147.27
The average cases cost	-352026.589	128200.061	-390820.884	115613.504

Table5.2: Comparison between Profit in Prime and Standby Rates at 1KWh equal 2 NIS

Annual cost	profit in Standby Rate \$		profit in Prime Rate\$	
	First year	Second year	First year	Second year
The first case cost	388788.917	869015.563	296924.613	803358.903
The second case cost	567953.233	1048179.883	539772.963	1046207.253
The third case cost	629989.95	1110216.6	601809.65	1108243.94
The fourth case cost	612588.64	1092815.29	584408.34	1090843.22
The fifth case cost	674625.35	1154852	646445.05	1152879.34
The sixth case cost	628693.06	1108919.71	600512.76	1106947.05
The average cases cost	583773.191	1063999.841	544978.896	1051413.284

5.4 Implementation of The Project

In the case the local authority or private investors want to apply this project. The equity capital used in this project will be recovered in maximum duration a five years at the worst case. When the price of the 1 KWh equals NIS 1.5. But when the price of 1 KWh equal NIS 2, we will recover the equity capital in first year only. In the case, the electrical distribution company that apply this project, the equity capital will recover faster than the previous case because the wheeling cost will be deducted from the cost of this project in each year as shown Table 5.3.

Table5.3: The Wheeling Cost to All Cases in Prime and Standby Rates

Annual cost	Wheeling cost \$
The first case cost	93579.187
The second case cost	93579.187
The third case cost	91273.67
The fourth case cost	91956.1
The fifth case cost	89650.59
The sixth case cost	91614.88
The average cases cost	91942.269

This project can be successful and can achieve its objectives and application without external financier from the third party, for example at a price of 1.5 NIS by 1 KWh, but having a financier may lead to lower the price of 1KWh and works to speed up the implementation of this project which depends on the nature of this funding.

Chapter 6

CONCLUSIONS AND FUTURE WORK

6.1 Conclusions

The need to improve the electricity sector has become more significant in the Gaza Strip. This can be done in several ways including creating a new technique to solve shortage in electricity and improving the quality of the energy and voltage stability.

The study presents a design of an emergency system that works during power cut-offs to provide electricity to customers in the Saudi village. Eight diesel generation units are required with capacity varying between 330-605 KVA. The electricity grid is used where no extra wiring is required for various operating conditions and a feasibility study is also provided for each condition.

ETAP software is used to simulate all cases by using the same electric grid in Saudi village. The parameters are entered to ETAP software to provide the value of load flow analysis.

For a price of NIS 1.5 per 1 KWh, the payback period is about five years, and for a price of NIS 2 per 1 KWh, the payback period is about one year.

It is recommended to start the project with a price of NIS 2 per 1 KWh in the first year, and then reduce the price to NIS 1.5 per 1 KWh.

We do hope that local authorities will benefit from this study in other places to lessen the suffering of the residents of the Gaza Strip.

6.2 Future Work

- Study the use of wind and solar energy as an alternative to generators
- The use of energy-saving measures



REFERENCES



- [1] Gaza Strip
Wikipedia; Available: /wiki/%D9%82%D8%B7%D8%A7%D8%B9_%D8%BA%D8%B2%D8%A9.;
- [2] Hassona, Fouzy. Palestinian Energy and Natural Resources Authority- PENRA. 7-10-2010.
- [3] Bustami, Abdalla, Optimum Design and Performance Analysis of a Proposed Palestinian Electrical Network, An-Najah National University, 2008, 152 p.
- [4] Abu al khair, Ayman, The current status of energy sector in Palestine with special focus on electricity sector, report 2006, prepared for Geneva University
- [5] Electric power distribution; Wikipedia; Available from: wiki/Electric_power_distribution; 2011 Jan 28.
- [6] State of Electrical Energy In Gaza Strip; PENRA; Available: <http://penra.gov.ps>; 2010 May 20.
- [7] Weinberger, Sharon, "Gaza Powerless", IEEE Spectrum, p84, Dec 2009.
- [8] Ministry of Local Government, "The Palestinian Code of Energy Efficient Buildings. Ramallah": Ministry of Local Government, 2004.
- [9] Al Qaraa, Zaki, " Energy Efficient Sustainable Buildings: Case study Irada Building at IUG, Islamic university, 2013
- [10] BBC News Middle East, Life in the Gaza Strip, Available at: <http://www.bbc.co.uk>, Update at 22 November 2012, Access on: 20/4/2013.
- [11] Palestinian Central Bureau of Statistics (PCBS), Energy Balance in Palestine 2007, 2008, Available at: <http://www.pcbs.gov.ps/Portals/PCBS/Downloads/book1621.pdf>, accessed on: 26/6/2011.
- [12] Palestinian Energy & Natural Resources Authority (PENRA), available at: http://penra.gov.ps/index.php?option=com_content&view=article&id=590:2011-08-24-06-09-43&catid=1:2009-12-29-11-09-44&Itemid=29, accessed on: 26/6/2011.
- [13] GEDCO, available at: <http://www.gedco.ps/under.php>, accessed on: 25/6/ 2010.
- [14] Elaydi, Ibrik, Koudary , " Conservation And Management Of Electrical Energy In Gaza Strip Using Low Cost Investment", IJERA Journal, Vol. 2, Issue 4, July-August 2012.
- [15] Palestinian Energy & Natural Resources Authority (PENRA), available at: http://penra.gov.ps/index.php?option=com_content&view=article&id=590:2011-08-24-06-09-43&catid=1:2009-12-29-11-09-44&Itemid=29, accessed on: 26/6/2011.
- [16] Persson, M. et al. "Influence of window size on the energy balance of low energy houses". Energy and Buildings Journal 38 (2006) 181–188.
- [17] Pal-think for strategic studies, "The Exacerbating Electricity Crisis in Gaza and Urgency of Finding Strategic Solutions", January 2014 Gaza – Palestine.
- [18] State of Electrical Energy In Gaza Strip; PENRA; Available: <http://penra.gov.ps>; 2010 May 20.
- [19] Gaza Electricity Distribution Company, 2011. Unpublished data. Gaza Strip. Palestine.

- [20] Palestinian Investment Fund, Annual Report 2008, Available at: www.pif.ps/resources/file/annual_report/AnnualReportEnglishFinal.pdf, Access on: 22/6/2011.
- [21] AbuMeteir, Hasan, A Proposed SCADA System to improve the conditions of the Electricity sector in Gaza Strip Islamic University, 2013.
- [23] alarabiya.net; Available from: <http://www.alarabiya.net/articles/2013/02/04/264382.html>.
- [22] Al faraa, Fawzy, UNRWA Housing Projects & their adequacy to the natural & urban environment of Gaza Strip ,Islamic University,2010.
- [24] ETAP PowerStation; Available from: <http://etap-powerstation.software.informer.com>
- [25] FG wilson.net; Available from: <https://www.fgwilson.com/>
- [26] perkins.net; Available from: <https://www.perkins.com/>




APPENDIX A


A.1 Branches 5B, 6B, 7B, and 8B from Branch T1A in Transform T1









A.2 Branches 1A, 2A, 3B, 4A, and 8B from Branch T1B in Transform T1








A.3 Branches 11C, 15C, 12C, 14B, and 13A from Branch T1C in Transform T1









A.4 Branches 9B, and10B from Branch T1D in Transform T1









APPENDIX B

B.1 Branches 32C, and33B from Branch T2A in Transform T2







B.2 Branches 18C, 23B, 17C, 22C, 16C, and 21C from Branch T2B in Transform T2









B.3 Branches 28C, 29C, 31C, and 30C from Branch T2C in Transform T2







B.4 Branches 24C, 25C, 27C, and 26C from Branch T2D in Transform T2






B.5 Branches 20B, and 19B from Branch T2E in Transform T2









APPENDIX C




C.1 Branches 44B, 46C, 48C, 47C, and 45B from Branch T3A in Transform T3













C.2 Branches 40C, 81C, 41A, 43C, and 42B from Branch T3B in Transform T3







C.3 Branches 34C, 39C, 35B, 37C, 38C, and 36C from Branch T3C in Transform T3















APPENDIX D

D.1 Branches 50C, 49C, 51B, 52B, and 53B from Branch T4A in Transform T4










D.2 Branches 54B, 55C, and 56B from Branch T4B in Transform T4







D.3 Branches 57C, 60B, 68B, 59C, and 58B from Branch T4C in Transform T4










D.4 Branches 61C, 83C, 82C, and 62B from Branch T4D in Transform T4







D.5 Branches 67C, 64C, 66B, 65B, and 63B from Branch T4E in Transform T4







APPENDIX E


E.1 Branches 71C, and 72C from Branch T5A in Transform T5





E.2 Branches 69C, and 70C from Branch T5B in Transform T5





E.3 Branches 78C, 77C, and 76C from Branch T5D in Transform T5








APPENDIX F



F.1 Branches M.P1/1, M.P1/2, M.P1/3, and M.P1/4 from Branch S.D.B1 in Transform T6








F.2 Branches M.P2/1, M.P2/2, M.P2/3, and M.P2/4 from Branch S.D.B2 in Transform T6













F.3 Branches M.P3/1, M.P3/2, M.P3/3, and M.P3/4 from Branch S.D.B3 in Transform T6








F.4 Branches M.P4/1, M.P4/2, M.P4/3, M.P4/4, and M.P4/5 from Branch S.D.B4 in Transform T6













F.5 Branches M.P5/1, M.P5/2, M.P5/3, M.P5/4, and M.P5/5 from Branch S.D.B5 in Transform T6








APPENDIX G




G.1 Branches M.P6/1, M.P6/2, M.P6/3, and M.P6/4 from Branch S.D.B6 in Transform T7










G.2 Branches M.P7/1, M.P7/2, M.P7/3, M.P7/4, and M.P7/5 from Branch S.D.B7 in Transform T7









G.3 Branches M.P8/1, M.P8/2, M.P8/3, M.P8/4, and M.P8/5 from Branch S.D.B8 in Transform T7






G.4 Branches M.P9/1, M.P9/2, M.P9/3, M.P9/4, and M.P9/5 from Branch S.D.B9 in Transform T7












APPENDIX H


H.1 Branches M.P10/1, M.P10/2, M.P10/3, M.P10/4, and M.P10/5 from Branch S.D.B10 in Transform T8














H.2 Branches M.P11/1, M.P11/2, M.P11/3, and M.P11/4 from Branch S.D.B11 in Transform T8









H.3 Branches M.P12/1, M.P12/2, M.P12/3, and M.P12/4 from Branch S.D.B12 in Transform T8








H.4 Branches M.P13/1, M.P13/2, M.P13/3, and M.P13/4 from Branch S.D.B13 in Transform T8





H.5 Branches M.P14/1, M.P14/2, and M.P14/3 from Branch S.D.B14 in Transform T8



H.6 Branches M.P15/1, M.P15/2, M.P15/3, and M.P15/4 from Branch S.D.B15 in Transform T8

