

**An-Najah National University
Faculty of Graduate Studies**

**EVALUATION OF URBAN WATER SUPPLY
OPTIONS USING WEAP: THE CASE OF
NABLUS CITY**

**By
Rahma Uthman Khader Abdo**

**Supervisors
Dr. Mohammad N. Almasri
Dr. Amal Alhudhud**

*Submitted in Partial Fulfillment of the Requirements for the Degree of
Master of Water and Environmental Engineering, Faculty of Graduate
Studies, at An-Najah National University, Nablus, Palestine.*

2009

**EVALUATION OF URBAN WATER SUPPLY
OPTIONS USING WEAP: THE CASE OF
NABLUS CITY**



By

Rahma Uthman Khader Abdo

This thesis was defended successfully on 14/9/2009 and approved by:

Committee Members

Signature

Dr. Mohammad Almasri / Academic Advisor

.....

Dr. Amal Alhudhud / Academic Advisor

.....

Dr. Hafez Shaheen / Internal Examiner

.....

Dr. Nidal mahmod / External Examiner

.....



DEDICATION

To my husband and my parents for their encouragement and support

ACKNOWLEDGEMENTS

First of all, praise be to Allah for helping me in making this thesis possible. I would like to express my sincere gratitude to Dr. Mohammad N. Almasri for his supervision, guidance and constructive advice. To Dr. Amal Alhudhud many thanks for her guidance. Special thanks also go to my defense committee.

Thanks go to the Water Supply and Sanitation Department at Nablus Municipality for providing data. I would like to mention in this regard engineers: Adnan Amodi, Areej Kittaneh, Hana Habash, and Sami Zaghah of Nablus Municipality.

My husband and parents: thank you for being a great source of support and encouragement. I am grateful to all of you for your love, moral support, and patience.

الإقرار

أنا الموقع أدناه مقدم الرسالة التي تحمل العنوان:

EVALUATION OF URBAN WATER SUPPLY OPTIONS USING WEAP: THE CASE OF NABLUS CITY

أقر بأن ما اشتملت عليه هذه الرسالة إنما هي نتاج جهدي الخاص، باستثناء ما تمت الإشارة إليه حيثما ورد، وأن هذه الرسالة ككل، أو أي جزء منها لم يقدم من قبل لنيل أية درجة علمية أو بحث علمي أو بحثي لدى أية مؤسسة تعليمية أو بحثية أخرى.

Declaration

The work provided in this thesis, unless otherwise referenced, is the researcher's own work, and has not been submitted elsewhere for any other degree or qualification.

Student's name:

اسم الطالبة:

Signature:

التوقيع:

Date:

التاريخ:

VI
TABLE OF CONTENTS

| Contents | Page No |
|--|----------------|
| Acknowledgments | IV |
| Declaration | V |
| Table of Contents | VI |
| List of Tables | VIII |
| List of Figures | IX |
| List of Appendix, Tables and Figures | XI |
| Abbreviations Table | XII |
| Abstract | XIII |
| Chapter 1 INTRODUCTION | 1 |
| 1.1 General Background | 2 |
| 1.2 Importance of the Study | 3 |
| 1.3 Descriptions of the Study Area | 5 |
| 1.4 Research Motivation | 8 |
| 1.5 Research main Objective | 10 |
| 1.6 Why WEAP | 10 |
| 1.7 Methodology | 10 |
| 1.8 Thesis outline | 12 |
| Chapter 2 LITERATURE REVIEW | 13 |
| 2.1 General | 14 |
| 2.2 Water Evaluation and Planning System (WEAP) | 15 |
| 2.3 WEAP Applications | 17 |
| Chapter 3 MODELING WATER SUPPLY AND DEMAND FOR NABLUS CITY USING WEAP | 23 |
| 3.1 Introduction | 24 |
| 3.2 Water Supply in Nablus City | 25 |
| 3.3 Water Distribution System | 28 |
| 3.4 Water Quality | 29 |
| 3.5 Unaccounted for water | 30 |

| | | |
|-------------------|---|-----------|
| 3.6 | Water Demand and Consumption | 32 |
| 3.7 | City Expansion | 35 |
| 3.8 | Nablus City WEAP Model | 35 |
| Chapter 4 | ANALYSIS OF SCENARIOS AND MANAGEMENT OPTIONS | 40 |
| 4.1 | Introduction | 41 |
| 4.2 | Scenarios | 42 |
| 4.3 | Management Options | 44 |
| 4.4 | Results | 53 |
| 4.5 | Discussion of results | 59 |
| Chapter 5 | CONCLUSIONS AND RECOMMENDATIONS | 66 |
| 5.1 | Conclusions | 67 |
| 5.2 | Recommendations | 68 |
| References | | 69 |
| Appendix | | 1 |
| الملخص | | ب |

VIII
LIST OF TABLES

| Contents | | Page No |
|------------------|---|----------------|
| Table 1 | Wells and springs of Nablus Municipality | 27 |
| Table 2 | The storage reservoirs of Nablus Municipality | 27 |
| Table 3 | A summary of scenarios and management options | 49 |
| Table 4.1 | Summary of sample results for reference scenario and management options | 54 |
| Table 4.2 | Summary of sample results for population growth increase scenario and management options | 55 |
| Table 4.3 | Summary of sample results for climate change scenario and management options | 56 |
| Table 4.4 | Summary of sample results for using WHO daily use rate standard scenario and management options | 57 |
| Table 5 | The decrease in the unmet water demand using different management options | 62 |

IX
LIST OF FIGURES

| Contents | | Page No |
|------------------|---|----------------|
| Figure 1 | Location of the City of Nablus | 5 |
| Figure 2 | The two mountains of the City of Nablus | 6 |
| Figure 3 | The annual and the average annual rainfall of Nablus City | 7 |
| Figure 4 | The average yield of water resources in Nablus City | 8 |
| Figure 5 | Depiction of research methodology | 11 |
| Figure 6 | Location of water sources | 26 |
| Figure 7 | Schematic shows reservoirs and pumping stations | 26 |
| Figure 8 | Supplied zones of Nablus city | 29 |
| Figure 9 | Chlorination tank and injector at Deir Sharaf well | 30 |
| Figure 10 | Percentage of unaccounted for water | 31 |
| Figure 11 | Water production and water sold | 31 |
| Figure 12 | Water demand, water production, unmet water demand | 33 |
| Figure 13 | Average per capita daily water consumption for the old city | 34 |
| Figure 14 | Nablus City conceptual model | 36 |
| Figure 15 | Demand data entry table | 39 |
| Figure 16 | The Scenarios and the Management Options | 41 |

| | | |
|------------------|---|----|
| Figure 17 | Reference Scenario and Management Options | 42 |
| Figure 18 | Sabastia Well | 45 |
| Figure 19 | Wadi Zeimer | 47 |
| Figure 20 | Potential new wells locations | 48 |
| Figure 21 | Projected water demand for using 100l/c.d scenario | 58 |
| Figure 22 | Unmet water demand for using 100l/c.d scenario | 58 |
| Figure 23 | Average yearly per capita daily water use rate | 62 |
| Figure 24 | The unmet water demand for reference scenario management options | 63 |
| Figure 25 | The unmet water demand for population growth increase scenario management options | 63 |
| Figure 26 | The unmet water demand, climate change scenario management options | 64 |
| Figure 27 | The unmet water demand for 150l/c.d scenario management options | 64 |
| Figure 28 | Water demand for 70l/c.d,100l/c.d, and 150l/c.d use rate | 65 |
| Figure 29 | The unmet water demand for 70l/cd,100l/cd, and 150l/c.d use rat stations | 65 |

LIST OF APPENDIX TABLES AND FIGURES

| Contents | | Page No |
|-----------------|---|--------------------|
| | Appendix A: Tables | 1 |
| Table 1 | Pumping hours for areas | 2 |
| Table 2 | Chemical analysis of the main water sources of the City of Nablus | 3 |
| Table 3 | Amount of pumping m ³ /month | 3 |
| Table 4 | Demand sites in WEAP model | 4 |
| Table 5 | The potential wells that can be used to supply Nablus City | 6 |
| Table 6 | The estimated water demand for the residential uses in ein beit elma zon | 7 |
| Table 7 | Reference scenario results | 8 |
| Table 8 | Population growth rate increase scenario results | 9 |
| Table 9 | Climate change Scenario results | 10 |
| Table 10 | Using WHO standard use rate results | 11 |
| Table 11 | Reference scenario results considering one demand site and one water source | 12 |
| Table 12 | Population growth rate increase scenario results considering one demand site and one water source | 13 |
| Table 13 | Climate change Scenario results considering one demand site and one water source | 14 |
| Table 14 | Using WHO standard use rate results considering one demand site and one water source | 15 |
| | Appendix B: Figures | 16 |
| Figure 1 | Pumping stations and reservoirs | 17 |
| Figure 2 | The expected expansion areas in Nablus City | 21 |

ABBREVIATIONS

| Symbols | Definition |
|----------------------|--|
| WEAP | Water Evaluation And Planing |
| PCBS | Palestinian Central Bureau of Statistics |
| m ³ | Cubic Meter |
| mcm | Million Cubic Meter |
| L | Liter |
| m ³ /m | Cubic Meter Per Month |
| l/c-d | Liter Per Capita Per Day |
| m ³ /h | Cubic Meter Per Hour |
| m ³ /year | Cubic Meter Per Year |
| DSS | Decision Support System |
| IWRM | Integrated Water Resources Management |
| WWTP | Wastewater Treatment Plant |

**EVALUATION OF URBAN WATER SUPPLY OPTIONS USING
WEAP: THE CASE OF NABLUS CITY**

By

Rahma Abdo

Advisors

Dr. Mohammad N. Almasri

Dr. Amal Alhudhud

ABSTRACT

Palestinians undergo the problem of insufficient water which emerges largely from the fact that the Israelis do not allow the Palestinians a full control of their water resources. In addition to this restriction, the Palestinians are not permitted to pump out sufficient quantities from the aquifers. This has led to water shortage and thus the majority of the major cities and communities in the West Bank encounter challenges and difficulties in water allocation and management. The City of Nablus is an example of such a situation since it suffers from water shortage and difficulties in distributing water to all users at sufficient quantities.

This work utilizes the Water Evaluation And Planning Tool (WEAP) in assessing the management options the Municipality of Nablus is considering for dealing with the on-going water crisis in the City of Nablus.

The study methodology consists of three components: data gathering; knowledge acquisition on WEAP and its applications; and WEAP modeling that aided to evaluate water resources management options for Nablus City.

The results show that the unmet water demand will continue to increase over the coming years. This is mainly due to the increase in population with limited water resources. Therefore, securing additional water supplies becomes an essential issue to meet the increase in water demand. The most effective option for the period 2009-2025 is the construction of Sabastia well that leads the lowest unmet water demand during this period. The development of new groundwater wells is very efficient in covering the unmet water demand. In this option the unmet water demand will start to decrease when adding the first well in 2015, and more decrease in 2020, 2025, and 2035 when the second, the third, and the fourth wells are constructed. The decrease in 2025 in the unmet water demand is more than Sabastia well option, so in this period this option becomes more effective than Sabastia well option. The option of using stormwater harvesting gives satisfactory results in decreasing the unmet water demand better than the options of spring rehabilitations and the reduction in water leakage which gives a small decrease in the unmet water demand. Improving the water-related infrastructure of the City to decrease the water leakage is crucial in mitigating the water shortage.

CHAPTER ONE
INTRODUCTION

1.1 General Background

Palestine like many other Middle Eastern countries undergoes water shortage problem. West Bank and Gaza Strip suffer from a chronic water shortage, preventing sustained economic growth and damaging the environment and the Palestinians health sector. The large variations in rainfall and limited surface water resources has led to a widespread scarcity of fresh water resources in the region, resulting in heavy reliance on groundwater as a major source for various uses. The contribution of surface water to the overall water balance is limited and marginal (Mogheir et al., 2005).

The sources of water in the West Bank are the renewable water of the mountain aquifer that rises and outcrops in the West Bank but extends across and below the territories of historic Palestine. The groundwater recharge in the West Bank is from the direct infiltration of rainwater through fractured rocks and porous soils. The overall average recharge in the West Bank is estimated to be 679 mcm/year, while in Gaza it is estimated at 45 mcm/year (Mogheir et al., 2005).

The extent of the problem that the Palestinians undergo emerges largely from the fact that the Israelis do not allow the Palestinians a full control of their water resources. In addition to this restriction, the Palestinians are not permitted to pump out sufficient quantities. This has led to water shortage and thus the majority of the major cities and communities in the West Bank undergo challenges and difficulties in water allocation and management.

The City of Nablus is an example of such a situation since it suffers from water shortage and difficulties in distribution of water to all users at sufficient quantities. Many future scenarios were proposed and under such scenarios many management options were highlighted. As a first step, it is essential to evaluate the existing conditions related to the water supply system in the City of Nablus, then assess the effectiveness of management options in mitigating the on-going water crisis. As such, this work comes in line with the objective of evaluating the efficacy of the proposed management options under potential future scenarios. The Water Evaluation And Planning Tool (WEAP) (<http://www.weap21.org/index.asp>, accessed on July 6, 2008) was utilized in this regard.

1.2 Importance of the Study

Nablus City like many other Middle Eastern cities undergoes water shortage problems that need to be addressed and solved. The Municipality of Nablus serves more than 170,000 inhabitants (PBCS, 2007) including the four refugee camps which are Balata, Old Askar, New Askar and Ein Beit El Ma. In addition, few surrounding villages are supplied with water by Nablus Municipality. These villages are Asira Ashamaliya, Zawata, Deir Sharaf, Al-Badan, Al-Juneid, Faraa, and Talluza through the Water Supply and Sanitation Department. As a first step for solving the on-going problem, an assessment of the current situation should be considered to find out the ramifications. This assessment is carried out by developing a

supply-demand model using WEAP. Thereafter, this WEAP model will be utilized to assess and evaluate the outcome of the different options.

WEAP is a powerful tool for water planning and management. WEAP incorporates water supply in the context of demand-side issues, and provides a practical tool for water resources planning. WEAP is distinguished by its integrated approach to simulating water systems.

The importance of the study emerges from the following facts:

1. This is the first time WEAP will be developed and utilized at city level for the assessment of urban water management;
2. The Municipality of Nablus has absolutely no tool to assess the efficacy or the outcome of the proposed management options; and
3. The experience gained from carrying out this research can be further extended to other urban centers in the West Bank.

1.2 Description of the study area

The City of Nablus is one of the major Palestinian cities. It is located in the middle of the northern part of the West Bank (see Figure 1).



Figure 1. Location of the City of Nablus

As shown in Figure 2, the city is located between two mountains; Eibal (940 m amsl) in the north and Gerizim (881 m amsl) in the south.



Figure 2. The two mountains of the City of Nablus

The city has an area of about 28.5 km² (<http://ar.wikipedia.org>, accessed on June 10, 2008) and has a population of approximately 156,992 inhabitants (PCBS, 2007) including the four refugee camps.

Nablus has hot dry summers and moderate rainy winters. The maximum average temperature in the year is during the month of August, which is 29.4 °C while the minimum average temperature is 6.2 °C during the month of January (<http://www.nablus.org>, accessed on June 15, 2008).

Rainfall in Nablus is limited to the winter and spring months from October to May. The total annual mean rainfall is approximately 660 mm with a range from 350 to 1200 mm as shown in Figure 3.




Figure 3. The annual and the annual average rainfalls of Nablus City for the period from 1975 to 2007 (The meteorological station of Nablus, 2008)

The mean annual relative humidity of Nablus City is 62%. The minimum value of humidity is 50.72% in May, while the maximum humidity is 67% is usually reported in December (<http://www.nablus.org>, accessed on June 15, 2008).

Groundwater is the sole source of water in Nablus City. The Municipality utilizes four deep groundwater wells located outside the city. These wells cover an average of about 80% of the present supply (according to the Municipality of Nablus). In addition, five major springs located within the city boundaries are utilized. The average yield rates of the wells and springs of Nablus City are depicted in Figure 4. Additional information related to the existing water infrastructure and supply procedure is given in Chapter 3.




Figure 4. The average yield of water sources in Nablus City (Lahmeyer and Setec, 2004)

1.4 Research motivations

The research is motivated by the following issues:

1. The importance of understanding the extent of the existing problems in the water sector of the City of Nablus;
2. Nablus City is expanding very fast and assessing the potential solutions for the water supply problems is vital;
3. Decision makers lack a tool that can aid them in the planning and management of the water sector and WEAP is a tool that provides instant answers to raised planning inquiries.

The following are the main deficiencies in the water sector of the City of Nablus that motivate carrying out the work furnished in this thesis (Lahmeyer and Setec,2004):

- Insufficient water resources especially during summer time;

Undersized distribution network where 2 and 3 inch pipes are mostly used to provide water for wide and extended areas resulting in high head losses. However, recently there were replacements of some undersized pipes and this led to decrease the water losses. Replacements included a 14-inch transmission link between Deir Sharaf well and Ein Beit Elma reservoir, and replacement of Rafidia area network by higher diameter pipes.

- High water losses from the network;
- Lack of proper bedding of pipes that are close to the surface. This results in frequent pipe bursts and damages due to traffic;
- Heavy reliance on continuous direct pumping into large sections of the pipe network with widely differing elevations. This generates excessive head in low areas and sites close to the pumping stations. But there will be restructuring and optimization of the main system, aiming at water loss reduction and operation efficiency by using the available water resources focusing on defining pressure zones where the pressure is not to exceed 10 bars at lowest points and 3 bars at highest points (Lahmeyer and Setec,2005).
- Negative pressure as a result of the intermittent supply operation and risk of contamination with sewage and pollutants.

1.5 Research main objective

The main objective of the thesis is to evaluate the existing conditions related to the water supply system in the City of Nablus and to assess the long-term impacts of the proposed management options under potential driving scenarios using WEAP.

1.6 Why WEAP?

WEAP was chosen in this research due to the following reasons:

- Recently, WEAP received a great deal of attention where it is being applied at national and international levels;
- WEAP can be used at different levels spatially and temporarily;
- Its capabilities promote using it as a decision support system (DSS);
- Easy to use;
- The developers of WEAP can provide technical help;
- Public domain for academic use; and
- Capable to simulate conveniently hydrology, groundwater utilization, and wastewater treatment.

1.7 Methodology

The research methodology is comprised of three main phases as shown in Figure 5. The first phase includes data collection mainly from Nablus Municipality, Water and Environmental Studies Institute at An-Najah National University, relevant reports and studies, and information from the

internet. Interviews and meetings with the engineers of the Department of Water Supply and Sanitation at Nablus Municipality were carried out especially to comprehend the existing situation and to gain an understanding regarding the management plans intended to mitigate the on-going water-related problems. In addition to the above, literature review was carried out regarding WEAP and its past applications. As such, reports and journal articles were reviewed.




Figure 5. Depiction of research methodology

The second phase implies knowledge acquisition on WEAP and its applications. The training manual accompanying WEAP was used to improve and direct my skills in using WEAP and to get acquainted regarding WEAP main functionalities.

The third phase entails the development of the conceptual model using WEAP. The conceptual model matches the existing conditions. Potential scenarios were proposed and were utilized in the research to explore the outcomes that correspond to the different applicable management options. As such, the planning and management alternatives were conceptualized (adapted from the Department of Water Supply and Sanitation of the Municipality of Nablus) and were later processed using WEAP.

1.8 Thesis outline

The general structure of the thesis goes as follows. Chapter II furnishes related literature review for WEAP past applications. Chapter III describes modeling demand and supply using WEAP corresponding to the existing conditions. Chapter IV demonstrates WEAP-based assessment of the different management options that correspond to the potential scenarios. In Chapter V, the conclusions and recommendations based on WEAP outcomes are furnished.

CHAPTER TWO
LITERATURE REVIEW

2.1 General

Planning, developing, and managing water resources to ensure adequate, inexpensive and sustainable supplies and quality of water for both humans and natural ecosystems can only be successful if such activities address the causal socio-economic factors, such as inadequate education, population pressures and poverty (Loucks and Beek, 2005).

Water management must be undertaken using an integrated approach that can achieve social equity, sustainable environment, and the economic efficiency which makes the identification and implementation of effective solutions much easier and improves the efficiency in water use (Global Water Partnership, 2004).

In the following sections, a brief description of WEAP is provided and review of available past studies that utilized WEAP is furnished.

2.2 Water Evaluation And Planning System (WEAP)

WEAP is a computer tool for integrated water resources planning. WEAP was created in 1988, and is continuously being updated by the Stockholm Environment Institute, Boston, US, with the aim to be a flexible, integrated, and transparent planning tool for evaluating the sustainability of current water demand and supply patterns and exploring alternative long-range scenarios. It provides a comprehensive, flexible and user-friendly framework for policy analysis and a system for maintaining water demand and supply information.

As a forecasting tool, WEAP simulates water demand, supply, flows and storage. WEAP operates on the basic principle of water balance and can be applied to municipal and agricultural systems, a single watershed or complex trans-boundary river basin systems. Moreover, WEAP can simulate a broad range of natural and engineered components of these systems, including rainfall-runoff, baseflow, and groundwater recharge from precipitation; demand analyses; water conservation; water rights and allocation priorities, reservoir operations; pollution tracking and water quality.

As such, WEAP is an effective tool for examining alternative water development and management options. Scenarios are used to explore the

model with an enormous range of "what if" questions, such as: what if population growth and economic development patterns change? What if reservoir operating rules are altered?

In this study WEAP forecasted water demand for the year 2035 in Nablus City, after providing information like population, population growth rate, annual use rate and consumption. WEAP simulates unmet demand according to supply sources under different management options and corresponding scenarios.

WEAP applications generally include several steps:

- Study definition: The time frame, spatial boundaries, and system components are established.
- Current accounts: Actual water demand, pollution loads, and available resources and supplies for the system.
- Scenarios and options: A set of alternative assumptions about future impacts of policies, costs, and climate (on water demand and supply, hydrology, and pollution) can be explored.
- Evaluation: The scenarios are evaluated with regard to water sufficiency, costs and benefits.

2.3 WEAP Applications

Lévit et al. (2003) developed water demand management scenarios in a water-stressed basin in South Africa using WEAP. This study was done for the water resources of the Olifants River Basin which is almost fully allocated. It flows from the highly populated and industrialized Gauteng Proven to Mozambique. To get a rapid and simple understanding of water balance at different levels in the basin and equity needs in water allocation, the study was done using WEAP model as a mean of addressing water allocation question in water stressed river basin. The use of WEAP allowed the simulation and analysis of various water allocation scenarios, by representing the system in terms of its various sources of supply (rivers, groundwater), water demand sights, reservoirs (location, capacity, operation), and the major water users. For each user, the activity level, the water demand, and return flow were introduced. Water demand management options can be included in WEAP either at specific sites (for example, by studying the possibilities for saving water by individual users) or globally. The study chose to consider the effect of the overall efforts of all users. Three options of water demand management were included in WEAP (at 10%, 20%, and 30% of saving water by users). The simulation results demonstrate that with no water demand management efforts, the requirements of up to 15 users would not be met. Moreover, for certain users, even extreme water demand management efforts (30% of saving water) would not be enough. This is possibly a consequence of their

position in the basin, on the other hand, at certain other locations; limited efforts appear to be sufficient to meet local requirements.

Using WEAP, Alfarra (2004) developed an IWRM model that can help to better understand the situation in the whole catchments and identify where problems do exist. The system of uncoordinated water resources management in the basin of Lake Naivasha in Kenya cannot sustain the ever increasing water needs of the various expanding sectors. Such increase in water needs include the increased water demand throughout the region because of the increase in human population, which causes a strain on agricultural production, larger flower farms, industrial and other sectors. This may lead to the dry up of Lake Naivasha during droughts. The WEAP model shows that the main problem in the area is caused by a number of identified water uses in agricultural sector. According to the study, water is misused by over-irrigation in fodder, grass, vegetable farming, and flower farm. Scenarios were built (reference, water year, water demand and supply, water balance, net evaporation scenarios, etc) and then the analysis of the results of the scenarios was carried out. Modeling demand and supply helped to observe and understand a wide long-term vision of the problem.

Assaf and Saadeh (2006) used WEAP for the development of an integrated decision support system for water quality control in the upper Litani basin. The study was developed to control water quality in the upper Litani basin in Lebanon due to the current practices of discharging untreated sewage

into the river causing wide-scale pollution. A decision support system (DSS) was developed using WEAP to help decision makers and other stakeholders assess alternative water quality control policy options to mitigate water pollution in the river. It was used to assess water quality conditions under three scenarios; the reference scenario where no water quality measures are introduced, another one considers adoption of an environmental master plan (the Council for Development and Reconstruction (CDR) plan), which is the construction of seven secondary wastewater treatment plants to serve seventy five towns, and the third scenario represents small scope plan which is the construction of six secondary wastewater treatment plants to serve eleven towns. The three selected scenarios were run against three hydrological records representing low, average and high river flows. The three scenarios were assessed only in terms of the Biochemical Oxygen Demand (BOD) using WEAP. The results showed that the CDR plan is effective in improving water quality.

Charlotte et al. (2006) used WEAP in the Rio Grande/Bravo Basin. The Rio Grande/Bravo basin is located in North America between two riparian nations, the United States and Mexico. This river basin is currently considered a water scarce area with less than 500 m³ per person per year of available water. Throughout decades, there has been a lot of population growth in the basin, with population expected to double. The study describes the basin-wide WEAP model that was constructed to help evaluate stakeholder driven scenarios to more effectively manage these

highly stressed water resources. The goal of study project was to create a hydrologic model that can be calibrated in the future. A Rainfall Runoff Soil Moisture model that allows for the characterization of land use and soil type impacts to hydrological processes was utilized. Evapotranspiration, surface runoff, sub-surface runoff and deep percolation were computed. Demands and supply, river, groundwater, local reservoirs, and return flows were all linked. The results show a good approximation to both annual and monthly flows. The model could be useful in generating inflows to the basin under various sequences of future precipitation.

Abu Hantash (2007) used WEAP for the development of sustainable management options for the water resources of the West Bank. The study considered different scenarios to ensure adequate, sustainable supplies and qualities of water. These scenarios are: (1) current state of occupation and closure scenario which includes: water management module ([i] demand management: domestic, industrial, and irrigated area as current, [ii] water conservation: improving infrastructure to decrease losses down to < 30%, [iii]-supply management), future expansion module (based on population growth, industrial demand, irrigated areas, domestic as current), water availability module, water cost module, water quality module, knowledge quality module, (2) consolidate state when peace process moves on scenario: domestic, industrial, and irrigated area demand was increased, improving infrastructure to decrease losses to <25%, supply management include additional annual supply of 70-80 mcm from GW, water

availability module development of additional 80 mcm, no increase in water cost module, for water quality module municipal have wastewater collection, for knowledge quality module: education awareness, (3) independent state of Palestine scenario: increase user awareness to save water and protect it from pollution, improving__infrastructure to decrease losses to <20%, Palestinian will gain their water rights and will develop all their needs, future expansion module: based on regional equity between Palestinian and Israelis, industrial demand projected to reach 13% of municipal water, irrigated areas will achieve the land requirement for national consumption needs 0.14 donum/capita, development of Palestinian needs from aquifers, Jordan river, treated water, wadis, cistern, collected wastewater used in agriculture, increase education to decrease water demand. WEAP output showed that management cannot take place properly if the existing situation continues, and implementation of water resource management aspects can take place only when peace process move on.

Arafat (2008) used WEAP software to build an IWRM model on Al-Faria catchment, and to examine alternative water development and management strategies. Different scenarios for Al-Faria watershed were investigated. The impact of these scenarios were evaluated. These Scenarios were (1) “Do-no-thing Scenario” shows the reference scenario that reflects the existing conditions. (2) Suggestion to establish wastewater treatment plant (WWTP) in the catchment to reuse water from agricultural and domestic

sites. (3) Wadi Al-Faria watershed is threatened by rapid population growth in the city of Nablus and several refugee camps. (4) well known that the new techniques can save about 30% of the irrigation water through the reduction of water losses by conveyance system as well as evaporation from soil surface. From the suggested scenarios, it was shown that all of them are successful to control and manage the water consumption in the region, but the most effective scenario is to use new techniques in agriculture.

To conclude, WEAP was used usefully in water demand management, developing integrated decision support system to control water quality in basins, developing IWRM models to identify the water allocation problems between users and thus to identify where is the misuse of water, and development of sustainable management options for water resources.

CHAPTER THREE
MODELING WATER SUPPLY AND DEMAND FOR
NABLUS CITY USING WEAP

3.1 Introduction

All people, whatever their stage of development and their social and economic conditions, have the right to have an access to drinking water in quantities and of a quality that suffice their basic needs (UN,1977).

Currently, the City of Nablus is suffering from a shortage of water and insufficient resources. Since twelve years, no new resources were developed to meet the increasing demand that accompany the population growth and urbanization until recently a new groundwater well (Sabastia well) was drilled for the utilization of the City of Nablus and the neighboring villages.

Water shortage in the City of Nablus can be attributed to the following:

1. Demand exceeds supply due to the increase of population without increasing the water quantity or developing new water resources,
2. The municipality is not permitted by the Israelis to dig new wells,
3. Losses of water from the distribution system due to the deficiencies in the existing system that uses pipe diameters less than the required, due to the aged pipes in many locations, and due to the poor maintenance and excessive pressure heads,
4. The expansion of the city exceeded the planning expectations. Several none residential sites were developed very rapidly and became full of residents. This situation has exacerbated the problem of water in the city as additional water infrastructure is needed. This

in turn increases the cost of construction and the cost of pumping for elevated and remote areas.

3.2 Water Supply in Nablus City

Water supply in the city comes from the springs located within the city boundaries and from the groundwater wells located outside the city boundaries (see Table 1). The Water Supply and Sanitation Department (WSSD) of Nablus Municipality operates four groundwater wells located outside the city's boundaries and these are Audala, Al-Badan, Al-Far'a, and Deir Sharaf wells, and utilizes five major springs and these are Ein Beit Elma, Al-Qaryon, Ras Al-Ain, Ein Al-Asal, and Ein Dafna springs for supplying water for all water-using sectors inside the city and for some villages and camps. Figure 6 shows the location of the water sources. The springs of the city derive their water from the rain that fall on the two mountains located inside the city. Therefore, there are fluctuations in spring yield from month to month, season to season, and year to year. This variability relies largely on the groundwater recharge which in turn depends on the total rainfall and level of urbanization.

Inside the City of Nablus, there are twelve operating storage reservoirs that are fed from wells and springs, two of them are out of order (see Figure 7 below, Figure 1 in appendix B). These reservoirs vary in size and date of construction (see Table 2). All storage reservoirs are combined with the pumping stations. There are ten pumping stations distributed throughout the city and provide water to the different service zones (see Figure 7).




Figure 6. Location of the water sources of the City of Nablus (Lahmeyer and Setec, 2004)




Figure 7. A schematic that shows reservoirs and pumping stations (Lahmeyer and Setec, 2004)

Table 1: Wells and springs of Nablus Municipality

| Name | Average yield(m ³ /d) | Elevation m (asl) | Coordinates | | location |
|-------------------------|----------------------------------|-------------------|-------------|--------|-----------------------------|
| | | | x | y | |
| Audala well | 4500 | 510 | 175200 | 173350 | 8km far, south east of city |
| Al-Bathan well | 4300 | 210 | 185610 | 179900 | 10km far east of Nablus |
| Al-Far'a well | 6000 | 100 | 185700 | 182700 | 4km far east of Bathan well |
| Deir Sharaf well | 3500 | 265 | 184650 | 166170 | 8km far west Nablus |
| Ein Beit Elma spring | 1574 | 454 | 173487 | 181846 | |
| A-Qaryon spring | 1447 | 538 | 174836 | 180542 | |
| Ras Al-Ain spring | 1169 | 580 | 174344 | 180292 | |
| Ein Al-Assal spring | 457 | 563 | 174399 | 180391 | |
| Ein Dafna spring | 340 | 531 | 176426 | 179998 | |
| Total m ³ /d | 23287 | | | | |

(Lahmeyer and Setec, 2004)

Table 2: The storage reservoirs of Nablus Municipality

| Reservoir | Capacity m ³ | Elevation m (asl) | Year of construction | Condition |
|---------------|-------------------------|-------------------|----------------------|--------------|
| Ein Dafna | 5000 | 531 | 1979 | Very good |
| New Reservoir | 3500 | 459 | 1995 | Very good |
| Northern | 500 | 668 | 1958 | poor |
| Southern | 500 | 645 | 1956 | moderate |
| Ras Al-Ein | 500 | 580 | 1953 | fair |
| Ein Al-Assal | 50 | 563 | 1952 | Very poor |
| Qaryon | 500 | 538 | 1935 | moderate |
| Juneid | 500 | 615 | 2000 | Very good |
| Ein Beit Elma | 250 | 454 | 1960 | poor |
| Total | 11300 | | | |
| Al Worash | 2000 | | | |
| Al-Horsh | 150 | 675 | | Out of order |
| Al-Rahbat | 500 | 568 | 1956 | Out of order |

(Lahmeyer and Setec, 2004)

3.3 Water Distribution System

The water distribution network of the city consists of about 270 km of water pipes ranging in diameter from 2 to 12 inches. Recently, a 14-inch transmission link was constructed between Deir Sharaf well and Ein Beit Elma reservoir.

The existing distribution system consists of a variety of pipe types: steel, cast iron, ductile iron, and galvanized steel. Lately, the polypropylene and HDPE pipes were used (Lahmeyer and Setec, 2004). The unaccounted for water is currently about 31% (<http://www.nablus.org>, accessed on Jan 8, 2009).

Nablus network supplies water to nine service zones as shown in Figure 8. The zones are supplied by water intermittently by a group of skilled water staff who is managing the system mainly by using controlling valves in order to supply all customers at least twice a week in winter time and almost once a week during summer time. This depends mainly on the experience and the understanding of the duration that every zone needs to get its need of water by simply filling up all the roof tanks (see Table 1 in Appendix A).




Figure 8. Supplied zones of Nablus City (Lahmeyer and Setec, 2004)

3.4 Water Quality

According to the Chemical analysis carried out by the Water and Environmental Studies Institute at An-Najah University, the groundwater quality of Nablus City is accepted for drinking water.

Table 2 in Appendix A summarizes the results of the chemical analysis performed in September 2006 for the wells and springs utilized by the Water Supply and Sanitation Department (Almasri, 2008). Upon examining the concentrations of the different parameters, it can be concluded that all the concentrations are below the maximum contaminant level and thus water is suitable for drinking purposes without a need for treatment.

Chlorination is the sole method of water disinfection. In general, chlorine is injected directly into the main supply at well locations (since villages receive their water immediately from the wells) or by mixing with water in the reservoirs of the pumping stations (see Figure 9).




Figure 9. Chlorination tank and injector at Deir Sharaf well.

3.5 Unaccounted for water

The water distribution network of Nablus City encounters a high percentage of unaccounted for water. Figure 10 shows the percentage of unaccounted for water from 1997 to 2007 while Figure 11 shows the difference between water production and water sold where this difference indicates the unaccounted for water.




Figure 10. Percentage of unaccounted for water
 (<http://www.nablu.org>, accessed on Jan 8, 2009).




Figure 11. Water Production and water sold
 (<http://www.nablu.org>, accessed on Jan 8, 2009).

Unaccounted for water is divided into: (1) physical losses which is called leakage. It varies spatially from location to location throughout the network depending on the age of the pipe, pressure magnitudes and proximity to the water source. Water leakage is attributed mainly to the following reasons: (i) the aged water distribution network, and the pipes diameter which is less than the required (ii) the improper linkage of houses and supplied units to the network especially for the old places, (iii) the incorrect and wrong burial of the network pipes, (iv) the failures and faults in the bulk meters located in the pumping stations. (2) Non-physical water losses which are called apparent losses, attributed mainly to the following reasons: (i) mistakes in reading meters due to the poor conditions of the household meters, and the low sensitivity of these meters to low flow rates, (ii) water thievery, and (iii) unpaid consumed quantities for example quantities for the public facilities, mosques and worship houses, schools, fire station and the slaughterhouse.

3.6 Water Demand and Consumption

Water demand increases with time due mainly to population growth. Therefore, new water resources ought to be developed in order to meet the increasing water demand at present and in future.

According to the Inception Report "Hydraulic Analysis Study of the Nablus Water Supply System" the potential unmet water demand in the future considering an annual growth rate of 3.5% is shown in Figure 12. This

figure shows the projected average annual domestic and non-domestic water demand in the years 2005, 2015, and 2025, and the available water production and deficit of water with population growth. Apparently, the unmet water demand (demand minus water availability) increases over time.




Figure 12. Water demand, water production and unmet water demand

The average per capita daily water consumption is 50 liters for villages and refugee camps and 70 liters within the city boundaries (Lahmeyer and SETEC, 2004). However, the daily water consumption varies throughout the year. For example, Figure 13 shows the average per capita daily water consumption for the years 2006 and 2007 for the Old City of Nablus. This consumption rate is below the recommended limit of the World Health

Organization (WHO) of 150 L/c-d, (http://wedc.lboro.ac.uk/WHO_Technical_Notes accessed on Jan 11, 2009). The figure shows that the daily water consumption varies throughout the year according to climate variation from season to season, very low water consumption in winter months, but rises during summer months due to the increase in water use in bathing, cleaning, and irrigation. Also, there is a variation in water consumption from one area in the city to another, which reflects the socio-economic conditions.




Figure 13. Average per capita daily water consumption for the years 2006 and 2007 for the Old City of Nablus (Almasri, 2008)

3.7 City Expansion

City expansion is characterized mainly by the increase in the built-up areas and the increase in pavements. Due to the rural-urban migration and the natural increase in population, utilizing an existing supply system or a distribution network to provide water to an extended area will result in an increase in headlosses and energy cost, especially in areas that are of high altitudes with reference to the pumping stations. In addition, urbanization has a potential negative impact on the groundwater recharge collected by the spring catchment areas. Therefore, urbanization may lead to a decline in the spring yield on the long term (figure 2 in Appendix B shows the expected expansion areas according to "Hydraulic Analysis Study of Nablus Water Supply System" Inception Report) .

3.8 Nablus City WEAP Model

The assessment model was constructed using WEAP, which operates on the basic principle of water balance for every node and link in the system subject to demand priorities and supply preferences.

Figure 14 shows Nablus WEAP model which consists of nine demand sites represented by the red circles (nodes) and eight water supply sources. The supply sources are seven reservoirs represented by green triangles and one more supply for Almasaken Al shabiyah area represented by a green square. Demand sites are connected to the water sources by transmission links (the green lines). The wastewater outflows from demand sites are

represented by return flow links (the red lines) that lead to the receiving bodies (wadis).




Figure 14. Nablus City WEAP model

3.8.1 Establishing the Current Accounts in WEAP

The current accounts represent the basic definition of the water system as it currently exists. In our case, the model simulation period is taken from 2008 to 2035, and the year 2008 was selected as the current year. The first step in this work was the development of WEAP schematic that shows all components needed in the model (water resources which are reservoirs that are connected to the demand sites by transmission links, in addition to return flow links). The data used in the model were for the year 2008, by defining the water uses in each demand site and for each user, the population or the number of devices, the population growth rate, and the

per capita water use rate were defined, also monthly inflow and storage capacity for reservoirs were considered. Then four scenarios were proposed to explore the model under six management options, and finally WEAP outcomes were assessed.

Identifying current water uses: Existing water uses that are used in WEAP model can be classified as follow:

- Residential
- Health care
- Schools
- Institutions
- Industrial (only from Ein Dafna, because of the location of industrial zone)

Activity levels are used to describe the demand sites. if the demand site represents a residential site or a school, then the activity level is the number of people. If it is a health care center, then the activity level is the number of beds. For other institutions it is the number of buildings. Water use rate is the average annual water need per unit of activity.

Demand in WEAP: The demand represents the amount of water needed by the demand site for its water use. The demand for water is calculated as follows:

Total demand = Total activity level × Water use rate.....

(1)

Supply Elements: These elements will be defined by the main reservoirs; Ein Dafna, New, Northern, Alqaryon, Ras Elein, Southern, and Ein Beit Elma Reservoirs. These reservoirs are fed by springs and wells as shown in Figure 7. For Ashabya Zone, it gets its water needs directly from the main line of Albadan well.

The monthly inflow, storage capacity, and net evaporation for each reservoir (which is zero because they are closed) were defined. Table 3 in Appendix A shows the monthly pumping amounts to the several zones which were used in the model as monthly inflow to the reservoirs.

Supply and preference: If a demand site is connected to more than one supply source, choices for supply where a specific supply is preferred to be used firstly may be ranked using supply preferences.

Transmission links: There is a need to connect supply sources to each demand site in WEAP model to satisfy the demand through creating a transmission link from supply nodes to demand sites to satisfy final demand at the demand sites. These transmission links are subject to losses that are about 31% (<http://www.nablus.org>, accessed on Jan 8, 2009). As such, the total amount delivered to the demand site equals the amount withdrawn from the source minus the losses.

Return flow links: These links are used to transmit wastewater from demand sites to destinations such as wastewater treatment plants or receiving water bodies.

Priorities for water allocation: Competing demand sites allocate water according to their demand priorities. These priorities are useful during a water shortage where sites with higher priorities are satisfied as fully as possible before lower priority sites are considered.

3.8.2 WEAP Input Parameters

In order to build up the WEAP model, the current supply and demand data were entered to WEAP model. Table 4 in appendix A and Figure 15 show the demand data entry table in WEAP).




Figure 15. Demand data entry table

CHAPTER FOUR
ANALYSIS OF SCENARIOS AND MANAGEMENT
◉ OPTIONS

4.1 Introduction

In this chapter, the assessment of the different management options that correspond to scenarios will be demonstrated using WEAP model. Scenarios were built using WEAP, and then their impacts on water supply and unmet water demands in the city were assessed. Figure 16 shows the proposed management options for the different scenarios that were assessed using the developed WEAP model.




Figure 16. The scenarios and the management options for the City of Nablus as assessed by the WEAP model

The following sections illustrate these scenarios and the corresponding management options along with the assessment carried out using WEAP.

4.2 Scenarios

Four main scenarios were considered in the assessment:

- Scenario 1 (Reference scenario): This scenario represents the current system conditions with its water supplies (reservoirs) and demand sites (with population, annual use rates). It starts from a common year for which the model current accounts data are established. In this study, the current year is 2008. This scenario represents the changes that are likely to occur in future under conditions depicted in Figure 17.




Figure 17. Reference Scenario and Corresponding Management Options

- Scenario 2: Population growth increases more than 2.6% to be 3%. This increase is due to the assumption of improving the city conditions (economic and political conditions)

which encourages people who immigrate to another city or country to return to the city. In addition, the placement of people from villages to the city is another cause to the increase in population growth.

- Scenario 3: Climate change which is the change in magnitude of a single climate parameter such as temperature. The assumption that there will be a decline in the yield of the water resources can be attributed to the potential impact of climate variability which may lead to a decline in spring and well yield and groundwater recharge below the average values (Almasri, 2008). In this scenario the effect of climate change on water resources and the yield, and how this change will affect water supply and the unmet water demand were considered.
- Scenario 4: This scenario uses the WHO standard for daily use rate which is 150 l/c-d. Thus, this scenario shows how is the unmet demand will increase under the existing conditions and management options.

4.3 Management Option

4.3.1. Key Factors

The key factors that have significant effects on developing water resources and the formulation of the management options under different scenarios are:

1- Political constraints: this is represented by the Israeli restrictions on all the development schemes of existing and new water resources for the City of Nablus. For example, difficulties to lay new pipes or replacement of existing transmission lines that connect groundwater wells with their reservoirs. This is an apparent problem when these transmission lines are located partly outside Nablus City behind the check-points. In addition, the obstructions to get a license to dig a new well, which takes several years of negotiations. Even if the license is granted, there will be restrictions on the well depth and thus well productivity.

2- Financial constraints: Since the available funds for water resources development are scarce and depends on external donations, the choices for water supply alternatives will be restricted in magnitudes to these funds. For example, there is a water leakage reduction project in Nablus network in which there will be a replacement of the old pipes by new ones with higher diameters. This project is funded by KFW. There is a lot of projects which need funds to implement, like a wastewater treatment plant in the east of Nablus, separation of the wastewater from stormwater, construction of reservoirs to save the unused water from springs in winter months.

3- Socio–Economic Aspects: Water resources development should go beyond the mere allocation of certain quantities of water concerned with the quality of life for people, in addition, although water is available it cannot be afforded to pay for it.

4.3.2 Management Options

The following are the management options that are proposed by the Municipality of Nablus:

- Developing a new groundwater well in Sabastia (Sabastia well): There will be an additional quantity of water supply due to the construction of the new well with a yield of 350 m³/h, 250 m³/h for the city and 100 m³/h for the neighboring villages (personal communications, Eng. Areej Kittaneh, Nablus Municipality). It is funded by Arab Fund for Economic Development in cooperation and partnership with Palestinian Water Authority (see Figure 18). In this option additional quantity of 50 m³/hr from Rujeib well will be added.



Figure 18. Sabastia Well during construction

- Reduction in water leakage: by improving the water infrastructure, the unaccounted for water rates will be reduced and losses will drop to 25% in this option.
- Storm water harvesting: The City of Nablus utilizes a combined system for wastewater and stormwater collection. The estimated volume of urban stormwater is approximately 2-4 mcm/yr (Lahmeyer and Setec, 2004) which is completely lost through the two major drainage systems of the city. This situation deprives the city from the potential reuse of the collected stormwater. Recently and when carrying out new construction and rehabilitation works for the sewerage system, the WSSD started to separate between the wastewater and stormwater collection systems.
- Rehabilitation of springs: Based on the estimates furnished in the "Hydraulic Analysis Study of the Nablus Water Supply System" . Additional water quantities can be obtained from the city springs once rehabilitated. This implies an additional amount of water of about 15% of springs' yield that can be utilized for domestic purposes. Spring rehabilitation implies storing the lost water from springs during winter months.
- Wastewater reuse: The increase in demand for the limited raw water resources has led to the proposals of reusing treated wastewater in agricultural production, industrial cooling, landscape watering and recharges to aquifers. This in turn will be on the expense of reducing the use of fresh water in these applications and thus more fresh water

can be used to supply for potable water needs. Wastewater in the City of Nablus is being disposed of without treatment. After leaving the two main outfall points (in the east and west), untreated wastewater flows in open channels (wadis) as shown in Figure 19. Recently, an approval was given for the construction of Wastewater treatment plant (WWTP) in the western part of Nablus, which receives wastewater daily inflows of about 6000 m³ according to the Sewerage Project Nablus West Report 2. The effluent standards will be determined to be: BOD5 20 mg/l, SS 30 mg/l, N (total nitrogen) 50 mg/l (Lahmeyer, 2007). The effluent of treated wastewater will be used for agricultural irrigation in the nearby villages. This option will not be used in this study since it needs advanced treatments to use for public services in the city.



Figure 19. Wadi Zeimer

- Developing new groundwater wells: Based on different hydrological studies (for instance, the "Hydraulic Analysis Study of the Nablus Water Supply System") additional eight new wells can be developed to supply Nablus with additional water quantities. The proposed wells can provide some 9.3 mcm/yr. The potential new wells are shown in Figure 20 (Table 5 in Appendix A).

But this option is not realistic and still not applicable because the municipality cannot construct all these wells at once and there will be Israeli restrictions and financial constraints. This study consider the development of four wells at different time steps: By using Deir Sharaf N 3 which will start at the year 2015 with a yield of 1.1 mcm/year, using Deir Sharaf N 4 which starts in the year of 2020 with an annual yield of 1.8 mcm, using Yutma N 1 which starts in the year of 2025 with an annual yield of 1.5 mcm/year, and finally using Yutma N 2 with a yield of 1.5 mcm/year and starts in the year 2030.




Figure 20. Potential new wells locations (Lahmeyer and SETEC, 2004)

Table 3 summarizes the proposed future scenarios and the management options.

Table 3: Summary of future scenarios and management options

| Scenarios | Description | | |
|---------------------|--|----------------------------------|--|
| Population increase | In this scenario, the impact of increasing the population growth rate to be 3% on water demand, and the unmet water demand, was assessed under potential management options, using the minimum standard for daily use rate which is 100 l/c-d. | | |
| | Management options | | Description |
| | 1 | With no water supply development | The impact of population growth increase on water demand, and the unmet water demand, with no new water resources were developed |
| | 2 | Construction of Sabastia well | The impact of increasing the amount of water supplied by adding Sabastia well 300 m ³ /h (250 m ³ from sabastia+50m ³ from Rujeib) |
| | 3 | Rehabilitation of springs | The impact of additional 15% of springs yield (202025 m ³ /year) that can be utilized for domestic purposes will be evaluated |
| | 4 | Reduction in water leakage | The impact of decreasing the water leakage to 25% instead of 31% on the unmet water demand |
| | 5 | Stormwater harvesting | The impact of increasing the amount of water supplied by adding the amount of stormwater harvesting, which can be used in public services and it is estimated to be 2 mcm/year |

| | | | |
|----------------|---|---|---|
| | 6 | Construction of additional supplied wells | The impact of increasing the amount of water supplied by construction: 1- Deir Sharaf well N 3 with yield 1.1 mcm/year (from 2015-2035) 2- Deir Sharaf N 4 well with yield 1.8 mcm/year (from 2020-2035). 3- Yutma N 1 with yield 1.5 mcm/year (from 2025-2035). 4- Yutma N 2 with yield 1.5 mcm/year (from 2030-2035). (These wells will feed all reservoirs in the model) |
| Climate change | Considering the negative impacts of climate change accompanied with declining rates in water resources replenishment due to decrease in rainfall amounts and the increase in water demand due to increase in temperatures, using the minimum standard for daily use rate which is 100 l/c-d, the assumption of declining 20% of the water sources yield | | |
| | 1 | With no water supply development | The impact of declining of wells and springs yield, which is assumed to be 20% of its average yield on the unmet water demand. No new water resources development are considered |
| | 2 | Construction of Sabastia well | The impact of adding Sabastia well which in turn will be affected by climate change, which leads to a decline in its yield to be 240 m ³ /h |
| | 3 | Rehabilitation of springs | The impact of reduction the amount of springs rehabilitation which is declined 20% estimated to be 0.161 mcm/year |

| | | | |
|-----------------------------------|--|---|---|
| | 4 | Reduction in water leakage | The impact of decreasing the water leakage to 25% on the unmet water demand under climate change condition |
| | 5 | Stormwater harvesting | The impact of reduction the amount of stormwater harvesting which is declined 20% estimated to be 1.6 mcm/year |
| | 6 | Construction of additional supplied wells | The impact of climate change on the yield of the proposed new wells which will decline 20%: 1- The yield of Deir Sharaf well N 3 will be 0.88 mcm/year 2- Deir Sharaf N 4 well with yield 1.44 mcm/year. 3- Yutma N 1 with yield 1.2mcm/year. 4-Yutma N 2 with yield 1.2 mcm/year |
| Using WHO daily use rate standard | In this scenario, the standard of WHO for capita daily use rate, which is 150 l/c-d will be used to evaluate the existing supply systems and management options. | | |
| | | Management options | Description |
| | 1 | With no water supply development | The impact of increasing the daily water use rate to be 150 l/cd on water demand, and the unmet water demand, with no water resources development. |
| | 2 | Construction of Sabastia well | The impact of increasing the amount of water supplied by adding Sabastia well on the unmet water demand with increasing in water demand |
| | 3 | Rehabilitation of springs | The impact of additional 15% of springs yield (202025 m ³ /year) that can be utilized for domestic purposes on unmet water demand |

| | | | |
|--|---|---|--|
| | | | will be evaluated |
| | 4 | Reduction in water leakage | The impact of decreasing the water leakage to 25% on the unmet water demand under the increase of water use rate |
| | 5 | Stormwater harvesting | The impact of increasing the amount of water supplied by adding the amount of stormwater harvesting which is estimated to be 2 mcm/year, under the increase of water use rate. |
| | 6 | Construction of additional supplied wells | The impact of increasing the amount of water supplied by construction Deir Sharaf well N 3 , Deir Sharaf well N 4 , Yutma N 1 , Yutma N 2 on the unmet water demand, under the increase of water use rate. |

4.4 Results

WEAP was applied to assess all the proposed scenarios and recommended management options. A summary of sample results is provided in Tables 4.1, 4.2, 4.3, and 4.4. WEAP provides the results in charts (See Figures 21 and 22) or in tables, which include all demand sites (including all users: residential, health care centers, schools, institutions), and can show the results for every user in each demand site (for example see Table 6 in Appendix A, which shows the estimated water demand for the residential uses in Ein beit elma zone).

Tables (7, 8, 9, and 10) in Appendix A show the outcomes of the different management options related to the different scenarios. These tables show the water demand and the unmet water demand in each year of the simulation period which increase with time for every zone. For example, in Table 7 the water demand in 2011 when 100 l/c.d is considered equals 6.74 mcm, and the unmet water demand when no water resources development is 2.94 mcm, 1.13 mcm when Sabastia well is considered, 2.66 when water leakage is reduced, 1.56 mcm for stormwater harvesting, 2.8 mcm for spring rehabilitation, and 2.94 mcm for the option of developing new well.

Summary of sample results for different scenarios and management options

Table 4.1: Reference Scenario

| Reference Scenario | | | | | | | | | |
|---------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 70 l/cd | 4.74 | 5.35 | 6.84 | 8.76 | 1.327 | 1.789 | 3.39 | 4.896 |
| | With no water supply development using 100 l/cd | 6.58 | 7.44 | 9.54 | 12.26 | 2.789 | 3.621 | 5.645 | 8.265 |
| 2 | Construction of Sabastia well | | | | | 0.976 | 1.808 | 3.832 | 6.452 |
| 3 | Reduction in water leakage | | | | | 2.540 | 3.313 | 5.337 | 7.95 |
| 4 | Stormwater harvesting | | | | | 1.409 | 2.24 | 4.265 | 6.88 |
| 5 | Rehabilitation of springs | | | | | 2.65 | 3.48 | 5.506 | 8.126 |
| 6 | Development of new wells | | | | | 2.789 | 2.862 | 2.609 | 4.194 |

Table 4.2: Population growth increase scenario

| Population growth increases | | | | | | | | | |
|-----------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 100 l/cd | 6.69 | 7.72 | 10.27 | 13.70 | 2.905 | 3.887 | 6.345 | 9.64 |
| 2 | Construction of Sabastia well | | | | | 1.09 | 2.073 | 4.53 | 7.835 |
| 3 | Reduction in water leakage | | | | | 2.63 | 3.578 | 6.036 | 9.34 |
| 4 | Stormwater harvesting | | | | | 1.525 | 2.508 | 4.969 | 8.27 |
| 5 | Rehabilitation of springs | | | | | 2.765 | 3.747 | 6.205 | 9.509 |
| 6 | Development of new wells | | | | | 2.905 | 3.128 | 3.916 | 6.391 |

Table 4.3: Climate change scenario

| Climate change scenario | | | | | | | | | |
|-------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 100 l/cd | 6.58 | 7.44 | 9.54 | 12.26 | 3.498 | 4.33 | 6.354 | 8.974 |
| 2 | Construction of Sabastia well | | | | | 2.047 | 2.88 | 4.904 | 7.524 |
| 3 | Reduction in water leakage | | | | | 3.252 | 4.084 | 6.108 | 8.728 |
| 4 | Stormwater harvesting | | | | | 2.394 | 3.226 | 5.25 | 7.870 |
| 5 | Rehabilitation of springs | | | | | 3.287 | 4.219 | 6.24 | 8.863 |
| 6 | Development of new wells | | | | | 3.498 | 3.845 | 3.925 | 5.7179 |

Table 4.4: Adopting the WHO daily use rate standard scenario

| Using WHO daily use rate standard | | | | | | | | | |
|-----------------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 100 l/cd | 9.663 | 10.95 | 14.07 | 18.12 | 5.758 | 6.997 | 10.009 | 13.906 |
| 2 | Construction of Sabastia well | | | | | 3.945 | 5.184 | 8.196 | 12.092 |
| 3 | Reduction in water leakage | | | | | 5.45 | 6.689 | 9.700 | 13.597 |
| 4 | Stormwater harvesting | | | | | 4.378 | 5.617 | 8.629 | 12.526 |
| 5 | Rehabilitation of springs | | | | | 5.619 | 6.858 | 9.869 | 13.766 |
| 6 | Development of new wells | | | | | 5.758 | 6.238 | 6.97 | 9.835 |




Figure 21. Projected water demand for using 100 l/c-d scenario




Figure 22. Unmet water demand when using 100 l/c-d scenario

4.5 Discussion of results

- WEAP estimates the water demand and the unmet water demand for every zone alone taking in consideration the amount of supplied water to every zone, then adds the water demand or the unmet water demand for all zones together at the end of every year.
- The reference scenario WEAP results indicate the following:
 - 1- The total water demand will increase from 4.738 mcm in 2010 to 8.768 mcm by the end of 2035 when using the current average use rate of 70 l/c-d. This increase is due to population growth only. However, if the use rate reaches the minimum standard of WHO which is 100 l/c-d, then the amount of water demand will increase by 1.84 mcm to be 6.579 mcm in 2010 and by 3.49 mcm to be 12.26 mcm in 2035. The amount of unmet water demand will increase by 1.46 mcm to be 2.78 mcm in 2010, while for the year 2035 it will increase 3.37 mcm to be 8.26 mcm.

This is illustrated in Figures 28 and 29

- 2- The per capita water availability will decrease to become approximately 37 l/c-d at the end of the year 2035 if the available water remains the same and no new water resources will be developed (see figure 23). This decrease is due to the increase in water demand that accompany population increase with the same water available.
- 3- The decrease in the amounts of the unmet water demand when using the different management options are as summarized in Table 5, which

show the amount that every management option will decrease the unmet water demand.

4- Figures 24, 25, 26, and 27 show the unmet water demand for the different management options under the different scenarios. The most effective option for the period 2009-2025 is the construction of Sabastia well that gives the lowest unmet water demand during this period , and from the year 2025 until 2035 is the development of new groundwater wells since this will be more efficient in covering the unmet water demand. In this option the unmet water demand will start to decrease about 0.759 mcm when adding the first well in 2015, in 2020 the second well will be added then the unmet water demand will continue to decrease by an amount of 2 mcm until 2025 where the third well will be added that will decrease the unmet water demand to 3.036 mcm until 2030. The decrease here is more than Sabastia well option decrease, so in this period this option becomes more effective than Sabastia well option. The last well will be added in 2030, and then the unmet water demand will decrease by 4.07 mcm. The option of using stormwater harvesting gives satisfactory results in decreasing the unmet water demand better than the options of spring rehabilitations and the reduction in water leakage which give small decrease amount in unmet water demand.

- For the increase in population growth rate by 0.4%, the water demand increases by an amount of 0.12 mcm in the year 2010, and by an amount of 1.435 mcm in the year 2035.

- Using 150 l/c daily use rate scenario and when comparing the water demand for the different daily use rates in the year 2010 (see Figure 28) we got the following estimates:

$$70 \text{ l/c-d} = 4.74 \text{ mcm}$$

$$100 \text{ l/c-d} = 6.579 \text{ mcm}$$

$$150 \text{ l/c-d} = 9.663 \text{ mcm}$$

The water demand when using 150 l/c-d has increased by an amount of 4.9 mcm when using 70 l/c-d and 3.08 mcm when using 100 l/c-d. Also the unmet water demand increased by an amount of 4.43 mcm when using 70 l/c-d, and by an amount 2.97 mcm when using 100 l/c-d (see Figure 29).

- The connections between reservoirs are not possible in WEAP. This makes it impossible to transmit the surplus water between reservoirs and thus the unmet water demand cannot be possibly reduced. To overcome this problem, I tried to consider all demand sites as one demand site and all water sources as one source (by adding all water quantity available together). Tables 11, 12, 13, and 14 in Appendix A show the actual final unmet water demand in the City of Nablus

Table 5: The decrease in the unmet water demand for the different management options

| Reference, Population growth increase, and Using WHO daily use rate standard scenarios | | Decrease in unmet water demand (mcm) | | | |
|--|-------------------------------|--------------------------------------|--------|--------|--------|
| | | 2010 | 2015 | 2025 | 2035 |
| Management options | | | | | |
| 1 | Construction of Sabastia well | 1.813 | 1.813 | 1.813 | 1.813 |
| 2 | Reduction in water leakage | 0.308 | 0.308 | 0.308 | 0.308 |
| 3 | Stormwater harvesting | 1.38 | 1.38 | 1.38 | 1.38 |
| 4 | Rehabilitation of springs | 0.14 | 0.14 | 0.14 | 0.14 |
| 5 | Development of new wells | 0 | 0.759 | 3.036 | 4.071 |
| Climate change scenario | | | | | |
| 1 | Construction of Sabastia well | 1.4506 | 1.4506 | 1.4506 | 1.4506 |
| 2 | Reduction in water leakage | 0.246 | 0.246 | 0.246 | 0.246 |
| 3 | Stormwater harvesting | 1.104 | 1.104 | 1.104 | 1.104 |
| 4 | Rehabilitation of springs | 0.112 | 0.112 | 0.112 | 0.112 |
| 5 | Development of new wells | 0 | 0.607 | 2.429 | 3.257 |




Figure 23. Average yearly per capita daily water use rate




Figure 24. The unmet water demand under the reference scenario for the different management options




Figure 25. The unmet water demand under the population growth rate scenario for the different management options




Figure 26. The unmet water demand under climate change scenario for the different management options




Figure 27. The unmet water demand under 150 l/c-d scenario for the different management options




Figure 28. Water demand for 70 l/c-d, 100 l/c-d, and 150 l/c-d use rate




Figure 29. The unmet water demand for 70l/c-d, 100l/c-d, and 150l/c-d use rate

CHAPTER FIVE
CONCLUSIONS AND RECOMMENDATIONS

The following are the main conclusions and recommendations:

5.1 Conclusions

1. The results show that the unmet water demand will continue to increase over the coming years. This is mainly due to the increase in population with limited water resources. Therefore, securing additional water supplies becomes an essential issue to meet the increase in water demand.
2. The per capita water availability will decrease to reach approximately 37 l/c-d by the end of the year 2035 if the available water remains the same and no new water resources are developed.
3. The development of additional groundwater wells for water supply is an influential option especially for the period from 2025 to 2035. The option of using Sabastia well, will be an efficient option till the year of 2025. Stormwater harvesting gives satisfactory results. Improving the water-related infrastructure of the city to decrease the water losses is crucial in mitigating the water shortage problem.
4. WEAP has many shortcomings that I did experience such as:
 - i. The connections between reservoirs are not possible in WEAP. This makes it impossible to transmit the surplus water between reservoirs and thus the unmet water demand cannot be reduced possible.
 - ii. No connections can be made between groundwater wells and reservoirs.

- iii. Assessment of all options simultaneously cannot be carried out.

5.2 Recommendations

1. Since this is the first time to use WEAP at the city level, additional work should follow in this regard by other researchers in order to address all the outstanding issues including carrying out economic analysis.
2. To better improve the outcome of this work, stakeholder involvement should be considered when executing similar work.
3. It is highly recommended that Nablus Municipality has a better and well-arranged database that summarizes and contains all the information regarding water use rates for the different sectors in the city.
4. Since the deteriorated infrastructure is responsible for water leakage, it is highly recommended to carry out rehabilitation activities.
5. The Municipality of Nablus should continue working on public awareness campaigns, though people are consuming an average amount of water way less than the WHO standards. This is just to urge people to adapt to water availability.
6. It is highly recommended to continue the current work taking into consideration:
 - i) Pressure zoning that Nablus Municipality is executing nowadays.
 - ii) Mixing of scenarios or part of scenarios.

REFERENCES

- [1] Abu Hantash, S., (2007), **Development of Sustainable Management Options for the West Bank Water Resources Using WEAP**, MSc. thesis, Faculty of Graduate Studies, An-Najah National University, Nablus, Palestine.
- [2] Alfarra, Amani (International Institute For Geo-Information Science and Earth Observation Enschede), (2004). **Modeling Water Resource Management in Lake Naivasha**, The Netherlands
- [3] Almasri, Mohammad, (2008). **Impact of Climate Change**. Nablus, Palestine
- [4] Almasri, Mohammad, (2008). **Status and Challenges of Urban Water Supply in Palestine - The Case of Nablus City**, Nablus, Palestine
- [5] Arafat, A., (2007), **Integrated Water Resources planning for water-Stressed Basin in Palestine**, MSc. thesis, Faculty of Graduate Studies, An-Najah National University, Nablus, Palestine.
- [6] Assaf, H., and Saadeh, M., (2006). **Development of Integrated Decision Support System for Water Quality Control in Upper Litani Basin**, American University of Beirut, Lebanon

- [7] Charlotte C., Daene, C., Mckinney, E., Ingol-Blanco and Rebecca, T., (2006). **WEAP Hydrology Model Applied: The Rio Grande/Bravo Basin.Rio Grand Project**, Center of Research in Water Resources, Texas
- [8] LAHMEYER INTERNATIONAL, and SETEC ENGINEERING, (2004). **Hydraulic Analysis Study Of The Nablus Water Supply System**. Nablus. Palestine
- [9] LAHMEYER INTERNATIONAL, and SETEC ENGINEERING, (2005). **Hydraulic Analysis Study Of The Nablus Water Supply System, Conceptual Redesign Of The Main System**, Nablus. Palestine
- [10] Lévit, H., Sally, H., and Cour, J., (2003). **Water Demand Management Scenarios in a Water –Stressed Basin in South Africa,..** South Africa
- [11] Loucks,D.,and Beek,E., (2005). **Water Resources System, Planning and Management**. UNISCO Publishing, Italy
- [12] Mogheir, Y.,Abu Hujair,T., Zalmot, Z., Ahmad, A, and Fattaa,D., (2005). **Treated Wastewater Reuse in Palestine**, West Bank, Palestine
- [13] Palestinian Central Bureau of Statistics (PCBS), (2007). **Population Statistics for Nablus City**, Nablus, West Bank

- [14] Palestinian Water Authority (PWA), (2000). **Summary of Palestinian Hydrologic Data**, West Bank, Palestine
- [15] Water and Sanitation Department engineers, (2008). **Personal communication**
- [16] UN, (1997). **Report of the United Nations Water Conference**, New York, NY, U.S.A,1977.
- [17] Water and environmental study institute, (2008). **Water Quality information**, Nablus, Palestine.

Internet Websites

- [1] http://wedc.lboro.ac.uk/WHO_Technical_Notes, accessed on Jan 11,2009.
- [2] <http://www.nablus.org/en/htm>. accessed on June 15, 2008.
- [3] <http://www.weap21.org/download>. accessed on July 6, 2008.
- [4] <http://ar.wikipedia.org> PBCS. accessed on June 10, 2008.

APPENDIX A

Tables

Table 1: pumping hours for areas

| pumping station | summer days | winter days |
|---------------------------|--------------------|--------------------|
| Alein station | | |
| Rafidya | 15.5hrs/4days | 9hrs/2days |
| Almreij | 14hrs/4days | 9hrs/2days |
| Junblat alqadeem | 13.5hrs/4days | 7hrs/2days |
| Junblat aljadeed | 11hrs/4days | 7hrs/2days |
| Alein camp | 9hrs/2days | 5hrs/2days |
| Asira street | 16hrs/4days | 10hrs/2days |
| Zawata | 18hrs/4days | 8hrs/2days |
| Almaajeen | 10hrs/4days | 8hrs/2days |
| Aljneid | 7.5hrs/4days | 5hrs/2days |
| Ras el ein station | | |
| Ras elein | 6hrs/4+days | 3hrs/2days |
| Albasha | 10hrs/4days | 6hrs/2days |
| Abu obaida | 10hrs/4days | 6hrs/2days |
| Southern station | | |
| Altaawon | 9hrs/4days | 6hrs/2days |
| Alshinar | 9hrs/4days | 6hrs/2days |
| Tell | 17hrs/4days | 11hrs/2days |
| new Fatayer | 11hrs/4days | 8hrs/2days |
| Ein Dafna station | | |
| Alquds street | 21hrs/4days | 12hrs/2days |
| Amman street | 21hrs/4days | 12hrs/2days |
| Iraq altayeh | 17hrs/4days | 9hrs/2days |
| Khalet alamod | 14hrs/4days | 8hrs/2days |
| Salah aldeen | 11hrs/4days | 8hrs/2days |
| Adahyeh | 17hrs/4days | 9hrs/2days |
| Balata Camp | 13hrs/4days | 7hrs/2days |
| Old+new Askar camp | 15hrs/4days | 8hrs/2days |
| Khalet aleman alsoflya | 8hrs/4days | 5hrs/2days |
| Sumara station | | |
| Almakhfya | 17hrs/4days | 12hrs/2days |
| 15street,almtalleh | 14hrs/4days | 9hrs/2days |
| Northern station | | |
| Imad eddin,Beiker | 14hrs/4days | 8hrs/2days |
| Khalet aleman alolwyeh | 17hrs/4days | 11hrs/2days |
| Albalad | 20hrs/4days | 10hrs/2days |
| New reserrior | | |
| Assekkeh | 15hrs/4days | 9hrs/2days |
| Aqaryon station | 8hrs/4days | 5hrs/2days |
| Deir Sharaf | 9hrs/4days | 7hrs/2days |
| Almasaken ashabya | 20hrs/4days | 10hrs/2days |

Table 2. Chemical analysis of the main water sources of the City of Nablus.

| Water Source | PH | Turbidity(NTU) | NO3 mg/l | SO4 mg/l | PO4 mg/l | F mg/l | Cl mg/l | HC O3 mg/l | CaC O3 mg/l | TDS mg/l | Ca mg/l | Mg mg/l | Na mg/l | K mg/l |
|------------------|------|-----------------|----------|----------|----------|--------|---------|------------|-------------|----------|---------|---------|---------|--------|
| Odala well | 7.3 | 0.17 | 16.8 | 8 | 0.0 | 0.15 | 49.9 | 220 | 222. | 340 | 59.5 | 18 | 21 | 1.7 |
| Alfar'a well | 7.4 | 0.79 | 15.8 | 8 | 0.00 | 0.38 | 89 | 260 | 274. | 450 | 78 | 19.4 | 36 | 1.6 |
| AlBadan well | 7.24 | 0.31 | 13 | 10 | 0.01 | 0.23 | 69 | 240 | 252. | 390 | 65 | 22 | 28 | 1.5 |
| Alqaryoon | 7.16 | 0.15 | 19.5 | 6 | 0.0 | 0.15 | 45 | 190 | 191. | 290 | 57 | 12 | 19.5 | 1.9 |
| Deir sharaf well | 7.35 | 0.15 | 16.7 | 11.5 | 0.01 | 0.34 | 43 | 240 | 221. | 350 | 59 | 18 | 25.5 | 1.7 |
| Ein Beit Elma | 7.27 | 0.18 | 36 | 10 | 0.0 | 0.14 | 71 | 220 | 242. | 390 | 65 | 19.4 | 32 | 2.7 |
| Ein Defna | 7.5 | 0.16 | 24 | 8 | 0.06 | 0.1 | 59.9 | 220 | 216. | 350 | 62 | 15 | 35 | 1.5 |
| Ein Al-Asal | 7.46 | 0.16 | 14.1 | 8 | 0.01 | 0.12 | 39.9 | 165 | 167. | 260 | 43 | 14.5 | 21 | 0.38 |
| Ras Al Ein | 7.58 | 0.16 | 15 | 7 | 0.00 | 0.14 | 32 | 180 | 176. | 258 | 51 | 12 | 17 | 0.4 |

Table 3: amount of pumping m³/month

| pumping station | Month | | | | | | | | | | | |
|----------------------|--------|--------|--------|--------|---------|--------|--------|--------|--------|--------|--------|--------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 |
| Ein beitelma station | 120656 | 107939 | 122018 | 154971 | 153649 | 145280 | 146640 | 164736 | 145752 | 137135 | 137900 | 130400 |
| Ras el ein station | 16368 | 73080 | 42780 | 37440 | 25296 | 15840 | 15624 | 14880 | 12600 | 12960 | 13320 | 16368 |
| Southern station | 29997 | 29997 | 34188 | 38236 | 27747 | 24812 | 24812 | 24812 | 24812 | 24812 | 29997 | 29997 |
| Ein Dafna station | 145455 | 100833 | 124340 | 161840 | 181240 | 202200 | 202240 | 202142 | 198060 | 200552 | 186700 | 174948 |
| Sumara station | 28911 | 28911 | 27161 | 25665 | 19771 | 19433 | 19433 | 19433 | 19433 | 19433 | 28911 | 28911 |
| Northern station | 32222 | 32222 | 32165 | 28043 | 29084 | 22971 | 22971 | 22971 | 22971 | 22971 | 32222 | 32222 |
| New reservior | 95642 | 98642 | 102642 | 108475 | 115650 | 120038 | 135993 | 130493 | 125862 | 110685 | 105685 | 101360 |
| Alqaryon station | 23808 | 78509 | 71424 | 45720 | 38539.2 | 33840 | 32944 | 30600 | 30504 | 25300 | 18760 | 0 |
| Al masaken Alshabya | 9209 | 9389 | 8382 | 9792 | 10574 | 10176 | 12558 | 13398 | 13388 | 13661 | 11552 | 9700 |

Table 4: Demand sites in WEAP model

| Demand sites | unit | Activity level | Annual use rate m³/c/year |
|--------------------------------|-------------|-----------------------|---|
| Ein Beit Elma Zone | | | |
| Residential areas | No.people | 27228 | 36.5 |
| Health care centers | No. beds | 86 | 54.75 |
| Schools | No.people | 5794 | 3.65 |
| Institutions | No.points | 600 | 40.9 |
| Rafeedy hospital | No.points | 1 | 11315 |
| Najah University | No.points | 1 | 6935 |
| Ras Elein Zone | | | |
| Residential areas | No.people | 6303 | 36.5 |
| Health care centers | No. beds | 11 | 54.75 |
| Schools | No.people | 329 | 3.65 |
| Institutions | No.points | 123 | 40.9 |
| Southern Reservoir Zone | | | |
| Residential areas | No.people | 11132 | 36.5 |
| Health care centers | No. beds | 26 | 54.75 |
| Schools | No.people | 2225 | 3.65 |
| Institutions | No.points | 216 | 40.9 |
| Ein Dafna Zone | | | |
| Residential areas | No.people | 62188 | 36.5 |
| Health care centers | No. beds | 184 | 54.75 |
| Schools | No.people | 10302 | 3.65 |
| Institutions | No.points | 1383 | 40.9 |
| Industrial uses | No.points | 1 | 112739 |
| Sumara Zone | | | |
| Residential areas | No.people | 9107 | 36.5 |
| Health care centers | No. beds | 0 | 54.75 |

| | | | |
|--------------------------------|-----------|-------|-------|
| Schools | No.people | 1673 | 3.65 |
| Institutions | No.points | 39 | 40.9 |
| Najah University | No.points | 1 | 8030 |
| | | | |
| Northern Reservoir Zone | | | |
| Residential areas | No.people | 17527 | 36.5 |
| Health care centers | No. beds | 152 | 54.75 |
| Schools | No.people | 3824 | 3.65 |
| Institutions | No.points | 344 | 40.9 |
| Al watani Hospital | No.points | 1 | 9855 |
| | | | |
| New Reservoir Zone | | | |
| Residential areas | No.people | 3496 | 36.5 |
| Health care centers | No. beds | 5 | 54.75 |
| Schools | No.people | 699 | 3.65 |
| Institutions | No.points | 48 | 40.9 |
| Al Engely Hospital | No.points | 1 | 5110 |
| | | | |
| Al Qaryon Zone | | | |
| Residential areas | No.people | 2003 | 36.5 |
| Health care centers | No. beds | 6 | 54.75 |
| Schools | No.people | 400 | 3.65 |
| Institutions | No.points | 97 | 40.9 |
| | | | |
| AlMasaken+Askar Albalad | | | |
| Residential areas | No.people | 9615 | 36.5 |
| Health care centers | No. beds | 38 | 54.75 |
| Schools | No.people | 1923 | 3.65 |
| Institutions | No.points | 243 | 40.9 |
| | | | |

Table 5: The potential wells that can be used to supply Nablus City

| name | coordinate s | Elevation m asl | Drilling depth m | Aquifer basin | Expected pumping rate (m³/hr) | Expected pumping hours (m³/hr) | Expected pumpage (Mcm/yr) |
|--------------------------------|-------------------------|----------------------------|-----------------------------|--------------------------|---|--|--|
| Deir Sharaf well N3 | 166.35/186. 2 | 280 | 900 | Northeasten | 150 | 7300 | 1.1 |
| Deir Sharaf well N4 | 164.75/186. 0 | 240 | 800 | Northeasten | 250 | 7300 | 1.8 |
| Anabta well N1 | 162.3/189.6 5 | 185 | 850 | Western | 150 | 7300 | 1.1 |
| Anabta well N1 | 159.65/191. 00 | 120 | 750 | Western | 150 | 7300 | 1.1 |
| Azmout | 179.6/181.4 | 500 | 400 | Northeasten | 65 | 7300 | 0.5 |
| Burin | 174.1/173.4 | 520 | 700 | Northeasten | 100 | 7300 | 0.7 |
| Yutma1 | 177.0/168.5 | 510 | 500 | | 200 | 7300 | 1.5 |
| Yutm2 | 174.5/167.1 | 520 | 550 | | 200 | 7300 | 1.5 |

Table 6: The estimated water demand for the residential uses in ein beit elma zone

| year | Water demand (m3) |
|-------------|--------------------------|
| 2009 | 787543.7904 |
| 2010 | 812745.1917 |
| 2011 | 838753.0378 |
| 2012 | 865593.135 |
| 2013 | 893292.1153 |
| 2014 | 921877.463 |
| 2015 | 951377.5418 |
| 2016 | 981821.6232 |
| 2017 | 1013239.915 |
| 2018 | 1045663.592 |
| 2019 | 1079124.827 |
| 2020 | 1113656.822 |
| 2021 | 1149293.84 |
| 2022 | 1186071.243 |
| 2023 | 1224025.523 |
| 2024 | 1263194.34 |
| 2025 | 1303616.558 |
| 2026 | 1345332.288 |
| 2027 | 1388382.921 |
| 2028 | 1432811.175 |
| 2029 | 1478661.133 |
| 2030 | 1525978.289 |
| 2031 | 1574809.594 |
| 2032 | 1625203.501 |
| 2033 | 1677210.013 |
| 2034 | 1730880.734 |
| 2035 | 1786268.917 |

Table 7. Reference scenario results

| year | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 |
|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Water demand(70l/cd) | 4624931 | 4738133 | 4854299 | 4973508 | 5095840 | 5221375 | 5350199 | 5482398 | 5618060 |
| Water demand(100l/cd) | 6419797 | 6579665 | 6743711 | 6912044 | 7084778 | 7262026 | 7443907 | 7630542 | 7822056 |
| The unmet water demand under management options | | | | | | | | | |
| No supply development(70l/cd) | 1243625 | 1327083 | 1412726 | 1500612 | 1591492 | 1689243 | 1789554 | 1892492 | 1998127 |
| No supply development(100l/cd) | 2635539 | 2789479 | 2947442 | 3109533 | 3275860 | 3446535 | 3621671 | 3801385 | 3985796 |
| Construction Sabastia well | 822219 | 976159 | 1134122 | 1296213 | 1462540 | 1462540 | 1808351 | 1988065 | 2172476 |
| Reduction inwater leakage | 2416077 | 2540616 | 2668408 | 2801216 | 2967543 | 2967543 | 3313354 | 3493068 | 3677479 |
| Stormwater harvesting | 1255539 | 1409479 | 1567442 | 1729533 | 1895860 | 1895860 | 2241671 | 2421385 | 2605796 |
| Rehabilitation of springs | 2519822 | 2650082 | 2808044 | 2970135 | 3136463 | 3136463 | 3482274 | 3661987 | 3846399 |
| Development of new wells | 2635539 | 2789479 | 2947442 | 3109533 | 3275860 | 3275860 | 2862671 | 3042385 | 3226796 |
| year | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 |
| Water demand(70l/cd) | 5757277 | 5900140 | 6046747 | 6197195 | 6351586 | 6510022 | 6672609 | 6839458 | 7010680 |
| Water demand(100l/cd) | 8018576 | 8220233 | 8427163 | 8639502 | 8857392 | 9080979 | 9310412 | 9545843 | 9787431 |
| The unmet water demand under management options | | | | | | | | | |
| No supply development(70l/cd) | 2106527 | 2217767 | 2331921 | 2449064 | 2569656 | 2722211 | 2878763 | 3039417 | 3204282 |
| No supply development(100l/cd) | 4175028 | 4369206 | 4568461 | 4772925 | 4982734 | 5198028 | 5418951 | 5645651 | 5878278 |
| Construction Sabastia well | 2361708 | 2555886 | 2755141 | 2959605 | 3169414 | 3384708 | 3605631 | 3832331 | 4064958 |
| Reduction inwater leakage | 3866711 | 4060889 | 4260144 | 4464608 | 4674417 | 4889711 | 5110634 | 5337334 | 5569960 |
| Stormwater harvesting | 2795028 | 2989206 | 3188461 | 3392925 | 3602734 | 3818028 | 4038951 | 4265651 | 4498278 |
| Rehabilitation of springs | 4035631 | 4229809 | 4429064 | 4633527 | 4843337 | 5058631 | 5279554 | 5506253 | 5738880 |
| Development of new wells | 3416028 | 3610206 | 2567461 | 2771925 | 2981734 | 3197028 | 3417951 | 2609651 | 2842278 |
| year | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Water demand(70l/cd) | 7186389 | 7366703 | 7551743 | 7741634 | 7936503 | 8136480 | 8341699 | 8552299 | 8768421 |
| Water demand(100l/cd) | 1E+07 | 1E+07 | 1.1E+07 | 1.1E+07 | 1.1E+07 | 1.1E+07 | 1.2E+07 | 1.2E+07 | 1.2E+07 |
| The unmet water demand under management options | | | | | | | | | |
| No supply development(70l/cd) | 3373467 | 3547087 | 3725258 | 3908098 | 4095731 | 4288283 | 4485883 | 4688663 | 4896760 |
| No supply development(100l/cd) | 6116987 | 6361938 | 6613295 | 6871224 | 7135899 | 7407495 | 7686194 | 7972183 | 8265651 |
| Construction Sabastia well | 4303667 | 4548618 | 4799975 | 5057904 | 5322579 | 5594175 | 5872874 | 6158863 | 6452331 |
| Reduction inwater leakage | 5808670 | 6053621 | 6304978 | 6562907 | 6827582 | 7099178 | 7377877 | 7663865 | 7957333 |
| Stormwater harvesting | 4736987 | 4981938 | 5233295 | 5491224 | 5755899 | 6027495 | 6306194 | 6592183 | 6885651 |
| Rehabilitation of springs | 5977590 | 6222541 | 6473898 | 6731827 | 6996502 | 7268098 | 7546797 | 7832785 | 8126253 |
| Development of new wells | 3080987 | 3325938 | 3577295 | 2800224 | 3064899 | 3336495 | 3615194 | 3901183 | 4194651 |

Table 8: Population growth increase scenario results

| year | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 |
|---|--------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Water demand | 6513205 | 6699692 | 6891773 | 7089616 | 7293395 | 7503288 | 7719477 | 7942151 | 8171506 |
| The unmet water demand under management options | | | | | | | | | |
| No supply development | 2725494 | 2905068 | 3090029 | 3280539 | 3476765 | 3678877 | 3887052 | 4101473 | 4322326 |
| Construction Sabastia well | 912174 | 1091748 | 1276709 | 1467219 | 1663445 | 1865557 | 2073732 | 2288153 | 2509006 |
| Reduction inwater leakage | 2488943 | 2634246 | 2783908 | 2972222 | 3168447 | 3370560 | 3578735 | 3793156 | 4014009 |
| Stormwater harvesting | 1345960 | 1525669 | 1710774 | 1901436 | 2097823 | 2300106 | 2508463 | 2723075 | 2944131 |
| Rehabilitation of springs | 2592687 | 2765671 | 2950632 | 3141142 | 3337367 | 3539479 | 3747655 | 3962076 | 4182929 |
| Development of new wells | 2725494 | 2905068 | 3090029 | 3280539 | 3476765 | 3678877 | 3128052 | 3342473 | 3563326 |
| year | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 |
| Water demand | 8407742 | 8651065 | 8901687 | 9159828 | 9425713 | 9699575 | 9981653 | 1E+07 | 1.1E+07 |
| The unmet water demand under management options | | | | | | | | | |
| no supply development | 4549805 | 4784109 | 5025441 | 5274014 | 5530043 | 5793754 | 6065375 | 6345146 | 6633309 |
| Construction Sabastia well | 2736485 | 2970789 | 3212121 | 3460694 | 3716723 | 3980434 | 4252055 | 4531826 | 4819989 |
| Reduction inwater leakage | 4241488 | 4475791 | 4717124 | 4965696 | 5221726 | 5485436 | 5757058 | 6036829 | 6324992 |
| Stormwater harvesting | 3171823 | 3406353 | 3647924 | 3896748 | 4153043 | 4417033 | 4688949 | 4969030 | 5257521 |
| Rehabilitation of springs | 4410408 | 4644711 | 4886044 | 5134616 | 5390646 | 5654356 | 5925978 | 6205748 | 6493912 |
| Development of new wells | 3790805 | 4025109 | 3024441 | 3273014 | 3529043 | 3792754 | 4064375 | 3916146 | 4204309 |
| year | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Water demand | 1.1E+07 | 1.1E+07 | 1.2E+07 | 1.2E+07 | 1.2E+07 | 1.3E+07 | 1.3E+07 | 1.3E+07 | 1.4E+07 |
| The unmet water demand under management options | | | | | | | | | |
| no supply development | 6930118 | 7235830 | 7550715 | 7875045 | 8209106 | 8553188 | 8907593 | 9272630 | 9648618 |
| Construction Sabastia well | 5116798 | 5422510 | 5737395 | 6061725 | 6395786 | 6739868 | 7094273 | 7459310 | 7835298 |
| Reduction inwater leakage | 6621800 | 6927513 | 7242397 | 7566728 | 7900788 | 8244871 | 8599276 | 8964312 | 9340301 |
| Stormwater harvesting | 5554673 | 5860748 | 6176013 | 6500744 | 6835225 | 7179750 | 7534619 | 7900144 | 8276644 |
| Rehabilitation of springs | 6790720 | 7096433 | 7411317 | 7735648 | 8069708 | 8413791 | 8768195 | 9133232 | 9509220 |
| Development of new wells | 5E+06 | 4806830 | 5121715 | 4618045 | 4952106 | 5296188 | 5650593 | 6015630 | 6391618 |

Table 9. Climate change Scenario results

| year | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 |
|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Water demand | 6419797 | 6579665 | 6743711 | 6912044 | 7084778 | 7262026 | 7443907 | 7630542 | 7822056 |
| The unmet water demand under management options | | | | | | | | | |
| No supply development | 3344669 | 3498609 | 3656571 | 3818662 | 3984990 | 4155665 | 4330801 | 4510515 | 4694926 |
| Construction Sabastia well | 1894013 | 2047953 | 2205915 | 2368006 | 2534334 | 2705009 | 2880145 | 3059859 | 3244270 |
| Reduction inwater leakage | 3098015 | 3251955 | 3409918 | 3572009 | 3738336 | 3909011 | 4084147 | 4263861 | 4448272 |
| Stormwater harvesting | 2240669 | 2394609 | 2552571 | 2714662 | 2880990 | 3051665 | 3226801 | 3406515 | 3590926 |
| Rehabilitation of springs | 3233151 | 3387091 | 3545053 | 3707145 | 3873472 | 4044147 | 4219283 | 4398997 | 4583408 |
| Development of new wells | 3344669 | 3498609 | 3656571 | 3818662 | 3984990 | 4155665 | 3845041 | 4024755 | 4209166 |
| year | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 |
| Water demand | 8018576 | 8220233 | 8427163 | 8639502 | 8857392 | 9080979 | 9310412 | 9545843 | 9787431 |
| The unmet water demand under management options | | | | | | | | | |
| no supply development | 4884158 | 5078336 | 5277591 | 5482055 | 5691864 | 5907158 | 6128081 | 6354781 | 6587407 |
| Construction Sabastia well | 3433502 | 3627680 | 3826935 | 4031399 | 4241208 | 4456502 | 4677425 | 4904125 | 5136751 |
| Reduction inwater leakage | 4637504 | 4831682 | 5030937 | 5235401 | 5445210 | 5660504 | 5881427 | 6108127 | 6340754 |
| Stormwater harvesting | 3780158 | 3974336 | 4173591 | 4378055 | 4587864 | 4803158 | 5024081 | 5250781 | 5483407 |
| Rehabilitation of springs | 4772640 | 4966818 | 5166073 | 5370537 | 5580346 | 5795640 | 6016563 | 6243263 | 6475889 |
| Development of new wells | 4276958 | 4471136 | 3676791 | 3881255 | 4091064 | 4306358 | 4527281 | 3925981 | 4158607 |
| year | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Water demand | 1E+07 | 1E+07 | 1.1E+07 | 1.1E+07 | 1.1E+07 | 1.1E+07 | 1.2E+07 | 1.2E+07 | 1.2E+07 |
| The unmet water demand under management options | | | | | | | | | |
| no supply development | 6826117 | 7071068 | 7322425 | 7580354 | 7845029 | 8116625 | 8395324 | 8681312 | 8974780 |
| Construction Sabastia well | 5375461 | 5620412 | 5871769 | 6129698 | 6394373 | 6665969 | 6944668 | 7230656 | 7524124 |
| Reduction inwater leakage | 6579463 | 6824414 | 7075771 | 7333700 | 7598375 | 7869971 | 8148670 | 8434659 | 8728127 |
| Stormwater harvesting | 5722117 | 5967068 | 6218425 | 6476354 | 6741029 | 7012625 | 7291324 | 7577312 | 7870780 |
| Rehabilitation of springs | 6714599 | 6959550 | 7210907 | 7468836 | 7733511 | 8005107 | 8283806 | 8569794 | 8863262 |
| Development of new wells | 4397317 | 4642268 | 4893625 | 4323554 | 4588229 | 4859825 | 5138524 | 5424512 | 5717980 |

Table 10. Using WHO standard use rate

| year | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 |
|---|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| Water demand | 9424961 | 9662963 | 9907175 | 10157759 | 10414880 | 10678711 | 10949426 | 11227205 | 11512232 |
| The unmet water demand under the management options | | | | | | | | | |
| No water supply development | 5529496 | 5758678 | 5993840 | 6235137 | 6482731 | 6736784 | 6997466 | 7264951 | 7539415 |
| Construction of Sabastia well | 3716176 | 3945358 | 4180520 | 4421817 | 4669411 | 4923464 | 5184146 | 5451631 | 5726095 |
| Reduction in water leakage | 5221178 | 5450361 | 5685523 | 5926820 | 6174413 | 6428467 | 6689149 | 6956634 | 7231098 |
| Stormwater harvesting | 4149496 | 4378678 | 4613840 | 4855137 | 5102731 | 5356784 | 5617466 | 5884951 | 6159415 |
| Rehabilitation of springs | 5390098 | 5619281 | 5854442 | 6095740 | 6343333 | 6597387 | 6858069 | 7125553 | 7400017 |
| Development of new wells | 5529496 | 5758678 | 5993840 | 6235137 | 6482731 | 6736784 | 6238466 | 6505951 | 6780415 |
| year | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 |
| Water demand | 11804697 | 12104793 | 12412721 | 12728684 | 13052894 | 13385564 | 13726916 | 14077176 | 14436578 |
| The unmet water demand under management options | | | | | | | | | |
| No water supply development | 7821041 | 8110016 | 8406531 | 8710785 | 9022978 | 9343319 | 9672020 | 10009299 | 10355381 |
| Construction Sabastia well | 6007721 | 6296696 | 6593211 | 6897465 | 7209658 | 7529999 | 7858700 | 8195979 | 8542061 |
| Reduction inwater leakage | 7512724 | 7801698 | 8098214 | 8402468 | 8714661 | 9035002 | 9363702 | 9700982 | 10047063 |
| Stormwater harvesting | 6441041 | 6730016 | 7026531 | 7330785 | 7642978 | 7963319 | 8292020 | 8629299 | 8975381 |
| Rehabilitation of springs | 7681643 | 7970618 | 8267134 | 8571387 | 8883581 | 9203922 | 9532622 | 9869902 | 10215983 |
| Development of new wells | 7062041 | 7351016 | 6405531 | 6709785 | 7021978 | 7342319 | 7671020 | 6973299 | 7319381 |
| year | 2027 | 2028 | 2029 | 2030 | 2031 | 2032 | 2033 | 2034 | 2035 |
| Water demand | 14805361 | 15183768 | 15572052 | 15970471 | 16379290 | 16798779 | 17229218 | 17670894 | 18124099 |
| The unmet water demand under The management options | | | | | | | | | |
| No water supply development | 10710495 | 11074877 | 11448770 | 11832422 | 12226088 | 12630029 | 13044514 | 13469818 | 13906225 |
| Construction of Sabastia well | 8897175 | 9261557 | 9635450 | 10019102 | 10412768 | 10816709 | 11231194 | 11656498 | 12092905 |
| Reduction in water leakage | 10402177 | 10766560 | 11140453 | 11524105 | 11917770 | 12321712 | 12736197 | 13161501 | 13597908 |
| Stormwater harvesting | 9330495 | 9694877 | 10068770 | 10452422 | 10846088 | 11250029 | 11664514 | 12089818 | 12526225 |
| Rehabilitation of springs | 10571097 | 10935480 | 11309373 | 11693025 | 12086690 | 12490631 | 12905117 | 13330421 | 13766828 |
| Development of new wells | 7674495 | 8038877 | 8412770 | 7761422 | 8155088 | 8559029 | 8973514 | 9398818 | 9835225 |

Table 11: Reference Scenario results considering one demand site and one water source

| Reference Scenario | | | | | | | | | |
|---------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 70 l/cd | 4.738 | 5.35 | 6.839 | 8.768 | 0.00 | 0.575 | 2.064 | 3.993 |
| | With no water supply development using 100 l/cd | 6.579 | 7.44 | 9.54 | 12.26 | 1.804 | 2.665 | 4.765 | 7.4854 |
| 2 | Construction of Sabastia well | | | | | 0.008 | 0.852 | 2.95 | 5.672 |
| 3 | Reduction in water leakage | | | | | 1.389 | 2.25 | 4.35 | 7.07 |
| 4 | Stormwater harvesting | | | | | 0.424 | 1.285 | 3.385 | 6.105 |
| 5 | Rehabilitation of springs | | | | | 1.665 | 2.526 | 4.626 | 7.3460 |
| 6 | Development of new wells | | | | | 1.804 | 1.906 | 1.729 | 3.415 |

Table 12: Population growth increase scenario results considering one demand site and one water source

| Population growth increases | | | | | | | | | |
|-----------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 100 l/cd | 6.699 | 7.719 | 10.27 | 13.702 | 1.924 | 2.944 | 5.495 | 8.927 |
| 2 | Construction of Sabastia well | | | | | 0.111 | 1.131 | 3.682 | 7.114 |
| 3 | Reduction in water leakage | | | | | 1.509 | 2.529 | 5.080 | 8.512 |
| 4 | Stormwater harvesting | | | | | 0.544 | 1.564 | 4.115 | 7.547 |
| 5 | Rehabilitation of springs | | | | | 1.785 | 2.805 | 5.356 | 8.788 |
| 6 | Development of new wells | | | | | 1.165 | 2.185 | 2.459 | 4.857 |

Table 13: Climate change scenario results considering one demand site and one water source

| Climate change scenario | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
|-------------------------|---|--------------------|------|------|-------|--------------------------|-------|-------|--------|
| | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 100 l/cd | 6.579 | 7.44 | 9.54 | 12.26 | 2.759 | 3.620 | 5.720 | 8.4403 |
| 2 | Construction of Sabastia well | | | | | 1.308 | 2.169 | 4.269 | 6.9896 |
| 3 | Reduction in water leakage | | | | | 2.427 | 3.288 | 5.388 | 8.1081 |
| 4 | Stormwater harvesting | | | | | 1.655 | 2.516 | 4.616 | 7.3363 |
| 5 | Rehabilitation of springs | | | | | 2.647 | 3.508 | 5.608 | 8.3288 |
| 6 | Development of new wells | | | | | 2.759 | 3.013 | 3.291 | 5.184 |

Table 14: Using WHO daily use rate standard scenario results considering one demand site and one water source

| Using WHO daily use rate standard | | | | | | | | | |
|-----------------------------------|---|---------------------------|-------------|-------------|-------------|---------------------------------|-------------|-------------|-------------|
| | | Water demand (mcm) | | | | Unmet water demand (mcm) | | | |
| Management options | | 2010 | 2015 | 2025 | 2035 | 2010 | 2015 | 2025 | 2035 |
| 1 | With no water supply development using 100 l/cd | 9.66 | 10.95 | 14.07 | 18.12 | 4.885 | 6.175 | 9.2954 | 13.345 |
| 2 | Construction of Sabastia well | | | | | 3.072 | 4.362 | 7.4821 | 11.532 |
| 3 | Reduction in water leakage | | | | | 4.470 | 5.760 | 8.8801 | 12.930 |
| 4 | Stormwater harvesting | | | | | 3.505 | 4.795 | 7.9153 | 11.965 |
| 5 | Rehabilitation of springs | | | | | 4.746 | 6.036 | 9.1560 | 13.206 |
| 6 | Development of new wells | | | | | 4.885 | 5.416 | 6.2594 | 9.275 |

APPENDIX B

FIGURES




Figure 1: shows pumping stations and reservoirs



Aljunied Pumping Station



Ein Beit Elma Pumping Station , and Reservoir



Deir Sharaf Pumping station



Ein Dafna Pumping Station



Northern Pumping Station and Reservoir



Southern Pumping Station and Reservoir



Ras Elein Pumping Station and Reservoir



Alsumara Pumping Station




Figure 2 : The expected expansion area in Nablus City

جامعة النجاح الوطنية
كلية الدراسات العليا

تقييم إدارة التزود للمياه في مدينة نابلس باستخدام برنامج
(WEAP)

إعداد
رحمه عثمان خضر عبده

إشراف
د. محمد المصري
د. أمال الهدهد

قدمت هذه الأطروحة استكمالاً لمتطلبات درجة الماجستير في هندسة المياه و البيئة
بكلية الدراسات العليا، جامعة النجاح الوطنية، نابلس، فلسطين

2009

تقييم إدارة التزود للمياه في مدينة نابلس باستخدام برنامج

(WEAP)

إعداد

رحمه عثمان خضر عبده

إشراف

د. محمد المصري

د. أمال الهدهد

الملخص

يعاني الفلسطينيون من نقص حاد لمصادر المياه نتيجة للقيود التي فرضها الاحتلال الإسرائيلي على الفلسطينيين والتي تعوق دون تطوير مصادر جديدة و تحد من توفر المياه للفلسطينيين. و تفقر الضفة الغربية لبنية تحتية جيدة لتوفير المياه مما تسبب في فقدان كميات كبيرة من المياه بالإضافة إلى عدم توفر الدعم المالي لمشاريع جديدة، بالتالي بعض المدن الرئيسية في الضفة الغربية كمدينة نابلس تعاني من مشكلة في توزيع المياه إلى المستهلكين بكميات كافية.

تم استخدام برنامج WEAP في هذه الدراسة لتقييم الخيارات لدى بلدية نابلس لتقليل الفجوة بين الطلب والتزود. تكونت منهجية الدراسة مما يلي: (1) جمع البيانات اللازمة (2) التدريب على برنامج (WEAP) و تطبيقاته (3) نمذجة نظام مصادر المياه في مدينة نابلس باستخدام برنامج (WEAP) بهدف محاكاة الواقع لدراسة و تقييم الخيارات المختلفة .

تشير النتائج التي حصلنا عليها أن الطلب على المياه يتزايد بتزايد عدد السكان على مدى سنوات الدراسة، وإذا استمر الوضع الحالي بوجود نفس كميات المياه فان الفجوة بين مقدار التزود و الطلب على المياه سوف تزداد اتساعا. لذا تطوير مصادر إضافية أصبحت حاجة ملحة لمواجهة الطلب المتزايد للمياه، و أيضا استغلال الحصاد المائي و تحسين البنية التحتية للمدينة لتقليل الفاقد من المياه من الأمور المهمة لتقليل الفجوة بين التزود و الطلب.